

**Mėnesinė ataskaita**



Plant: Kauno kogeneraci

Report time: vas. - 2026

Date of creation: 01-03-2026 05:01

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	5.00	DLV:	6.00	DLV:	30,00	DLV:	1,00	DLV:	50,00	DLV:	10,00
01-02-26	V	0,01	V	0,75	V	1,16	V	0,20	V	11,65	V	0,07
02-02-26	V	0,00	V	0,75	V	1,17	V	0,25	V	11,88	V	0,07
03-02-26	V	0,04	V	0,75	V	1,18	V	0,20	V	11,78	V	0,12
04-02-26	V	0,00	V	0,75	V	1,15	V	0,18	V	10,78	V	0,11
05-02-26	V	0,00	V	0,74	V	1,03	V	0,19	V	11,22	V	0,23
06-02-26	V	0,00	V	0,74	V	1,58	V	0,19	V	11,11	V	0,23
07-02-26	V	0,02	V	0,74	V	0,86	V	0,19	V	12,32	V	0,36
08-02-26	V	0,00	V	0,72	V	0,82	V	0,21	V	10,09	V	0,22
09-02-26	V	0,00	V	0,74	V	1,08	V	0,22	V	11,26	V	0,21
10-02-26	V	0,03	V	0,75	V	1,12	V	0,20	V	11,04	V	0,15
11-02-26	V	0,07	V	0,75	V	0,91	V	0,23	V	9,72	V	0,32
12-02-26	V	0,03	V	0,74	V	0,93	V	0,21	V	12,54	V	0,24
13-02-26	V	0,00	V	0,74	V	1,07	V	0,19	V	14,07	V	0,19
14-02-26	V	0,01	V	0,75	V	0,94	V	0,20	V	13,11	V	0,10
15-02-26	V	0,00	V	0,73	V	1,02	V	0,24	V	9,67	V	0,08
16-02-26	V	0,01	V	0,75	V	1,03	V	0,27	V	9,75	V	0,10
17-02-26	V	0,02	V	0,73	V	1,08	V	0,24	V	9,72	V	0,08
18-02-26	V	0,03	V	0,74	V	0,99	V	0,22	V	10,29	V	0,14
19-02-26	V	0,13	V	0,72	V	0,77	V	0,20	V	10,16	V	0,23
20-02-26	V	0,00	V	0,71	V	1,02	V	0,21	V	10,92	V	0,19
21-02-26	V	0,00	V	0,70	V	0,98	V	0,20	V	10,07	V	0,21
22-02-26	V	0,05	V	0,70	V	0,62	V	0,18	V	9,54	V	0,23
23-02-26	V	0,02	V	0,70	V	0,55	V	0,17	V	9,88	V	0,26
24-02-26	V	0,12	V	0,69	V	0,88	V	0,17	V	7,97	V	0,23
25-02-26	V	0,00	V	0,71	V	0,69	V	0,19	V	9,57	V	0,16
26-02-26	V	0,01	V	0,71	V	1,13	V	0,20	V	11,52	V	0,17
27-02-26	V	0,10	V	0,71	V	1,51	V	0,19	V	9,51	V	0,22
28-02-26	V	0,14	V	0,72	V	1,30	V	0,20	V	6,18	V	0,15
MAV		0,03		0,73		1,02		0,21		10,62		0,18

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneraci

Report time: vas. - 2026

Date of creation: 01-03-2026 05:01

Date	NOx		NH <sub>3</sub>		Hg		O <sub>2</sub>		H <sub>2</sub> O		Kamino T	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C
	DLV:	150.00	DLV:	10.00	DLV:	0.02						
01-02-26	V	110,98	V	0,92	V	0,0006	V	9,41	V	12,69	V	51,92
02-02-26	V	108,18	V	0,93	V	0,0006	V	9,37	V	13,34	V	52,33
03-02-26	V	111,54	V	0,93	V	0,0006	V	9,44	V	13,30	V	51,22
04-02-26	V	110,96	V	0,93	V	0,0006	V	9,41	V	13,05	V	50,91
05-02-26	V	107,75	V	0,91	V	0,0006	V	9,27	V	12,47	V	49,46
06-02-26	V	105,56	V	0,98	V	0,0006	V	9,42	V	11,91	V	47,68
07-02-26	V	102,08	V	0,92	V	0,0006	V	9,43	V	11,63	V	47,17
08-02-26	V	110,97	V	0,89	V	0,0006	V	9,08	V	11,49	V	47,70
09-02-26	V	106,80	V	0,92	V	0,0006	V	9,31	V	12,66	V	50,17
10-02-26	V	109,69	V	0,96	V	0,0006	V	9,46	V	12,61	V	50,21
11-02-26	V	115,66	V	0,93	V	0,0006	V	9,47	V	12,39	V	48,02
12-02-26	V	104,56	V	0,92	V	0,0006	V	9,47	V	11,22	V	45,48
13-02-26	V	105,95	V	0,91	V	0,0006	V	9,46	V	11,17	V	45,47
14-02-26	V	105,04	V	0,91	V	0,0006	V	9,44	V	11,45	V	47,96
15-02-26	V	103,45	V	0,91	V	0,0006	V	9,30	V	11,87	V	49,62
16-02-26	V	106,96	V	0,92	V	0,0006	V	9,38	V	12,98	V	50,79
17-02-26	V	106,74	V	0,91	V	0,0006	V	9,25	V	12,39	V	49,73
18-02-26	V	101,07	V	0,92	V	0,0006	V	9,47	V	11,44	V	47,71
19-02-26	V	100,63	V	0,90	V	0,0007	V	9,23	V	11,23	V	46,66
20-02-26	V	110,96	V	0,88	V	0,0006	V	9,16	V	10,58	V	45,79
21-02-26	V	111,41	V	0,86	V	0,0006	V	8,94	V	9,99	V	45,03
22-02-26	V	97,03	V	0,87	V	0,0007	V	9,06	V	9,73	V	43,50
23-02-26	V	96,93	V	0,86	V	0,0007	V	8,96	V	9,66	V	43,13
24-02-26	V	99,07	V	0,85	V	0,0006	V	8,86	V	9,94	V	43,60
25-02-26	V	90,67	V	0,88	V	0,0006	V	9,24	V	9,85	V	44,28
26-02-26	V	111,16	V	0,87	V	0,0006	V	9,22	V	9,63	V	44,33
27-02-26	V	109,57	V	0,85	V	0,0005	V	9,18	V	9,16	V	42,79
28-02-26	V	106,84	V	0,85	V	0,0005	V	8,80	V	12,15	V	47,52
MAV		106,01		0,90		0,0006		9,27		11,50		47,50

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

# Mėnesinė ataskaita

Plant:

Report time: vas.- 2026

Date of creation: 01-03-2026 05:01

Date	Slėgis		Srautas		Degimo T	
	Unit:	hPa	Unit:	Nm³/h	Unit:	°C
			DLV:	240000,00	DLV:	850,00
01-02-26	V	1014,96	V	136630,25	V	963,72
02-02-26	V	1010,86	V	133662,04	V	960,58
03-02-26	V	1010,46	V	131347,21	V	960,19
04-02-26	V	1009,56	V	131225,81	V	958,85
05-02-26	V	1000,04	V	129268,27	V	969,56
06-02-26	V	993,20	V	128148,86	V	959,83
07-02-26	V	995,71	V	127519,38	V	957,53
08-02-26	V	1005,28	V	128010,21	V	971,17
09-02-26	V	1008,34	V	130670,75	V	969,69
10-02-26	V	996,24	V	131634,05	V	964,94
11-02-26	V	982,29	V	128383,95	V	973,15
12-02-26	V	975,04	V	128776,59	V	969,19
13-02-26	V	974,72	V	130494,08	V	962,82
14-02-26	V	990,55	V	132864,50	V	959,59
15-02-26	V	1004,90	V	133764,65	V	961,75
16-02-26	V	999,49	V	132374,73	V	961,65
17-02-26	V	999,75	V	130787,31	V	966,62
18-02-26	V	999,10	V	131932,23	V	949,10
19-02-26	V	997,76	V	128792,70	V	959,05
20-02-26	V	1010,28	V	126900,31	V	962,12
21-02-26	V	1005,98	V	123425,98	V	966,91
22-02-26	V	998,83	V	123625,21	V	959,29
23-02-26	V	993,20	V	122841,03	V	967,58
24-02-26	V	996,78	V	123158,40	V	980,33
25-02-26	V	1010,13	V	128073,77	V	971,19
26-02-26	V	1015,87	V	129425,67	V	970,80
27-02-26	V	1008,68	V	124593,76	V	972,30
28-02-26	V	1006,99	V	117978,83	V	974,01
MAV		1000,57		128799,01		965,14

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value