

**Mėnesinė ataskaita**



Plant: Kauno kogeneraci

Report time: geg.- 2026

Date of creation: 01-06-2026 05:01

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	5,00	DLV:	6,00	DLV:	30,00	DLV:	1,00	DLV:	50,00	DLV:	10,00
01-05-26	V	0,03	V	0,65	V	1,47	V	0,24	V	7,58	V	0,27
02-05-26	V	0,21	V	0,65	V	1,72	V	0,20	V	6,23	V	0,28
03-05-26	V	0,07	V	0,67	V	1,83	V	0,20	V	7,86	V	0,23
04-05-26	V	0,07	V	0,69	V	1,90	V	0,19	V	7,10	V	0,26
05-05-26	V	0,01	V	0,71	V	1,94	V	0,20	V	7,74	V	0,26
06-05-26	V	0,02	V	0,70	V	1,89	V	0,22	V	7,43	V	0,17
07-05-26	V	0,01	V	0,66	V	1,74	V	0,21	V	8,82	V	0,35
08-05-26	V	0,22	V	0,67	V	1,72	V	0,19	V	6,64	V	0,27
09-05-26	V	0,10	V	0,66	V	1,64	V	0,19	V	8,52	V	0,29
10-05-26	V	0,01	V	0,68	V	1,69	V	0,19	V	7,35	V	0,32
11-05-26	V	0,08	V	0,68	V	1,73	V	0,20	V	6,80	V	0,24
12-05-26	V	0,18	V	0,68	V	1,76	V	0,18	V	9,26	V	0,22
13-05-26	V	0,08	V	0,69	V	1,76	V	0,20	V	11,83	V	0,18
14-05-26	V	0,04	V	0,70	V	1,77	V	0,21	V	19,37	V	0,27
15-05-26	V	0,08	V	0,72	V	1,92	V	0,24	V	8,72	V	0,23
16-05-26	V	0,00	V	0,72	V	1,87	V	0,25	V	10,35	V	0,21
17-05-26	V	0,01	V	0,73	V	1,84	V	0,22	V	10,02	V	0,20
18-05-26	V	0,00	V	0,71	V	1,68	V	0,22	V	12,07	V	0,17
19-05-26	V	0,00	V	0,74	V	1,79	V	0,21	V	10,57	V	0,18
20-05-26	V	0,04	V	0,75	V	1,79	V	0,23	V	14,77	V	0,22
21-05-26	V	0,01	V	0,73	V	1,78	V	0,21	V	9,42	V	0,22
22-05-26	V	0,02	V	0,73	V	1,82	V	0,19	V	8,01	V	0,24
23-05-26	V	0,00	V	0,77	V	1,93	V	0,21	V	11,28	V	0,19
24-05-26	V	0,01	V	0,76	V	1,90	V	0,20	V	13,78	V	0,26
25-05-26	V	0,29	V	0,77	V	1,95	V	0,23	V	14,75	V	0,29
26-05-26	V	0,03	V	0,81	V	2,06	V	0,22	V	7,22	V	0,29
27-05-26	V	0,03	V	0,80	V	1,85	V	0,24	V	14,05	V	0,30
28-05-26	V	0,00	V	0,79	V	1,77	V	0,24	V	10,87	V	0,20
29-05-26	V	0,01	V	0,73	V	1,62	V	0,23	V	8,55	V	0,23
30-05-26	V	0,00	V	0,72	V	1,61	V	0,19	V	7,13	V	0,26
31-05-26	V	0,01	V	0,70	V	1,46	V	0,18	V	8,20	V	0,23
MAV		0,05		0,72		1,78		0,21		9,72		0,24

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneraci

Report time: geg.- 2026

Date of creation: 01-06-2026 05:01

Date	NOx		NH <sub>3</sub>		Hg		O <sub>2</sub>		H <sub>2</sub> O		Kamino T	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C
DLV:	150.00	DLV:	10.00	DLV:	0.02							
01-05-26	V	73,42	V	0,80	V	0,0006	V	8,03	V	9,80	V	43,73
02-05-26	V	70,28	V	0,81	V	0,0006	V	8,09	V	10,48	V	44,87
03-05-26	V	66,87	V	0,83	V	0,0006	V	8,12	V	12,17	V	47,62
04-05-26	V	66,31	V	0,85	V	0,0007	V	7,94	V	15,73	V	53,13
05-05-26	V	68,73	V	0,88	V	0,0007	V	8,07	V	17,07	V	55,02
06-05-26	V	72,57	V	0,86	V	0,0007	V	7,99	V	16,38	V	54,41
07-05-26	V	65,97	V	0,82	V	0,0006	V	7,69	V	13,56	V	49,74
08-05-26	V	78,94	V	0,83	V	0,0007	V	7,86	V	13,53	V	50,06
09-05-26	V	76,90	V	0,82	V	0,0007	V	7,81	V	13,30	V	49,87
10-05-26	V	77,35	V	0,86	V	0,0007	V	8,09	V	13,97	V	50,54
11-05-26	V	73,72	V	0,85	V	0,0007	V	8,17	V	13,13	V	49,04
12-05-26	V	77,60	V	0,86	V	0,0008	V	8,16	V	13,58	V	49,21
13-05-26	V	75,68	V	0,88	V	0,0007	V	8,16	V	13,97	V	49,84
14-05-26	V	78,57	V	0,86	V	0,0007	V	8,56	V	12,54	V	47,93
15-05-26	V	83,89	V	0,89	V	0,0007	V	9,03	V	12,53	V	47,84
16-05-26	V	81,80	V	0,89	V	0,0007	V	8,81	V	13,42	V	48,97
17-05-26	V	77,47	V	0,90	V	0,0007	V	8,77	V	14,47	V	50,87
18-05-26	V	80,65	V	0,87	V	0,0008	V	8,43	V	14,29	V	50,89
19-05-26	V	85,03	V	0,92	V	0,0009	V	8,90	V	15,16	V	51,75
20-05-26	V	86,02	V	0,92	V	0,0007	V	9,10	V	14,43	V	51,01
21-05-26	V	81,06	V	0,91	V	0,0008	V	8,94	V	13,71	V	49,64
22-05-26	V	76,00	V	0,90	V	0,0008	V	8,88	V	13,80	V	50,29
23-05-26	V	85,81	V	0,96	V	0,0008	V	9,49	V	14,71	V	51,86
24-05-26	V	91,81	V	0,94	V	0,0008	V	9,29	V	14,42	V	51,10
25-05-26	V	94,92	V	0,95	V	0,0007	V	9,58	V	13,75	V	50,01
26-05-26	V	95,75	V	1,01	M	0,0007	V	10,29	V	13,01	V	48,60
27-05-26	V	84,51	V	1,04	V	0,0006	V	10,22	V	12,35	V	47,78
28-05-26	V	84,16	V	0,99	V	0,0006	V	10,05	V	12,44	V	47,94
29-05-26	V	81,82	V	0,92	V	0,0005	V	9,08	V	12,74	V	48,46
30-05-26	V	78,06	V	1,06	V	0,0005	V	8,67	V	14,71	V	51,56
31-05-26	V	78,05	V	0,87	V	0,0006	V	8,28	V	14,88	V	51,62
MAV		78,99		0,89		0,0007		8,66		13,68		49,85

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: geg.- 2026

Date of creation: 01-06-2026 05:01

Date	Slėgis		Srautas		Degimo T	
	Unit:	hPa	Unit:	Nm³/h	Unit:	°C
			DLV:	240000,00	DLV:	850,00
01-05-26	V	1011,76	V	110456,62	V	984,43
02-05-26	V	1007,59	V	108252,82	V	983,64
03-05-26	V	1001,40	V	105493,42	V	990,82
04-05-26	V	997,43	V	107826,30	V	998,96
05-05-26	V	997,77	V	109430,69	V	997,15
06-05-26	V	996,59	V	109111,29	V	1006,72
07-05-26	V	997,81	V	106373,37	V	1004,81
08-05-26	V	1005,52	V	108585,22	V	1000,88
09-05-26	V	1006,48	V	109040,89	V	999,00
10-05-26	V	1003,55	V	110633,43	V	993,18
11-05-26	V	996,16	V	109548,27	V	984,86
12-05-26	V	987,53	V	109332,25	V	962,49
13-05-26	V	986,89	V	110710,39	V	958,88
14-05-26	V	990,71	V	112627,83	V	956,31
15-05-26	V	991,58	V	113382,27	V	952,27
16-05-26	V	992,13	V	111356,24	V	950,55
17-05-26	V	1000,82	V	111274,01	V	950,26
18-05-26	V	1000,20	V	109255,51	V	953,09
19-05-26	V	1002,18	V	112184,67	V	946,87
20-05-26	V	1009,26	V	115105,92	V	939,09
21-05-26	V	1009,52	V	112094,98	V	941,67
22-05-26	V	1011,97	V	111160,40	V	945,45
23-05-26	V	1014,14	V	117118,05	V	943,76
24-05-26	V	1010,09	V	115558,29	V	932,93
25-05-26	V	1010,42	V	112903,50	V	937,71
26-05-26	V	1004,01	V	115893,57	V	935,09
27-05-26	V	998,30	V	110516,24	V	932,10
28-05-26	V	1001,73	V	110908,23	V	950,37
29-05-26	V	1004,36	V	108443,53	V	968,96
30-05-26	V	999,56	V	107942,24	V	951,65
31-05-26	V	997,57	V	103752,12	V	973,53
MAV		1001,48		110512,66		965,47

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value