

Mėnesinė ataskaita



Plant: Kauno kogeneraci

Report time: birž.- 2026

Date of creation: 03-06-2026 05:01

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	5.00	DLV:	6.00	DLV:	30,00	DLV:	1,00	DLV:	50,00	DLV:	10,00
01-06-26	V	0,00	V	0,72	V	1,54	V	0,17	V	8,23	V	0,20
02-06-26	V	0,10	V	0,76	V	1,58	V	0,18	V	10,00	V	0,30
MAV		0,05		0,74		1,56		0,18		9,12		0,25

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneraci

Report time: birž. - 2026

Date of creation: 03-06-2026 05:01

Date	NOx		NH ₃		Hg		O ₂		H ₂ O		Kamino T	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C
	DLV:	150.00	DLV:	10.00	DLV:	0.02						
01-06-26	V	83,17	V	0,89	V	0,0005	V	8,58	V	15,26	V	52,51
02-06-26	V	104,77	V	0,94	V	0,0005	V	9,36	V	13,81	V	49,95
MAV		93,97		0,92		0,0005		8,97		14,53		51,23

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant:

Report time: birž.- 2026

Date of creation: 03-06-2026 05:01

Date	Slėgis		Srautas		Degimo T	
	Unit:	hPa	Unit:	Nm ³ /h	Unit:	°C
			DLV:	240000,00	DLV:	850,00
01-06-26	V	1001,60	V	106541,61	V	973,09
02-06-26	V	1002,00	V	114349,05	V	952,11
MAV		1001,80		110445,33		962,60

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value