

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2020

Date of creation: 01/04/2020 04:11

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
02/03/20	V	0.01	V	0.00	V	1.44	V	0.00	V	0.78	V	0.17
03/03/20	V	0.06	V	0.00	V	0.40	V	0.00	V	11.11	V	0.22
04/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/03/20	V	0.18	V	0.00	V	1.53	V	0.00	V	15.22	V	0.12
06/03/20	V	0.19	V	0.00	V	1.91	V	0.00	V	31.57	V	0.46
07/03/20	V	0.09	V	0.00	V	5.05	V	0.00	V	35.14	V	0.77
08/03/20	V	0.17	V	0.00	V	0.97	V	0.00	V	13.70	V	0.12
09/03/20	V	0.09	V	0.00	V	37.38	V	0.00	V	13.60	V	0.06
10/03/20	V	0.14	V	0.00	V	87.09	V	0.00	V	8.72	V	0.02
11/03/20	V	0.08	V	0.00	V	47.29	V	0.00	V	10.26	V	0.26
12/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
13/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
14/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
15/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
16/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
17/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
18/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
19/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
23/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
24/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
25/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
26/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
31/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		0.12		0.00		25.56		0.00		17.43		0.27

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2020

Date of creation: 01/04/2020 04:11

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
02/03/20	V	117.07	V	10.72	V	18.42	V	57.14	V	987.72	V	144052.25
03/03/20	V	95.40	V	13.74	V	15.15	V	51.53	V	988.93	V	157778.10
04/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/03/20	V	97.45	V	9.38	V	18.11	V	57.44	V	994.30	M	0.00
06/03/20	V	129.19	V	8.99	V	16.04	V	53.56	V	994.01	M	102601.66
07/03/20	V	126.69	V	8.24	V	14.24	V	50.85	V	994.52	V	101606.42
08/03/20	V	111.97	V	8.33	V	14.39	V	51.23	V	1002.43	V	102091.35
09/03/20	V	130.98	V	9.82	V	12.96	V	48.58	V	1002.93	V	112995.38
10/03/20	V	148.31	V	10.42	V	11.76	V	46.30	V	997.00	V	119039.30
11/03/20	V	127.60	V	11.30	V	10.71	V	43.67	V	984.98	V	124059.82
12/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
13/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
14/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
15/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
16/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
17/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
18/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
19/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
23/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
24/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
25/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
26/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
31/03/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		125.94		9.68		14.00		50.13		995.48		114783.79

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2020

Date of creation: 01/04/2020 04:11

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/03/20	N	0.00				
02/03/20	V	909.35				
03/03/20	V	849.10				
04/03/20	N	0.00				
05/03/20	V	874.89				
06/03/20	V	874.26				
07/03/20	V	875.18				
08/03/20	V	885.54				
09/03/20	V	895.04				
10/03/20	V	902.38				
11/03/20	V	909.58				
12/03/20	N	0.00				
13/03/20	N	0.00				
14/03/20	N	0.00				
15/03/20	N	0.00				
16/03/20	N	0.00				
17/03/20	N	0.00				
18/03/20	N	0.00				
19/03/20	N	0.00				
20/03/20	N	0.00				
21/03/20	N	0.00				
22/03/20	N	0.00				
23/03/20	N	0.00				
24/03/20	N	0.00				
25/03/20	N	0.00				
26/03/20	N	0.00				
27/03/20	N	0.00				
28/03/20	N	0.00				
29/03/20	N	0.00				
30/03/20	N	0.00				
31/03/20	N	0.00				
MAV		888.84				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value