

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2020

Date of creation: 01/06/2020 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
02/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
03/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/05/20	V	0.23	V	0.00	V	1.94	V	0.00	V	9.81	V	0.18
09/05/20	V	0.22	V	0.00	V	0.71	V	0.00	V	7.50	V	0.11
10/05/20	V	0.21	V	0.00	V	0.77	V	0.00	V	0.01	V	0.07
11/05/20	V	0.19	V	0.00	V	0.68	V	0.00	V	0.24	V	0.12
12/05/20	V	0.08	V	0.00	V	0.50	V	0.00	V	12.10	V	0.19
13/05/20	V	0.10	V	0.00	V	1.09	V	0.00	V	0.54	V	0.15
14/05/20	V	0.12	V	0.00	V	0.74	V	0.00	V	12.29	V	0.39
15/05/20	V	0.19	V	0.00	V	0.86	V	0.00	V	15.76	V	0.30
16/05/20	V	0.18	V	0.00	V	4.27	V	0.00	V	5.87	V	0.11
17/05/20	V	0.13	V	0.00	V	7.56	V	0.00	V	3.71	V	0.06
18/05/20	V	0.19	V	0.00	V	11.67	V	0.00	V	16.40	V	0.16
19/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/05/20	V	0.14	V	0.00	V	0.57	V	0.00	V	6.55	V	0.04
23/05/20	V	0.13	V	0.00	V	0.88	V	0.00	V	1.11	V	0.08
24/05/20	V	0.13	V	0.00	V	0.85	V	0.00	V	0.05	V	0.01
25/05/20	V	0.06	V	0.00	V	0.85	V	0.00	V	19.04	V	0.53
26/05/20	V	0.14	V	0.00	V	0.91	V	0.00	V	1.91	V	0.06
27/05/20	V	0.18	V	0.00	V	0.96	V	0.00	V	1.69	V	0.06
28/05/20	V	0.10	V	0.00	V	1.09	V	0.00	V	3.19	V	0.06
29/05/20	V	0.19	V	0.00	V	1.45	V	0.00	V	0.08	V	0.03
30/05/20	V	0.11	V	0.00	V	0.85	V	0.00	V	3.78	V	0.04
31/05/20	V	0.04	V	0.00	V	0.85	V	0.00	V	6.88	V	0.12
MAV		0.14		0.00		1.83		0.00		5.89		0.14

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2020

Date of creation: 01/06/2020 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
	DLV:	200.00										
01/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
02/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
03/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/05/20	V	100.47	V	9.84	V	12.34	V	47.67	V	1002.14	V	92432.74
09/05/20	V	63.67	V	9.41	V	14.32	V	51.08	V	1000.57	V	91920.25
10/05/20	V	161.73	V	9.59	V	13.88	V	50.31	V	998.87	V	97317.93
11/05/20	V	95.18	V	8.80	V	14.17	V	50.40	V	988.39	V	98297.53
12/05/20	V	90.79	V	8.09	V	13.70	V	50.30	V	993.80	V	105013.12
13/05/20	V	97.06	V	9.11	V	13.23	V	49.49	V	998.72	V	109459.91
14/05/20	V	83.87	V	7.68	V	13.25	V	49.64	V	1001.40	V	110742.06
15/05/20	V	83.64	V	7.84	V	13.48	V	50.03	V	1001.74	V	110165.35
16/05/20	V	99.53	V	7.08	V	13.61	V	50.12	V	1000.64	V	109588.32
17/05/20	V	117.05	V	6.94	V	13.67	V	50.08	V	1000.61	V	108766.62
18/05/20	V	100.90	V	8.66	V	13.60	V	49.80	V	999.94	V	113812.66
19/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/05/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/05/20	V	74.29	V	10.00	V	11.05	V	45.22	V	1009.28	V	98788.62
23/05/20	V	81.23	V	9.58	V	11.41	V	46.23	V	1009.23	V	98882.83
24/05/20	V	80.41	V	9.04	V	11.94	V	46.52	V	1005.04	V	97721.33
25/05/20	V	132.87	V	9.20	V	11.91	V	46.60	V	1009.47	V	96717.00
26/05/20	V	144.32	V	8.58	V	11.83	V	46.62	V	1016.33	V	99054.54
27/05/20	V	113.83	V	8.39	V	11.59	V	46.41	V	1014.88	V	97773.19
28/05/20	V	133.69	V	8.15	V	12.00	V	46.86	V	1011.48	V	106034.94
29/05/20	V	139.65	V	8.32	V	11.66	V	46.39	V	1009.85	V	113125.64
30/05/20	V	116.56	V	7.78	V	12.92	V	48.76	V	1004.06	V	111535.06
31/05/20	V	121.27	V	8.17	V	15.23	V	53.03	V	1003.48	V	113286.70
MAV		107.64		8.50		12.97		48.78		1003.67		104178.10

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: May/ 2020

Date of creation: 01/06/2020 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/05/20	N	0.00				
02/05/20	N	0.00				
03/05/20	N	0.00				
04/05/20	N	0.00				
05/05/20	N	0.00				
06/05/20	N	0.00				
07/05/20	N	0.00				
08/05/20	V	918.57				
09/05/20	V	945.87				
10/05/20	V	964.89				
11/05/20	V	979.12				
12/05/20	V	1001.54				
13/05/20	V	1005.60				
14/05/20	V	1019.21				
15/05/20	V	1017.42				
16/05/20	V	1038.23				
17/05/20	V	1040.18				
18/05/20	V	1023.88				
19/05/20	N	0.00				
20/05/20	N	0.00				
21/05/20	N	0.00				
22/05/20	V	930.04				
23/05/20	V	955.40				
24/05/20	V	980.40				
25/05/20	V	964.41				
26/05/20	V	972.15				
27/05/20	V	964.95				
28/05/20	V	967.04				
29/05/20	V	973.23				
30/05/20	V	979.38				
31/05/20	V	979.28				
MAV		984.85				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value