

Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2020

Date of creation: 01/09/2020 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/08/20	V	0.09	V	0.00	V	0.64	V	0.00	V	14.08	V	0.57
02/08/20	V	0.04	V	0.00	V	0.70	V	0.00	V	6.12	V	0.15
03/08/20	V	0.11	V	0.00	V	0.60	V	0.00	V	9.02	V	0.15
04/08/20	V	0.04	V	0.00	V	0.63	V	0.00	V	7.65	V	0.22
05/08/20	V	0.06	V	0.00	V	0.65	V	0.00	V	0.90	V	0.21
06/08/20	V	0.03	V	0.03	V	0.68	V	0.00	V	1.92	V	0.10
07/08/20	V	0.05	V	0.00	V	0.93	V	0.00	V	0.77	V	0.11
08/08/20	V	0.04	V	0.00	V	0.62	V	0.00	V	1.05	V	0.06
09/08/20	V	0.01	V	0.00	V	0.77	V	0.00	V	0.55	V	0.28
10/08/20	V	0.04	V	0.00	V	0.63	V	0.00	V	1.68	V	0.32
11/08/20	V	0.01	V	0.01	V	0.85	V	0.00	V	0.50	V	0.41
12/08/20	V	0.01	V	0.00	V	0.72	V	0.00	V	0.63	V	0.15
13/08/20	V	0.02	V	0.02	V	0.68	V	0.00	V	1.67	V	0.11
14/08/20	V	0.02	V	0.03	V	0.58	V	0.00	V	3.78	V	0.05
15/08/20	V	0.05	V	0.00	V	0.62	V	0.00	V	0.64	V	0.13
16/08/20	V	0.09	V	0.00	V	0.63	V	0.00	V	0.27	V	0.04
17/08/20	V	0.08	V	0.00	V	0.58	V	0.00	V	0.69	V	0.09
18/08/20	V	0.00	V	0.00	V	0.61	V	0.00	V	0.45	V	0.24
19/08/20	V	0.01	V	0.00	V	0.62	V	0.00	V	0.76	V	0.13
20/08/20	V	0.00	V	0.02	V	0.68	V	0.00	V	0.90	V	0.17
21/08/20	V	0.03	V	0.01	V	0.61	V	0.00	V	0.46	V	0.10
22/08/20	V	0.00	V	0.00	V	0.59	V	0.00	V	0.34	V	0.01
23/08/20	V	0.00	V	0.01	V	0.60	V	0.00	V	1.19	V	0.02
24/08/20	V	0.00	V	0.01	V	0.62	V	0.00	V	0.67	V	0.25
25/08/20	V	0.00	V	0.01	V	0.61	V	0.00	V	5.72	V	0.59
26/08/20	V	0.00	V	0.01	V	0.58	V	0.00	V	0.45	V	0.32
27/08/20	V	0.00	V	0.01	V	0.57	V	0.00	V	0.49	V	0.24
28/08/20	V	0.01	V	0.00	V	0.61	V	0.00	V	1.15	V	0.31
29/08/20	V	0.01	V	0.00	V	0.56	V	0.00	V	9.86	V	0.43
30/08/20	V	0.00	V	0.00	V	0.55	V	0.00	V	0.14	V	0.72
31/08/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		0.03		0.01		0.64		0.00		2.52		0.22

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2020

Date of creation: 01/09/2020 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/08/20	V	66.23	V	7.28	V	22.47	V	62.30	V	1001.80	V	104861.43
02/08/20	V	68.39	V	7.33	V	21.98	V	62.09	V	1001.87	V	104779.59
03/08/20	V	66.89	V	7.53	V	22.09	V	61.90	V	998.46	V	105373.00
04/08/20	V	83.46	V	8.03	V	22.08	V	61.47	V	997.00	V	107124.96
05/08/20	V	111.59	V	8.81	V	20.88	V	60.74	V	1005.73	V	115027.27
06/08/20	V	129.46	V	8.97	V	19.85	V	60.24	V	1013.80	V	124110.71
07/08/20	V	147.02	V	8.77	V	20.26	V	60.53	V	1015.44	V	124444.88
08/08/20	V	109.35	V	8.32	V	21.73	V	61.72	V	1012.00	V	112060.06
09/08/20	V	123.11	V	8.35	V	22.04	V	61.81	V	1008.09	V	110772.32
10/08/20	V	103.03	V	8.51	V	21.73	V	61.42	V	1006.91	V	113431.31
11/08/20	V	98.80	V	8.68	V	20.28	V	60.62	V	1008.92	V	116649.03
12/08/20	V	99.39	V	8.61	V	19.81	V	60.36	V	1010.45	V	120251.82
13/08/20	V	89.78	V	8.64	V	19.54	V	59.84	V	1007.55	V	121200.07
14/08/20	V	91.82	V	8.81	V	19.61	V	59.74	V	1005.56	V	118851.75
15/08/20	V	106.61	V	8.80	V	19.99	V	59.97	V	1005.08	V	113988.33
16/08/20	V	115.65	V	8.39	V	20.71	V	60.62	V	1004.67	V	114081.22
17/08/20	V	148.95	V	8.26	V	16.69	V	56.26	V	1002.81	V	124368.98
18/08/20	V	146.81	V	8.28	V	16.86	V	56.49	V	998.71	V	124454.98
19/08/20	V	155.20	V	8.27	V	16.88	V	55.88	V	995.77	V	122397.20
20/08/20	V	138.17	V	8.15	V	18.48	V	57.69	V	999.55	V	121174.68
21/08/20	V	145.23	V	7.99	V	19.02	V	58.50	V	1004.04	V	123174.99
22/08/20	V	149.35	V	7.86	V	17.98	V	57.27	V	1003.17	V	120766.49
23/08/20	V	140.15	V	7.74	V	18.59	V	57.70	V	999.35	V	118541.86
24/08/20	V	114.44	V	7.82	V	19.34	V	58.79	V	999.33	V	119458.37
25/08/20	V	100.04	V	7.83	V	18.18	V	57.53	V	998.10	V	117951.31
26/08/20	V	142.80	V	7.91	V	18.26	V	57.50	V	994.43	V	121790.09
27/08/20	V	136.93	V	8.05	V	16.69	V	55.59	V	989.88	V	119110.48
28/08/20	V	109.70	V	7.83	V	15.72	V	55.24	V	997.07	V	119729.14
29/08/20	V	96.40	V	7.84	V	17.21	V	56.65	V	996.57	V	120199.89
30/08/20	V	144.73	V	8.50	V	18.53	V	57.83	V	998.19	V	115966.42
31/08/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		115.51		8.20		19.46		59.16		1002.70		117193.04

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Aug/ 2020

Date of creation: 01/09/2020 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/08/20	V	932.58				
02/08/20	V	945.48				
03/08/20	V	933.58				
04/08/20	V	924.60				
05/08/20	V	914.38				
06/08/20	V	904.37				
07/08/20	V	898.48				
08/08/20	V	920.79				
09/08/20	V	944.74				
10/08/20	V	950.96				
11/08/20	V	951.11				
12/08/20	V	932.17				
13/08/20	V	923.81				
14/08/20	V	935.31				
15/08/20	V	960.04				
16/08/20	V	975.86				
17/08/20	V	966.31				
18/08/20	V	964.44				
19/08/20	V	969.10				
20/08/20	V	974.42				
21/08/20	V	985.33				
22/08/20	V	991.58				
23/08/20	V	995.00				
24/08/20	V	978.00				
25/08/20	V	970.40				
26/08/20	V	957.56				
27/08/20	V	965.65				
28/08/20	V	982.41				
29/08/20	V	947.82				
30/08/20	V	885.17				
31/08/20	N	0.00				
MAV		950.37				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value