

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Oct/ 2020

Date of creation: 01/11/2020 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/10/20	M	0.00	V	0.00	V	0.55	V	0.00	V	0.09	V	0.35
02/10/20	M	0.00	V	0.00	V	0.56	V	0.00	V	0.19	V	0.40
03/10/20	V	0.00	V	0.00	V	0.51	V	0.00	V	0.21	V	0.37
04/10/20	V	0.00	V	0.00	V	0.55	V	0.01	V	0.44	V	0.27
05/10/20	V	0.01	V	0.00	V	0.58	V	0.00	V	0.25	V	0.33
06/10/20	V	0.01	V	0.00	V	0.60	V	0.01	V	0.58	V	0.34
07/10/20	V	0.00	V	0.00	V	0.64	V	0.01	V	0.19	V	0.23
08/10/20	V	0.00	V	0.00	V	0.64	V	0.01	V	0.02	V	0.29
09/10/20	V	0.01	V	0.00	V	0.55	V	0.00	V	1.22	V	0.30
10/10/20	V	0.01	V	0.00	V	0.50	V	0.00	V	0.00	V	0.32
11/10/20	V	0.26	V	0.00	V	0.49	V	0.00	V	0.00	V	0.29
12/10/20	V	0.00	V	0.00	V	0.52	V	0.02	V	0.76	V	0.29
13/10/20	V	0.01	V	0.01	V	0.56	V	0.00	V	1.11	V	0.31
14/10/20	V	0.00	V	0.00	V	0.53	V	0.00	V	0.90	V	0.34
15/10/20	V	0.00	V	0.00	V	0.47	V	0.00	V	0.42	V	0.31
16/10/20	V	0.00	V	0.06	V	0.56	V	0.02	V	1.62	V	0.29
17/10/20	V	0.00	V	0.10	V	0.65	V	0.00	V	0.68	V	0.29
18/10/20	V	0.00	V	0.05	V	0.86	V	0.01	V	0.44	V	0.36
19/10/20	V	0.00	V	0.05	V	0.49	V	0.00	V	1.21	V	0.31
20/10/20	V	0.00	V	0.08	V	0.46	V	0.04	V	1.39	V	0.32
21/10/20	V	0.00	V	0.01	V	0.45	V	0.03	V	0.67	V	0.25
22/10/20	V	0.00	V	0.00	V	0.47	V	0.01	V	1.88	V	0.30
23/10/20	V	0.01	V	0.00	V	0.56	V	0.03	V	1.86	V	0.29
24/10/20	V	0.00	V	0.00	V	0.51	V	0.03	V	5.47	V	0.34
25/10/20	V	0.00	V	0.00	V	0.59	V	0.05	V	0.25	V	0.30
26/10/20	V	0.00	V	0.01	V	0.66	V	0.01	V	1.31	V	0.24
27/10/20	V	0.00	V	0.00	V	0.50	V	0.03	V	1.07	V	0.34
28/10/20	V	0.01	V	0.00	V	0.53	V	0.03	V	0.21	V	0.24
29/10/20	V	0.00	V	0.00	V	0.51	V	0.05	V	0.07	V	0.23
30/10/20	V	0.00	V	0.00	V	0.48	V	0.03	V	1.39	V	0.23
31/10/20	V	0.00	V	0.00	V	0.48	V	0.02	V	1.68	V	0.34
MAV		0.01		0.01		0.55		0.02		0.86		0.30

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Oct/ 2020

Date of creation: 01/11/2020 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/10/20	V	110.34	V	9.11	V	15.45	V	57.04	V	999.26	V	142614.94
02/10/20	V	114.99	V	9.59	V	11.40	V	51.88	V	1001.43	V	154799.25
03/10/20	V	100.45	V	9.18	V	12.43	V	53.14	V	1001.07	V	155630.97
04/10/20	V	81.30	V	8.93	V	12.37	V	52.69	V	995.44	V	155635.60
05/10/20	V	84.74	V	9.05	V	12.41	V	52.79	V	1000.51	V	160829.54
06/10/20	V	84.77	V	8.96	V	11.91	V	52.43	V	996.43	V	160122.37
07/10/20	V	84.04	V	8.60	V	12.33	V	52.99	V	998.21	V	154524.20
08/10/20	V	84.54	V	9.21	V	9.26	V	48.08	V	1004.61	V	163258.17
09/10/20	V	88.34	V	9.05	V	5.73	V	41.75	V	1004.61	V	156116.06
10/10/20	V	94.48	V	8.23	V	6.32	V	43.42	V	1005.94	V	150174.57
11/10/20	V	78.44	V	8.93	V	6.76	V	44.05	V	1004.22	V	159216.87
12/10/20	V	90.47	V	8.95	V	6.36	V	43.62	V	1004.20	V	162020.38
13/10/20	V	95.14	V	8.86	V	5.74	V	42.29	V	1001.72	V	163252.15
14/10/20	V	92.99	V	9.06	V	5.55	V	41.32	V	995.97	V	155815.52
15/10/20	V	89.11	V	8.58	V	5.16	V	40.67	V	997.24	V	154535.32
16/10/20	V	95.60	V	8.91	V	2.75	V	33.78	V	1005.47	V	157072.76
17/10/20	V	89.78	V	8.66	V	2.17	V	31.80	V	1005.08	V	160350.82
18/10/20	V	96.44	V	8.68	V	2.24	V	31.89	V	994.57	V	158726.78
19/10/20	V	92.98	V	8.73	V	2.19	V	31.96	V	1001.56	V	159903.81
20/10/20	V	97.37	V	8.72	V	2.19	V	32.13	V	1008.99	V	163281.57
21/10/20	V	94.27	V	9.01	V	2.82	V	33.53	V	1001.59	V	166070.73
22/10/20	V	100.65	V	9.44	V	3.62	V	35.82	V	996.98	V	171898.64
23/10/20	V	97.91	V	9.45	V	3.87	V	36.43	V	997.98	V	171814.94
24/10/20	V	97.54	V	8.97	V	3.17	V	34.68	V	997.99	V	160791.80
25/10/20	V	94.41	V	9.17	V	3.36	V	35.21	V	1002.62	V	168489.15
26/10/20	V	91.67	V	8.92	V	5.54	V	39.71	V	1000.33	V	166075.19
27/10/20	V	98.06	V	9.43	V	4.87	V	39.32	V	999.15	V	171222.66
28/10/20	V	95.65	V	9.40	V	4.13	V	37.82	V	1002.11	V	167043.24
29/10/20	V	90.64	V	8.92	V	3.84	V	36.85	V	999.87	V	157562.57
30/10/20	V	84.96	V	8.59	V	3.39	V	35.99	V	1001.19	V	148472.54
31/10/20	V	76.67	V	8.90	V	3.44	V	36.30	V	1009.55	V	151718.48
MAV		92.47		8.97		6.32		41.51		1001.32		159500.10

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant:

Report time: Oct/ 2020

Date of creation: 01/11/2020 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/10/20	V	961.92				
02/10/20	V	960.73				
03/10/20	V	969.05				
04/10/20	V	968.01				
05/10/20	V	982.00				
06/10/20	V	1022.40				
07/10/20	V	1031.17				
08/10/20	V	1022.48				
09/10/20	V	1014.62				
10/10/20	V	1036.63				
11/10/20	V	1022.29				
12/10/20	V	1015.44				
13/10/20	V	1001.59				
14/10/20	V	973.58				
15/10/20	V	1007.01				
16/10/20	V	976.02				
17/10/20	V	987.44				
18/10/20	V	1004.83				
19/10/20	V	977.93				
20/10/20	V	971.79				
21/10/20	V	967.83				
22/10/20	V	955.25				
23/10/20	V	950.31				
24/10/20	V	972.83				
25/10/20	V	993.37				
26/10/20	V	1002.02				
27/10/20	V	990.37				
28/10/20	V	970.05				
29/10/20	V	985.88				
30/10/20	V	970.95				
31/10/20	V	966.40				
MAV		988.64				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value