

# Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Nov/ 2020

Date of creation: 01/12/2020 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/11/20	V	0.03	V	0.00	V	0.54	V	0.02	V	1.43	V	0.34
02/11/20	V	0.02	V	0.01	V	0.60	V	0.00	V	2.43	V	0.31
03/11/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/11/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/11/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/11/20	V	0.03	V	0.00	V	0.63	V	0.00	V	21.72	V	0.23
07/11/20	V	0.09	V	0.00	V	0.57	V	0.01	V	32.11	V	0.30
08/11/20	V	0.04	V	0.00	V	0.59	V	0.01	V	0.00	V	0.33
09/11/20	V	0.03	V	0.01	V	0.54	V	0.00	V	0.68	V	0.30
10/11/20	V	0.14	V	0.01	V	0.49	V	0.01	V	0.50	V	0.31
11/11/20	V	0.02	V	0.01	V	0.50	V	0.03	V	0.11	V	0.29
12/11/20	V	0.01	V	0.00	V	0.50	V	0.04	V	0.01	V	0.27
13/11/20	V	0.01	V	0.00	V	0.47	V	0.03	V	0.32	V	0.23
14/11/20	V	0.09	V	0.03	V	0.49	V	0.02	V	0.00	V	0.21
15/11/20	V	0.04	V	0.01	V	0.49	V	0.01	V	0.02	V	0.23
16/11/20	V	0.02	V	0.00	V	0.46	V	0.00	V	0.03	V	0.25
17/11/20	V	0.16	V	0.00	V	0.48	V	0.01	V	0.31	V	0.26
18/11/20	V	0.03	V	0.00	V	0.45	V	0.00	V	0.02	V	0.26
19/11/20	V	0.06	V	0.00	V	0.47	V	0.01	V	0.07	V	0.27
20/11/20	V	0.19	V	0.01	V	0.48	V	0.01	V	0.02	V	0.22
21/11/20	V	0.00	V	0.00	V	0.43	V	0.02	V	0.13	V	0.30
22/11/20	V	0.26	V	0.01	V	0.40	V	0.01	V	0.07	V	0.28
23/11/20	V	0.13	V	0.02	V	0.43	V	0.00	V	0.03	V	0.20
24/11/20	V	0.01	V	0.07	V	0.41	V	0.02	V	0.09	V	0.20
25/11/20	V	0.00	V	0.00	V	0.36	V	0.02	V	0.69	V	0.19
26/11/20	V	0.00	V	0.05	V	0.41	V	0.08	V	1.63	V	0.51
27/11/20	V	0.10	V	0.00	V	0.46	V	0.04	V	0.35	V	0.31
28/11/20	V	0.00	V	0.04	V	0.41	V	0.08	V	1.73	V	0.57
29/11/20	V	0.00	V	0.00	V	0.44	V	0.08	V	0.31	V	0.55
30/11/20	V	0.00	V	0.01	V	0.40	V	0.05	V	0.26	V	0.47
MAV		0.06		0.01		0.47		0.02		1.81		0.31

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

# Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Nov/ 2020

Date of creation: 01/12/2020 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
	DLV:	200.00										
01/11/20	V	55.91	V	9.85	V	10.73	V	51.43	V	1008.80	V	119130.97
02/11/20	V	56.65	V	10.16	V	10.76	V	51.96	V	1002.58	V	118721.16
03/11/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/11/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/11/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/11/20	V	41.27	V	10.63	V	15.04	V	57.24	V	1012.81	V	120461.04
07/11/20	V	46.64	V	9.49	V	16.36	V	58.76	V	1013.65	V	114790.14
08/11/20	V	57.32	V	9.79	V	16.18	V	58.58	V	1010.89	V	119709.86
09/11/20	V	76.32	V	9.33	V	11.90	V	53.26	V	1017.81	V	141150.77
10/11/20	V	83.46	V	9.26	V	10.55	V	51.80	V	1020.75	V	146462.91
11/11/20	V	79.22	V	8.57	V	12.15	V	54.22	V	1019.77	V	143450.61
12/11/20	V	88.98	V	8.91	V	10.80	V	52.26	V	1015.35	V	148337.92
13/11/20	V	87.87	V	8.61	V	9.53	V	49.98	V	1011.78	V	151755.43
14/11/20	V	102.15	V	8.79	V	7.41	V	45.89	V	1008.61	V	151229.00
15/11/20	V	92.79	V	8.62	V	11.39	V	52.50	V	1008.32	V	152324.68
16/11/20	V	69.79	V	9.01	V	10.89	V	51.99	V	1006.53	V	154627.85
17/11/20	V	71.46	V	8.71	V	13.70	V	55.86	V	1009.44	V	153248.97
18/11/20	V	69.07	V	8.87	V	13.76	V	55.73	V	1009.96	V	153666.61
19/11/20	V	70.36	V	8.93	V	13.71	V	55.60	V	999.24	V	154054.78
20/11/20	V	97.06	V	8.95	V	5.94	V	40.55	V	1005.26	V	157627.85
21/11/20	V	82.57	V	8.72	V	2.28	V	33.22	V	1014.60	V	149032.68
22/11/20	V	85.16	V	8.47	V	2.56	V	33.48	V	1001.01	V	148919.36
23/11/20	V	84.42	V	8.53	V	2.71	V	33.75	V	999.88	V	149682.76
24/11/20	V	86.12	V	8.61	V	3.78	V	37.45	V	1004.81	V	152573.28
25/11/20	V	82.60	V	8.86	V	7.50	V	45.08	V	1006.10	V	153314.16
26/11/20	V	83.91	V	8.76	V	3.95	V	36.80	V	1003.96	V	155508.63
27/11/20	V	89.69	V	9.07	V	6.89	V	43.31	V	1000.08	V	158610.72
28/11/20	V	97.10	V	9.43	V	3.91	V	38.01	V	1006.91	V	165918.97
29/11/20	V	105.12	V	9.51	V	5.93	V	40.91	V	1009.21	V	163208.66
30/11/20	V	103.26	V	9.29	V	3.65	V	37.19	V	1008.19	V	160739.84
MAV		80.89		9.04		8.83		46.94		1008.68		147666.57

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Nov/ 2020

Date of creation: 01/12/2020 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/11/20	V	949.26				
02/11/20	V	957.95				
03/11/20	N	0.00				
04/11/20	N	0.00				
05/11/20	N	0.00				
06/11/20	V	931.81				
07/11/20	V	937.31				
08/11/20	V	951.97				
09/11/20	V	958.84				
10/11/20	V	939.63				
11/11/20	V	971.97				
12/11/20	V	992.83				
13/11/20	V	1000.43				
14/11/20	V	1005.29				
15/11/20	V	1017.24				
16/11/20	V	1013.86				
17/11/20	V	1014.05				
18/11/20	V	1013.20				
19/11/20	V	1020.23				
20/11/20	V	1028.02				
21/11/20	V	1029.56				
22/11/20	V	1028.57				
23/11/20	V	1026.06				
24/11/20	V	1017.05				
25/11/20	V	999.87				
26/11/20	V	997.61				
27/11/20	V	996.07				
28/11/20	V	995.92				
29/11/20	V	995.23				
30/11/20	V	1016.18				
MAV		995.03				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value