

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2020

Date of creation: 01/01/2021 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/12/20	V	0.00	V	0.00	V	0.38	V	0.05	V	0.18	V	0.60
02/12/20	V	0.12	V	0.00	V	0.37	V	0.02	V	2.74	V	0.40
03/12/20	V	0.01	V	0.01	V	0.35	V	0.02	V	1.99	V	0.39
04/12/20	V	0.00	V	0.04	V	0.32	V	0.04	V	1.15	V	0.43
05/12/20	V	0.00	V	0.00	V	0.35	V	0.00	V	4.09	V	0.80
06/12/20	V	0.00	V	0.01	V	0.35	V	0.00	V	1.54	V	0.26
07/12/20	V	0.00	V	0.01	V	0.37	V	0.04	V	1.61	V	0.32
08/12/20	V	0.00	V	0.01	V	0.34	V	0.01	V	0.39	V	0.37
09/12/20	V	0.00	V	0.00	V	0.35	V	0.01	V	1.22	V	0.38
10/12/20	V	0.02	V	0.01	V	0.38	V	0.01	V	2.83	V	0.40
11/12/20	V	0.07	V	0.00	V	0.39	V	0.01	V	1.80	V	0.44
12/12/20	V	0.00	V	0.00	V	0.37	V	0.00	V	1.47	V	0.47
13/12/20	V	0.16	V	0.01	V	0.40	V	0.00	V	3.70	V	0.41
14/12/20	V	0.01	V	0.00	V	0.44	V	0.00	V	3.65	V	0.58
15/12/20	V	0.00	V	0.02	V	0.35	V	0.00	V	2.76	V	0.49
16/12/20	V	0.00	V	0.08	V	0.31	V	0.00	V	2.51	V	0.42
17/12/20	V	0.01	V	0.00	V	0.47	V	0.00	V	0.64	V	0.33
18/12/20	V	0.25	V	0.00	V	0.51	V	0.00	V	0.21	V	0.31
19/12/20	V	0.10	V	0.01	V	0.47	V	0.00	V	0.45	V	0.35
20/12/20	V	0.00	V	0.00	V	0.42	V	0.00	V	0.50	V	0.34
21/12/20	V	0.00	V	0.05	V	0.41	V	0.02	V	0.14	V	0.49
22/12/20	V	0.00	V	0.01	V	0.41	V	0.01	V	0.40	V	0.47
23/12/20	V	0.26	V	0.00	V	0.44	V	0.02	V	0.36	V	0.23
24/12/20	V	0.05	V	0.00	V	0.46	V	0.00	V	0.30	V	0.29
25/12/20	V	0.02	V	0.05	V	0.47	V	0.00	V	3.03	V	0.32
26/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
31/12/20	V	0.08	V	0.05	V	0.52	V	0.00	V	1.99	V	0.35
MAV		0.05		0.01		0.40		0.01		1.56		0.41

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2020

Date of creation: 01/01/2021 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/12/20	V	99.61	V	8.93	V	3.01	V	35.73	V	1013.18	V	159833.83
02/12/20	V	94.80	V	8.95	V	3.05	V	36.20	V	1016.44	V	161625.32
03/12/20	V	125.15	V	9.06	V	3.31	V	36.72	V	1007.46	V	162156.27
04/12/20	V	106.42	V	8.56	V	2.92	V	35.27	V	1000.95	V	152728.33
05/12/20	V	88.11	V	8.67	V	3.68	V	36.95	V	1004.31	V	150613.60
06/12/20	V	80.14	V	8.43	V	2.87	V	35.15	V	1009.93	V	151296.17
07/12/20	V	83.97	V	8.26	V	2.54	V	34.80	V	1009.88	V	147158.76
08/12/20	V	84.09	V	8.88	V	2.47	V	34.42	V	1010.63	V	153457.67
09/12/20	V	84.61	V	9.05	V	2.77	V	35.38	V	1011.77	V	157074.79
10/12/20	V	89.99	V	9.32	V	2.92	V	35.38	V	1006.60	V	161439.44
11/12/20	V	83.18	V	9.59	V	2.62	V	33.95	V	1001.76	V	165117.36
12/12/20	V	81.87	V	8.98	V	2.44	V	33.36	V	1001.11	V	160214.22
13/12/20	V	82.36	V	8.89	V	2.60	V	34.19	V	1003.79	V	159788.58
14/12/20	V	82.09	V	9.17	V	2.77	V	34.76	V	1006.50	V	163154.51
15/12/20	V	82.04	V	9.68	V	2.61	V	34.19	V	1008.82	V	165967.80
16/12/20	V	84.12	V	9.52	V	2.82	V	34.82	V	1006.35	V	160958.88
17/12/20	V	78.55	V	10.35	V	4.82	V	40.20	V	1013.41	V	168890.97
18/12/20	V	72.70	V	10.05	V	5.96	V	43.44	V	1010.54	V	170653.15
19/12/20	V	81.87	V	9.82	V	4.83	V	40.46	V	1013.25	V	171145.04
20/12/20	V	82.19	V	9.67	V	3.47	V	37.33	V	1015.12	V	167610.13
21/12/20	V	79.60	V	9.93	V	4.88	V	41.35	V	1014.05	V	171612.13
22/12/20	V	77.87	V	10.05	V	5.88	V	43.41	V	1004.96	V	174323.54
23/12/20	V	67.45	V	10.08	V	5.43	V	41.57	V	997.73	V	172967.17
24/12/20	V	79.74	V	9.97	V	3.83	V	37.00	V	991.06	V	169138.30
25/12/20	V	43.89	V	10.74	V	3.09	V	35.00	V	989.10	V	148173.24
26/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/12/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
31/12/20	V	70.18	V	9.22	V	5.75	V	42.63	V	997.33	V	138162.86
MAV		84.05		9.35		3.58		37.07		1006.71		161416.03

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Dec/ 2020

Date of creation: 01/01/2021 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/12/20	V	1018.20				
02/12/20	V	1009.22				
03/12/20	V	999.54				
04/12/20	V	1022.27				
05/12/20	V	1008.59				
06/12/20	V	1002.15				
07/12/20	V	994.26				
08/12/20	V	999.50				
09/12/20	V	1008.07				
10/12/20	V	996.26				
11/12/20	V	983.40				
12/12/20	V	1002.79				
13/12/20	V	974.54				
14/12/20	V	963.98				
15/12/20	V	962.59				
16/12/20	V	969.28				
17/12/20	V	939.58				
18/12/20	V	964.28				
19/12/20	V	976.93				
20/12/20	V	983.63				
21/12/20	V	989.34				
22/12/20	V	984.02				
23/12/20	V	972.68				
24/12/20	V	980.38				
25/12/20	V	975.16				
26/12/20	N	0.00				
27/12/20	N	0.00				
28/12/20	N	0.00				
29/12/20	N	0.00				
30/12/20	N	0.00				
31/12/20	V	949.28				
MAV		987.10				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value