

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2021

Date of creation: 24/01/2021 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/01/21	V	0.03	V	0.01	V	0.48	V	0.01	V	0.41	V	0.69
02/01/21	V	0.00	V	0.00	V	0.40	V	0.01	V	0.66	V	0.48
03/01/21	V	0.00	V	0.00	V	0.38	V	0.03	V	0.49	V	0.38
04/01/21	V	0.00	V	0.00	V	0.39	V	0.02	V	1.48	V	0.41
05/01/21	V	0.00	V	0.02	V	0.46	V	0.13	V	1.99	V	0.30
06/01/21	V	0.02	V	0.02	V	0.44	V	0.10	V	1.17	V	0.40
07/01/21	V	0.01	V	0.01	V	0.38	V	0.06	V	0.55	V	0.44
08/01/21	V	0.00	V	0.10	V	0.39	V	0.05	V	1.12	V	0.56
09/01/21	V	0.00	V	0.08	V	0.36	V	0.04	V	1.68	V	0.37
10/01/21	V	0.00	V	0.04	V	0.36	V	0.03	V	2.03	V	0.39
11/01/21	V	0.00	V	0.06	V	0.35	V	0.06	V	3.24	V	0.52
12/01/21	V	0.00	V	0.10	V	0.32	V	0.05	V	2.70	V	0.36
13/01/21	V	0.07	V	0.00	V	0.34	V	0.07	V	3.06	V	0.46
14/01/21	V	0.00	V	0.04	V	0.36	V	0.04	V	3.54	V	0.46
15/01/21	V	0.00	V	0.03	V	0.34	V	0.06	V	1.99	V	0.57
16/01/21	V	0.01	V	0.00	V	0.37	V	0.15	V	3.15	V	0.45
17/01/21	V	0.06	V	0.00	V	0.40	V	0.18	V	2.40	V	0.26
18/01/21	V	0.00	V	0.01	V	0.37	V	0.20	V	0.71	V	0.37
19/01/21	V	0.00	V	0.00	V	0.32	V	0.05	V	1.67	V	0.31
20/01/21	V	0.00	V	0.00	V	0.33	V	0.06	V	1.53	V	0.32
21/01/21	V	0.00	V	0.03	V	0.26	V	0.01	V	4.98	V	0.28
22/01/21	V	0.01	V	0.01	V	0.25	V	0.03	V	5.69	V	0.30
23/01/21	V	0.02	V	0.00	V	0.27	V	0.06	V	6.32	V	0.28
MAV		0.01		0.03		0.36		0.07		2.29		0.41

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2021

Date of creation: 24/01/2021 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/01/21	V	74.48	V	9.06	V	6.38	V	44.22	V	997.85	V	156064.15
02/01/21	V	77.00	V	8.66	V	5.30	V	41.59	V	1004.08	V	152882.89
03/01/21	V	72.50	V	8.49	V	3.36	V	36.86	V	1009.37	V	149757.55
04/01/21	V	61.63	V	8.78	V	2.97	V	35.37	V	1008.99	V	153441.78
05/01/21	V	77.66	V	9.04	V	2.41	V	33.03	V	1006.95	V	153978.91
06/01/21	V	74.80	V	8.93	V	2.10	V	31.95	V	1003.48	V	156199.13
07/01/21	V	74.96	V	9.17	V	2.28	V	32.41	V	998.50	V	157952.60
08/01/21	V	71.79	V	9.27	V	2.21	V	32.35	V	998.61	V	160025.69
09/01/21	V	80.50	V	8.93	V	2.50	V	33.77	V	1002.35	V	157082.88
10/01/21	V	76.46	V	8.90	V	2.38	V	33.62	V	1008.44	V	157611.70
11/01/21	V	75.55	V	8.77	V	2.42	V	33.49	V	1004.58	V	155898.84
12/01/21	V	80.43	V	8.62	V	2.33	V	33.15	V	993.81	V	153092.88
13/01/21	V	80.39	V	8.77	V	2.77	V	34.18	V	990.17	V	154217.13
14/01/21	V	72.00	V	8.95	V	3.35	V	37.15	V	996.87	V	155236.83
15/01/21	V	85.09	V	8.84	V	5.05	V	42.54	V	1002.19	V	156964.10
16/01/21	V	89.63	V	8.62	V	6.54	V	45.95	V	1002.24	V	155424.21
17/01/21	V	90.73	V	8.64	V	7.25	V	47.77	V	1007.38	V	155247.47
18/01/21	V	88.84	V	8.78	V	7.45	V	48.29	V	1007.61	V	156739.99
19/01/21	V	89.32	V	8.79	V	5.60	V	44.11	V	1003.56	V	157233.74
20/01/21	V	89.41	V	8.98	V	4.45	V	40.61	V	996.61	V	157158.58
21/01/21	V	85.72	V	8.81	V	2.75	V	34.24	V	990.70	V	156093.89
22/01/21	V	92.80	V	8.75	V	2.44	V	33.04	V	986.93	V	155615.49
23/01/21	V	92.24	V	8.72	V	2.72	V	33.91	V	987.57	V	155768.01
MAV		80.64		8.84		3.77		37.52		1000.39		155638.20

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jan/ 2021

Date of creation: 24/01/2021 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/01/21	V	961.51				
02/01/21	V	981.50				
03/01/21	V	985.42				
04/01/21	V	964.85				
05/01/21	V	949.04				
06/01/21	V	961.63				
07/01/21	V	967.74				
08/01/21	V	954.34				
09/01/21	V	961.50				
10/01/21	V	962.04				
11/01/21	V	965.92				
12/01/21	V	964.36				
13/01/21	V	969.01				
14/01/21	V	959.54				
15/01/21	V	966.86				
16/01/21	V	947.86				
17/01/21	V	930.30				
18/01/21	V	932.67				
19/01/21	V	944.77				
20/01/21	V	950.48				
21/01/21	V	963.46				
22/01/21	V	959.77				
23/01/21	V	968.60				
MAV		959.71				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value