

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Feb/ 2021

Date of creation: 01/03/2021 04:31

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/02/21	V	0.00	V	0.00	V	0.00	V	0.02	V	5.32	V	0.61
02/02/21	V	0.00	V	0.00	V	0.00	V	0.04	V	4.12	V	0.57
03/02/21	V	0.18	V	0.00	V	0.00	V	0.03	V	4.98	V	0.62
04/02/21	V	0.02	V	0.00	V	0.00	V	0.03	V	5.76	V	0.63
05/02/21	V	0.19	V	0.00	V	0.00	V	0.05	V	2.41	V	0.58
06/02/21	V	0.03	V	0.00	V	0.00	V	0.01	V	1.04	V	0.76
07/02/21	V	0.01	V	0.00	V	0.00	V	0.01	V	1.59	V	0.65
08/02/21	V	0.00	V	0.00	V	0.00	V	0.01	V	0.60	V	0.60
09/02/21	V	0.00	V	0.00	V	0.00	V	0.04	V	1.01	V	0.60
10/02/21	V	0.00	V	0.00	V	0.00	V	0.02	V	1.89	V	0.62
11/02/21	V	0.00	V	0.00	V	0.09	V	0.10	V	2.30	V	0.58
12/02/21	V	0.00	V	0.00	V	0.23	V	0.19	V	3.37	V	0.37
13/02/21	V	0.18	V	0.01	V	0.17	V	0.06	V	5.06	V	0.34
14/02/21	V	0.04	V	0.02	V	0.16	V	0.02	V	3.31	V	0.28
15/02/21	V	0.00	V	0.02	V	0.19	V	0.14	V	3.84	V	0.32
16/02/21	V	0.09	V	0.02	V	0.19	V	0.10	V	1.69	V	0.28
17/02/21	V	0.03	V	0.00	V	0.18	V	0.05	V	4.49	V	0.33
18/02/21	V	0.00	V	0.03	V	0.21	V	0.22	V	1.39	V	0.30
19/02/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/02/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/02/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/02/21	V	0.14	V	0.02	V	0.22	V	0.07	V	5.59	V	0.28
23/02/21	V	0.00	V	0.04	V	0.21	V	0.08	V	2.29	V	0.32
24/02/21	V	0.01	V	0.09	V	0.24	V	0.07	V	5.17	V	0.24
25/02/21	V	0.00	V	0.18	V	0.28	V	0.01	V	6.53	V	0.28
26/02/21	V	0.00	V	0.34	V	0.40	V	0.03	V	3.76	V	0.32
27/02/21	V	0.00	V	0.13	V	0.41	V	0.08	V	2.02	V	0.29
28/02/21	V	0.00	V	0.17	V	0.34	V	0.06	V	0.61	V	0.33
MAV		0.03		0.04		0.14		0.06		3.17		0.45

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Feb/ 2021

Date of creation: 01/03/2021 04:31

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/02/21	V	89.30	V	8.63	V	2.71	V	39.04	V	993.64	V	160398.07
02/02/21	V	82.82	V	8.51	V	3.15	V	40.25	V	994.58	V	158260.13
03/02/21	V	100.19	V	8.50	V	2.57	V	37.39	V	992.31	V	157693.41
04/02/21	V	107.62	V	8.70	V	2.35	V	37.92	V	996.22	V	161217.10
05/02/21	V	108.05	V	8.77	V	3.90	V	42.28	V	1006.23	V	161438.81
06/02/21	V	113.31	V	8.82	V	5.45	V	46.74	V	1009.85	V	163330.63
07/02/21	V	125.52	V	8.69	V	5.59	V	47.27	V	1011.19	V	162620.43
08/02/21	V	115.12	V	8.87	V	4.89	V	45.88	V	1004.97	V	161873.67
09/02/21	V	125.43	V	8.92	V	4.93	V	45.44	V	995.89	V	163941.69
10/02/21	V	126.19	V	9.16	V	5.25	V	46.23	V	998.23	V	168684.71
11/02/21	V	137.70	V	9.49	V	5.72	V	46.96	V	1007.00	V	172662.70
12/02/21	V	140.54	V	9.36	V	5.95	V	45.98	V	1013.30	V	168376.34
13/02/21	V	101.97	V	8.72	V	4.99	V	42.23	V	1012.54	V	160335.23
14/02/21	V	100.71	V	9.01	V	3.34	V	37.25	V	1013.25	V	160132.51
15/02/21	V	99.57	V	9.04	V	4.41	V	40.71	V	1018.02	V	159604.14
16/02/21	V	96.75	V	9.00	V	4.95	V	42.02	V	1011.21	V	157877.84
17/02/21	V	99.84	V	8.97	V	4.95	V	41.79	V	1005.11	V	155812.88
18/02/21	V	118.21	V	8.29	V	5.57	V	43.71	V	1011.79	V	145350.66
19/02/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/02/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/02/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/02/21	V	103.97	V	11.09	V	2.17	V	31.72	V	1012.40	V	133900.09
23/02/21	V	103.80	V	8.92	V	2.15	V	32.55	V	1015.51	V	158651.92
24/02/21	V	106.62	V	8.85	V	2.51	V	33.34	V	1015.72	V	155788.24
25/02/21	V	106.83	V	9.02	V	3.33	V	34.75	V	1011.10	V	153621.61
26/02/21	V	106.79	V	9.05	V	1.95	V	31.03	V	1005.10	V	154387.96
27/02/21	V	104.97	V	8.98	V	1.85	V	31.26	V	1009.55	V	153883.65
28/02/21	V	102.35	V	8.94	V	1.93	V	31.44	V	1012.58	V	153449.96
MAV		108.96		8.92		3.88		39.97		1006.86		159456.16

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Feb/ 2021

Date of creation: 01/03/2021 04:31

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/02/21	V	933.17				
02/02/21	V	947.81				
03/02/21	V	955.28				
04/02/21	V	952.43				
05/02/21	V	962.88				
06/02/21	V	951.83				
07/02/21	V	946.55				
08/02/21	V	953.02				
09/02/21	V	956.95				
10/02/21	V	943.81				
11/02/21	V	923.55				
12/02/21	V	927.24				
13/02/21	V	948.81				
14/02/21	V	942.89				
15/02/21	V	938.33				
16/02/21	V	952.95				
17/02/21	V	952.94				
18/02/21	V	982.09				
19/02/21	N	0.00				
20/02/21	N	0.00				
21/02/21	N	0.00				
22/02/21	V	927.07				
23/02/21	V	995.85				
24/02/21	V	956.41				
25/02/21	V	921.07				
26/02/21	V	943.24				
27/02/21	V	965.76				
28/02/21	V	976.81				
MAV		950.47				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value