

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2021

Date of creation: 01/04/2021 04:30

| Date | Dulkės | | HCl | | SO ₂ | | HF | | CO | | BOA | |
|----------|--------|--------------------|-------|--------------------|-----------------|--------------------|-------|--------------------|-------|--------------------|-------|--------------------|
| | Unit: | mg/Nm ³ | Unit: | mg/Nm ³ | Unit: | mg/Nm ³ | Unit: | mg/Nm ³ | Unit: | mg/Nm ³ | Unit: | mg/Nm ³ |
| | DLV: | 10.00 | DLV: | 10.00 | DLV: | 50.00 | DLV: | 1.00 | DLV: | 50.00 | DLV: | 10.00 |
| 01/03/21 | V | 0.00 | V | 0.09 | V | 0.31 | V | 0.07 | V | 2.77 | V | 0.33 |
| 02/03/21 | V | 0.00 | V | 0.23 | V | 0.32 | V | 0.03 | V | 1.92 | V | 0.34 |
| 03/03/21 | V | 0.00 | V | 0.03 | V | 0.29 | V | 0.06 | V | 2.49 | V | 0.36 |
| 04/03/21 | V | 0.05 | V | 0.01 | V | 0.27 | V | 0.03 | V | 2.05 | V | 0.37 |
| 05/03/21 | V | 0.00 | V | 0.01 | V | 0.23 | V | 0.06 | V | 3.00 | V | 0.19 |
| 06/03/21 | V | 0.00 | V | 0.10 | V | 0.27 | V | 0.04 | V | 1.78 | V | 0.27 |
| 07/03/21 | V | 0.00 | V | 0.16 | V | 0.27 | V | 0.04 | V | 4.63 | V | 0.22 |
| 08/03/21 | V | 0.02 | V | 0.04 | V | 0.24 | V | 0.08 | V | 2.44 | V | 0.39 |
| 09/03/21 | V | 0.00 | V | 0.03 | V | 0.23 | V | 0.09 | V | 2.47 | V | 0.54 |
| 10/03/21 | V | 0.02 | V | 0.01 | V | 0.23 | V | 0.10 | V | 2.63 | V | 0.46 |
| 11/03/21 | V | 0.00 | V | 0.00 | V | 0.22 | V | 0.06 | V | 3.35 | V | 0.49 |
| 12/03/21 | V | 0.15 | V | 0.09 | V | 0.23 | V | 0.02 | V | 3.38 | V | 0.50 |
| 13/03/21 | V | 0.00 | V | 0.02 | V | 0.22 | V | 0.13 | V | 1.14 | V | 0.57 |
| 14/03/21 | V | 0.15 | V | 0.01 | V | 0.21 | V | 0.06 | V | 0.92 | V | 0.47 |
| 15/03/21 | V | 0.25 | V | 0.06 | V | 0.27 | V | 0.03 | V | 3.77 | V | 0.48 |
| 16/03/21 | V | 0.00 | V | 0.07 | V | 0.29 | V | 0.02 | V | 5.54 | V | 0.44 |
| 17/03/21 | V | 0.00 | V | 0.00 | V | 0.24 | V | 0.05 | V | 2.27 | V | 0.40 |
| 18/03/21 | V | 0.00 | V | 0.00 | V | 0.22 | V | 0.03 | V | 2.03 | V | 0.35 |
| 19/03/21 | V | 0.00 | V | 0.02 | V | 0.22 | V | 0.06 | V | 1.99 | V | 0.39 |
| 20/03/21 | V | 0.06 | V | 0.03 | V | 0.24 | V | 0.07 | V | 1.87 | V | 0.47 |
| 21/03/21 | V | 0.13 | V | 0.02 | V | 0.22 | V | 0.05 | V | 0.94 | V | 0.37 |
| 22/03/21 | V | 0.06 | V | 0.02 | V | 0.22 | V | 0.05 | V | 1.73 | V | 0.34 |
| 23/03/21 | V | 0.00 | V | 0.02 | V | 0.24 | V | 0.06 | V | 2.45 | V | 0.36 |
| 24/03/21 | V | 0.00 | V | 0.08 | V | 0.28 | V | 0.06 | V | 1.46 | V | 0.35 |
| 25/03/21 | V | 0.01 | V | 0.16 | V | 0.32 | V | 0.00 | V | 1.83 | V | 0.34 |
| 26/03/21 | V | 0.00 | V | 0.14 | V | 0.35 | V | 0.00 | V | 1.06 | V | 0.31 |
| 27/03/21 | V | 0.01 | V | 0.23 | V | 0.43 | V | 0.01 | V | 0.96 | V | 0.35 |
| 28/03/21 | V | 0.01 | V | 0.14 | V | 0.39 | V | 0.02 | V | 1.14 | V | 0.35 |
| 29/03/21 | V | 0.01 | V | 0.06 | V | 0.35 | V | 0.05 | V | 0.99 | V | 0.36 |
| 30/03/21 | V | 0.22 | V | 0.08 | V | 0.49 | V | 0.04 | V | 2.98 | V | 0.37 |
| 31/03/21 | V | 0.00 | V | 0.03 | V | 0.58 | V | 0.00 | V | 2.96 | V | 0.44 |
| MAV | | 0.04 | | 0.06 | | 0.29 | | 0.05 | | 2.29 | | 0.39 |

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2021

Date of creation: 01/04/2021 04:30

| Date | NOx | | O ₂ | | H ₂ O | | Kamino T | | Slėgis | | Srautas | |
|----------|-------|--------------------|----------------|------|------------------|------|----------|-------|--------|---------|---------|--------------------|
| | Unit: | mg/Nm ³ | Unit: | Vol% | Unit: | Vol% | Unit: | °C | Unit: | hPa | Unit: | Nm ³ /h |
| 01/03/21 | V | 108.89 | V | 9.05 | V | 2.01 | V | 31.84 | V | 1016.75 | V | 155224.21 |
| 02/03/21 | V | 103.68 | V | 8.86 | V | 2.05 | V | 31.90 | V | 1013.99 | V | 152830.82 |
| 03/03/21 | V | 105.96 | V | 8.88 | V | 2.01 | V | 32.01 | V | 1012.21 | V | 151714.18 |
| 04/03/21 | V | 95.73 | V | 8.94 | V | 2.12 | V | 32.22 | V | 997.91 | V | 150382.04 |
| 05/03/21 | V | 88.02 | V | 9.12 | V | 2.11 | V | 32.83 | V | 1004.48 | V | 151697.77 |
| 06/03/21 | V | 84.54 | V | 9.05 | V | 4.23 | V | 37.60 | V | 1008.56 | V | 153987.23 |
| 07/03/21 | V | 95.18 | V | 8.73 | V | 2.34 | V | 32.97 | V | 993.77 | V | 150867.73 |
| 08/03/21 | V | 91.25 | V | 9.10 | V | 5.60 | V | 42.25 | V | 1000.74 | V | 154328.34 |
| 09/03/21 | V | 89.14 | V | 9.42 | V | 4.41 | V | 38.68 | V | 1008.42 | V | 135534.97 |
| 10/03/21 | V | 88.62 | V | 9.28 | V | 2.69 | V | 35.20 | V | 1008.51 | V | 139510.10 |
| 11/03/21 | V | 87.12 | V | 8.99 | V | 2.68 | V | 34.96 | V | 1001.49 | V | 164894.40 |
| 12/03/21 | V | 94.16 | V | 8.93 | V | 2.92 | V | 34.58 | V | 985.24 | V | 163860.64 |
| 13/03/21 | V | 92.54 | V | 8.83 | V | 2.53 | V | 33.36 | V | 988.36 | V | 163230.53 |
| 14/03/21 | V | 92.03 | V | 8.80 | V | 2.96 | V | 34.61 | V | 983.46 | V | 163817.24 |
| 15/03/21 | V | 95.11 | V | 8.76 | V | 2.89 | V | 34.51 | V | 993.60 | V | 164192.75 |
| 16/03/21 | V | 96.32 | V | 8.87 | V | 2.73 | V | 34.28 | V | 999.70 | V | 166353.70 |
| 17/03/21 | V | 98.27 | V | 8.88 | V | 2.48 | V | 33.74 | V | 1003.09 | V | 165955.12 |
| 18/03/21 | V | 86.49 | V | 8.83 | V | 2.88 | V | 35.20 | V | 1003.48 | V | 166079.94 |
| 19/03/21 | V | 90.61 | V | 8.82 | V | 3.05 | V | 35.92 | V | 1004.45 | V | 165952.22 |
| 20/03/21 | V | 92.17 | V | 8.77 | V | 3.29 | V | 37.05 | V | 1007.24 | V | 166131.40 |
| 21/03/21 | V | 91.63 | V | 8.71 | V | 3.42 | V | 36.48 | V | 992.55 | V | 164319.15 |
| 22/03/21 | V | 86.15 | V | 8.70 | V | 2.89 | V | 35.27 | V | 997.65 | V | 165864.93 |
| 23/03/21 | V | 85.85 | V | 8.77 | V | 3.51 | V | 37.26 | V | 1004.49 | V | 166148.56 |
| 24/03/21 | V | 93.67 | V | 8.96 | V | 3.20 | V | 36.10 | V | 1009.07 | V | 167357.77 |
| 25/03/21 | V | 94.48 | V | 9.09 | V | 2.89 | V | 34.91 | V | 1007.27 | V | 168976.38 |
| 26/03/21 | V | 97.22 | V | 9.02 | V | 3.36 | V | 36.20 | V | 1008.72 | V | 166893.81 |
| 27/03/21 | V | 93.95 | V | 9.01 | V | 4.35 | V | 38.05 | V | 1006.99 | V | 167697.79 |
| 28/03/21 | V | 90.70 | V | 8.97 | V | 3.04 | V | 35.29 | V | 1011.53 | V | 167412.59 |
| 29/03/21 | V | 89.55 | V | 8.97 | V | 3.07 | V | 35.37 | V | 1014.33 | V | 166194.80 |
| 30/03/21 | V | 86.72 | V | 8.99 | V | 3.45 | V | 35.75 | V | 1011.70 | V | 159210.59 |
| 31/03/21 | V | 86.53 | V | 8.99 | V | 3.06 | V | 34.68 | V | 1007.52 | V | 156842.84 |
| MAV | | 92.68 | | 8.94 | | 3.04 | | 35.19 | | 1003.41 | | 160100.83 |

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Mar/ 2021

Date of creation: 01/04/2021 04:30

| Date | Degimo T | | | | | |
|----------|----------|-------------|--|--|--|--|
| | Unit: °C | DLV: 850.00 | | | | |
| 01/03/21 | V | 947.93 | | | | |
| 02/03/21 | V | 935.75 | | | | |
| 03/03/21 | V | 943.13 | | | | |
| 04/03/21 | V | 948.20 | | | | |
| 05/03/21 | V | 953.55 | | | | |
| 06/03/21 | V | 967.28 | | | | |
| 07/03/21 | V | 943.49 | | | | |
| 08/03/21 | V | 929.90 | | | | |
| 09/03/21 | V | 926.92 | | | | |
| 10/03/21 | V | 957.84 | | | | |
| 11/03/21 | V | 975.79 | | | | |
| 12/03/21 | V | 979.10 | | | | |
| 13/03/21 | V | 993.06 | | | | |
| 14/03/21 | V | 995.67 | | | | |
| 15/03/21 | V | 971.05 | | | | |
| 16/03/21 | V | 950.61 | | | | |
| 17/03/21 | V | 958.43 | | | | |
| 18/03/21 | V | 969.37 | | | | |
| 19/03/21 | V | 985.69 | | | | |
| 20/03/21 | V | 991.09 | | | | |
| 21/03/21 | V | 995.90 | | | | |
| 22/03/21 | V | 969.06 | | | | |
| 23/03/21 | V | 952.79 | | | | |
| 24/03/21 | V | 967.13 | | | | |
| 25/03/21 | V | 976.07 | | | | |
| 26/03/21 | V | 989.59 | | | | |
| 27/03/21 | V | 996.94 | | | | |
| 28/03/21 | V | 998.39 | | | | |
| 29/03/21 | V | 967.02 | | | | |
| 30/03/21 | V | 943.95 | | | | |
| 31/03/21 | V | 959.76 | | | | |
| MAV | | 965.86 | | | | |

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value