

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2021

Date of creation: 01/06/2021 04:31

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/05/21	V	0.00	V	0.10	V	0.63	V	0.02	V	5.38	V	0.29
02/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
03/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
09/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
10/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
11/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
12/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
13/05/21	V	0.09	V	0.00	V	1.03	V	0.01	V	39.86	V	0.49
14/05/21	V	0.01	V	0.08	V	0.77	V	0.00	V	19.34	V	0.45
15/05/21	V	0.01	V	0.00	V	0.76	V	0.00	V	12.36	V	0.38
16/05/21	V	0.07	V	0.00	V	0.76	V	0.00	V	2.38	V	0.39
17/05/21	V	0.11	V	0.00	V	0.75	V	0.01	V	8.56	V	0.43
18/05/21	V	0.01	V	0.02	V	0.67	V	0.02	V	5.86	V	0.38
19/05/21	V	0.01	V	0.01	V	0.68	V	0.03	V	4.96	V	0.31
20/05/21	V	0.00	V	0.00	V	0.73	V	0.01	V	0.66	V	0.30
21/05/21	V	0.00	V	0.00	V	0.70	V	0.01	V	0.80	V	0.38
22/05/21	V	0.07	V	0.00	V	0.64	V	0.00	V	0.17	V	0.37
23/05/21	V	0.01	V	0.02	V	0.62	V	0.01	V	0.52	V	0.37
24/05/21	V	0.00	V	0.01	V	0.65	V	0.02	V	5.64	V	0.33
25/05/21	V	0.02	V	0.00	V	0.74	V	0.01	V	21.32	V	0.32
26/05/21	V	0.00	V	0.00	V	0.65	V	0.04	V	5.95	V	0.41
27/05/21	V	0.12	V	0.00	V	0.93	V	0.02	V	9.90	V	0.44
28/05/21	V	0.00	V	0.01	V	0.61	V	0.03	V	2.47	V	0.39
29/05/21	V	0.00	V	0.02	V	0.65	V	0.02	V	8.77	V	0.43
30/05/21	V	0.00	V	0.00	V	0.66	V	0.05	V	2.60	V	0.42
31/05/21	V	0.00	V	0.00	V	0.68	V	0.04	V	0.65	V	0.37
MAV		0.03		0.01		0.72		0.02		7.73		0.38

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2021

Date of creation: 01/06/2021 04:31

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/05/21	V	85.05	V	9.53	V	6.03	V	36.96	V	1002.72	V	153407.85
02/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
03/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
09/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
10/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
11/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
12/05/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
13/05/21	V	82.50	V	9.93	V	15.52	V	55.63	V	991.56	V	135577.75
14/05/21	V	85.05	V	10.59	V	13.05	V	50.87	V	988.89	V	142292.50
15/05/21	V	70.03	V	10.22	V	15.40	V	55.23	V	992.09	V	142593.87
16/05/21	V	85.98	V	10.00	V	16.34	V	56.63	V	993.76	V	143550.51
17/05/21	V	64.95	V	10.30	V	13.58	V	51.55	V	991.61	V	141369.83
18/05/21	V	69.60	V	10.31	V	14.72	V	54.03	V	989.83	V	141827.76
19/05/21	V	66.04	V	10.09	V	14.58	V	53.98	V	991.84	V	143734.45
20/05/21	V	60.51	V	9.85	V	15.25	V	55.25	V	995.35	V	148658.00
21/05/21	V	59.96	V	9.77	V	14.35	V	53.93	V	995.50	V	149498.53
22/05/21	V	59.35	V	9.59	V	16.25	V	56.76	V	991.54	V	148950.49
23/05/21	V	67.18	V	9.55	V	12.98	V	50.74	V	994.55	V	157590.33
24/05/21	V	71.10	V	9.43	V	9.85	V	46.01	V	1005.78	V	158674.53
25/05/21	V	65.74	V	10.28	V	13.75	V	52.67	V	1002.34	V	145728.43
26/05/21	V	59.80	V	9.81	V	13.87	V	52.91	V	998.90	V	134422.80
27/05/21	V	51.63	V	9.88	V	11.70	V	48.85	V	999.57	V	134128.39
28/05/21	V	58.80	V	10.03	V	12.01	V	49.46	V	1002.52	V	133997.65
29/05/21	V	58.40	V	10.27	V	13.06	V	51.47	V	1003.88	V	136773.39
30/05/21	V	53.36	V	10.16	V	11.83	V	49.93	V	1008.06	V	134385.34
31/05/21	V	52.96	V	10.03	V	11.52	V	49.24	V	1007.65	V	132758.61
MAV		65.76		9.99		13.47		51.99		997.32		142766.07

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: May/ 2021

Date of creation: 01/06/2021 04:31

Date	Degimo T					
	Unit:	°C				
	DLV:	850.00				
01/05/21	V	982.26				
02/05/21	N	0.00				
03/05/21	N	0.00				
04/05/21	N	0.00				
05/05/21	N	0.00				
06/05/21	N	0.00				
07/05/21	N	0.00				
08/05/21	N	0.00				
09/05/21	N	0.00				
10/05/21	N	0.00				
11/05/21	N	0.00				
12/05/21	N	0.00				
13/05/21	V	984.93				
14/05/21	V	968.82				
15/05/21	V	965.23				
16/05/21	V	962.84				
17/05/21	V	962.09				
18/05/21	V	964.13				
19/05/21	V	978.70				
20/05/21	V	984.11				
21/05/21	V	994.11				
22/05/21	V	999.57				
23/05/21	V	1017.36				
24/05/21	V	981.07				
25/05/21	V	941.45				
26/05/21	V	960.20				
27/05/21	V	971.54				
28/05/21	V	967.88				
29/05/21	V	966.81				
30/05/21	V	975.45				
31/05/21	V	984.69				
MAV		975.46				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value