

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jun/ 2021

Date of creation: 01/07/2021 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/06/21	V	0.00	V	0.01	V	0.63	V	0.02	V	0.45	V	0.36
02/06/21	V	0.00	V	0.00	V	0.65	V	0.02	V	0.78	V	0.35
03/06/21	V	0.00	V	0.00	V	0.65	V	0.02	V	1.16	V	0.30
04/06/21	V	0.01	V	0.00	V	0.62	V	0.01	V	0.73	V	0.31
05/06/21	V	0.00	V	0.00	V	0.65	V	0.01	V	0.01	V	0.35
06/06/21	V	0.00	V	0.00	V	0.65	V	0.00	V	0.12	V	0.33
07/06/21	V	0.01	V	0.00	V	0.65	V	0.00	V	0.14	V	0.31
08/06/21	V	0.00	V	0.00	V	0.67	V	0.00	V	0.00	V	0.32
09/06/21	V	0.01	V	0.00	V	0.64	V	0.00	V	0.04	V	0.27
10/06/21	V	0.02	V	0.00	V	0.68	V	0.00	V	0.17	V	0.33
11/06/21	V	0.09	V	0.00	V	0.65	V	0.00	V	0.54	V	0.34
12/06/21	V	0.01	V	0.00	V	0.65	V	0.01	V	0.05	V	0.31
13/06/21	V	0.00	V	0.00	V	0.66	V	0.01	V	2.27	V	0.26
14/06/21	V	0.02	V	0.00	V	0.68	V	0.02	V	0.20	V	0.33
15/06/21	V	0.03	V	0.00	V	0.68	V	0.00	V	0.15	V	0.30
16/06/21	V	0.00	V	0.00	V	0.66	V	0.03	V	0.05	V	0.31
17/06/21	V	0.00	V	0.00	V	0.65	V	0.02	V	0.14	V	0.28
18/06/21	V	0.06	V	0.01	V	0.66	V	0.01	V	1.22	V	0.32
19/06/21	V	0.01	V	0.00	V	0.66	V	0.01	V	0.00	V	0.29
20/06/21	V	0.01	V	0.00	V	0.67	V	0.00	V	0.00	V	0.27
21/06/21	V	0.00	V	0.00	V	0.69	V	0.00	V	0.07	V	0.27
22/06/21	V	0.03	V	0.00	V	0.66	V	0.00	V	0.25	V	0.25
23/06/21	V	0.00	V	0.00	V	0.66	V	0.00	V	0.09	V	0.27
24/06/21	V	0.01	V	0.00	V	0.66	V	0.00	V	0.77	V	0.31
25/06/21	V	0.09	V	0.00	V	0.66	V	0.00	V	0.08	V	0.29
26/06/21	V	0.04	V	0.00	V	0.69	V	0.00	V	0.07	V	0.32
27/06/21	V	0.15	V	0.00	V	0.70	V	0.00	V	0.02	V	0.30
28/06/21	V	0.05	V	0.00	V	0.68	V	0.00	V	0.23	V	0.28
29/06/21	V	0.04	V	0.00	V	0.68	V	0.00	V	0.16	V	0.27
30/06/21	V	0.15	V	0.00	V	0.69	V	0.00	V	0.34	V	0.26
MAV		0.03		0.00		0.66		0.01		0.34		0.30

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jun/ 2021

Date of creation: 01/07/2021 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/06/21	V	49.65	V	10.03	V	13.27	V	52.02	V	1005.63	V	131772.15
02/06/21	V	63.33	V	10.21	V	11.60	V	49.43	V	1011.72	V	132467.94
03/06/21	V	69.93	V	10.36	V	11.43	V	48.85	V	1013.04	V	131734.65
04/06/21	V	69.72	V	10.44	V	11.66	V	49.27	V	1011.36	V	130486.26
05/06/21	V	68.58	V	10.27	V	13.99	V	53.32	V	1006.73	V	130666.11
06/06/21	V	68.67	V	10.50	V	12.09	V	49.69	V	1004.49	V	130244.94
07/06/21	V	69.54	V	10.41	V	14.86	V	54.51	V	1003.58	V	130738.57
08/06/21	V	70.03	V	10.35	V	16.00	V	56.29	V	1003.47	V	131092.90
09/06/21	V	69.56	V	10.38	V	14.59	V	53.86	V	1002.69	V	129622.29
10/06/21	V	67.96	V	10.54	V	14.56	V	53.67	V	1001.86	V	129247.10
11/06/21	V	68.81	V	10.53	V	13.86	V	52.49	V	1000.61	V	128912.25
12/06/21	V	69.25	V	10.28	V	15.84	V	55.63	V	995.30	V	129797.65
13/06/21	V	68.65	V	9.79	V	15.96	V	55.98	V	994.95	V	130216.50
14/06/21	V	69.14	V	10.28	V	14.07	V	53.60	V	1005.23	V	133735.79
15/06/21	V	68.14	V	10.51	V	15.45	V	55.53	V	1002.56	V	128638.52
16/06/21	V	70.43	V	10.27	V	14.17	V	53.48	V	1005.95	V	128130.59
17/06/21	V	72.98	V	10.38	V	12.89	V	51.31	V	1009.16	V	131958.79
18/06/21	V	72.08	V	10.74	V	15.02	V	54.88	V	1008.47	V	136397.93
19/06/21	V	83.68	V	10.59	V	16.80	V	57.55	V	1005.95	V	136105.63
20/06/21	V	80.86	V	10.79	V	16.81	V	57.15	V	1002.90	V	135790.93
21/06/21	V	80.51	V	10.71	V	17.06	V	57.38	V	999.67	V	135825.71
22/06/21	V	76.04	V	10.84	V	15.79	V	55.16	V	997.88	V	135979.18
23/06/21	V	74.65	V	10.71	V	17.19	V	57.41	V	1001.97	V	136753.83
24/06/21	V	73.02	V	10.57	V	17.02	V	57.27	V	1003.45	V	137116.15
25/06/21	V	71.79	V	10.62	V	17.10	V	57.27	V	1000.22	V	136499.83
26/06/21	V	76.75	V	10.65	V	17.00	V	57.41	V	1001.57	V	137148.50
27/06/21	V	81.03	V	10.62	V	16.54	V	56.80	V	1000.84	V	137349.82
28/06/21	V	75.60	V	10.75	V	15.80	V	55.46	V	1000.66	V	136394.97
29/06/21	V	76.61	V	10.56	V	16.90	V	57.30	V	999.13	V	137081.57
30/06/21	V	81.65	V	10.62	V	16.19	V	56.08	V	995.66	V	136666.80
MAV		71.95		10.48		15.04		54.52		1003.23		133136.74

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jun/ 2021

Date of creation: 01/07/2021 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/06/21	V	986.08				
02/06/21	V	986.73				
03/06/21	V	987.06				
04/06/21	V	998.42				
05/06/21	V	1009.73				
06/06/21	V	1003.25				
07/06/21	V	1007.66				
08/06/21	V	1008.55				
09/06/21	V	1007.71				
10/06/21	V	1003.65				
11/06/21	V	1006.47				
12/06/21	V	1015.76				
13/06/21	V	1039.39				
14/06/21	V	1017.01				
15/06/21	V	1015.27				
16/06/21	V	1020.78				
17/06/21	V	1018.30				
18/06/21	V	994.50				
19/06/21	V	1001.40				
20/06/21	V	1000.24				
21/06/21	V	998.20				
22/06/21	V	991.62				
23/06/21	V	992.23				
24/06/21	V	981.85				
25/06/21	V	990.81				
26/06/21	V	999.54				
27/06/21	V	997.16				
28/06/21	V	996.75				
29/06/21	V	997.28				
30/06/21	V	993.91				
MAV		1002.29				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value