

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2021

Date of creation: 01/08/2021 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/07/21	V	0.05	V	0.00	V	0.64	V	0.00	V	0.20	V	0.28
02/07/21	V	0.03	V	0.00	V	0.69	V	0.00	V	0.66	V	0.32
03/07/21	V	0.02	V	0.00	V	0.69	V	0.00	V	0.22	V	0.34
04/07/21	V	0.00	V	0.00	V	0.69	V	0.00	V	1.76	V	0.33
05/07/21	V	0.01	V	0.00	V	0.74	V	0.00	V	1.41	V	0.33
06/07/21	V	0.01	V	0.00	V	0.65	V	0.00	V	0.25	V	0.38
07/07/21	V	0.03	V	0.00	V	0.67	V	0.01	V	1.12	V	0.31
08/07/21	V	0.05	V	0.00	V	0.65	V	0.02	V	0.72	V	0.27
09/07/21	V	0.17	V	0.00	V	1.90	V	0.01	V	4.19	V	0.26
10/07/21	V	0.07	V	0.00	V	0.79	V	0.01	V	0.68	V	0.25
11/07/21	V	0.26	V	0.00	V	0.66	V	0.00	V	0.65	V	0.30
12/07/21	V	0.04	V	0.00	V	0.66	V	0.01	V	0.71	V	0.25
13/07/21	V	0.10	V	0.00	V	0.64	V	0.01	V	4.98	V	0.24
14/07/21	V	0.05	V	0.00	V	0.67	V	0.01	V	0.67	V	0.25
15/07/21	V	0.12	V	0.00	V	0.66	V	0.01	V	0.70	V	0.24
16/07/21	V	0.05	V	0.00	V	0.65	V	0.01	V	2.11	V	0.27
17/07/21	V	0.17	V	0.00	V	0.68	V	0.01	V	0.18	V	0.26
18/07/21	V	0.12	V	0.00	V	0.69	V	0.00	V	1.33	V	0.28
19/07/21	V	0.07	V	0.00	V	0.69	V	0.00	V	0.91	V	0.26
20/07/21	V	0.05	V	0.00	V	0.68	V	0.00	V	0.28	V	0.30
21/07/21	V	0.11	V	0.00	V	0.68	V	0.00	V	0.52	V	0.29
22/07/21	V	0.04	V	0.00	V	0.64	V	0.00	V	0.79	V	0.31
23/07/21	V	0.04	V	0.00	V	0.65	V	0.00	V	1.92	V	0.26
24/07/21	V	0.01	V	0.00	V	0.68	V	0.00	V	0.18	V	0.32
25/07/21	V	0.02	V	0.00	V	0.69	V	0.00	V	0.08	V	0.32
26/07/21	V	0.00	V	0.00	V	0.67	V	0.00	V	0.17	V	0.27
27/07/21	V	0.00	V	0.00	V	0.66	V	0.00	V	0.71	V	0.25
28/07/21	V	0.03	V	0.00	V	0.66	V	0.00	V	3.44	V	0.22
29/07/21	V	0.07	V	0.00	V	0.68	V	0.00	V	0.88	V	0.25
30/07/21	V	0.02	V	0.00	V	0.71	V	0.00	V	0.73	V	0.25
31/07/21	V	0.01	V	0.00	V	0.70	V	0.00	V	0.14	V	0.27
MAV		0.06		0.00		0.72		0.00		1.08		0.28

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2021

Date of creation: 01/08/2021 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/07/21	V	77.87	V	10.54	V	17.40	V	57.80	V	994.87	V	136406.04
02/07/21	V	74.88	V	10.70	V	17.13	V	57.37	V	995.59	V	136077.27
03/07/21	V	87.52	V	10.60	V	17.17	V	57.66	V	996.99	V	133472.06
04/07/21	V	95.79	V	10.83	V	16.92	V	57.22	V	997.73	V	136078.20
05/07/21	V	80.69	V	10.83	V	17.14	V	57.37	V	997.40	V	135605.34
06/07/21	V	84.47	V	10.71	V	17.42	V	57.73	V	999.58	V	139016.86
07/07/21	V	85.32	V	10.72	V	17.48	V	58.06	V	1004.22	V	137625.94
08/07/21	V	76.50	V	10.76	V	17.57	V	58.21	V	1007.24	V	135390.32
09/07/21	V	80.76	V	10.90	V	17.01	V	57.44	V	1005.42	V	137000.93
10/07/21	V	78.31	V	10.59	V	17.59	V	58.38	V	1002.78	V	135659.21
11/07/21	V	76.70	V	10.61	V	17.37	V	58.06	V	1005.45	V	135308.67
12/07/21	V	81.62	V	10.78	V	17.15	V	57.65	V	1003.25	V	134611.84
13/07/21	V	83.83	V	10.76	V	17.33	V	57.68	V	1001.08	V	133218.48
14/07/21	V	79.16	V	10.72	V	17.54	V	57.87	V	999.25	V	130289.40
15/07/21	V	82.81	V	10.78	V	17.65	V	57.91	V	998.95	V	129581.65
16/07/21	V	76.52	V	10.59	V	17.69	V	58.04	V	999.87	V	128905.81
17/07/21	V	81.78	V	10.70	V	18.10	V	58.68	V	1000.20	V	131176.68
18/07/21	V	73.86	V	10.69	V	17.56	V	57.98	V	997.62	V	130646.59
19/07/21	V	86.65	V	10.51	V	17.16	V	57.72	V	997.97	V	140717.00
20/07/21	V	91.80	V	10.21	V	16.92	V	57.76	V	999.98	V	152109.86
21/07/21	V	94.25	V	9.91	V	17.19	V	58.28	V	1001.51	V	159451.52
22/07/21	V	79.28	V	9.67	V	16.95	V	58.15	V	1004.32	V	160776.43
23/07/21	V	84.98	V	10.12	V	17.42	V	58.44	V	1001.11	V	150016.41
24/07/21	V	78.85	V	10.55	V	16.79	V	57.56	V	1002.26	V	137540.28
25/07/21	V	84.82	V	10.79	V	16.54	V	57.31	V	1003.83	V	138465.14
26/07/21	V	77.80	V	10.67	V	16.77	V	57.47	V	1003.20	V	138447.43
27/07/21	V	74.82	V	10.55	V	17.09	V	57.39	V	998.36	V	133959.43
28/07/21	V	79.93	V	10.86	V	17.20	V	57.46	V	996.94	V	137476.02
29/07/21	V	77.04	V	10.77	V	16.93	V	56.99	V	994.27	V	136459.20
30/07/21	V	80.10	V	10.82	V	16.47	V	56.75	V	992.82	V	137342.67
31/07/21	V	84.03	V	10.64	V	17.11	V	57.77	V	991.91	V	138786.18
MAV		81.72		10.61		17.22		57.75		999.88		137997.99

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jul/ 2021

Date of creation: 01/08/2021 04:30

Date	Degimo T					
	Unit:	°C				
	DLV:	850.00				
01/07/21	V	992.91				
02/07/21	V	985.72				
03/07/21	V	985.34				
04/07/21	V	980.85				
05/07/21	V	975.70				
06/07/21	V	984.73				
07/07/21	V	987.37				
08/07/21	V	976.12				
09/07/21	V	975.89				
10/07/21	V	983.74				
11/07/21	V	982.51				
12/07/21	V	981.78				
13/07/21	V	984.01				
14/07/21	V	987.35				
15/07/21	V	983.09				
16/07/21	V	984.69				
17/07/21	V	981.28				
18/07/21	V	979.68				
19/07/21	V	996.15				
20/07/21	V	978.29				
21/07/21	V	966.30				
22/07/21	V	970.49				
23/07/21	V	974.25				
24/07/21	V	978.94				
25/07/21	V	984.13				
26/07/21	V	986.61				
27/07/21	V	983.12				
28/07/21	V	980.54				
29/07/21	V	981.86				
30/07/21	V	984.76				
31/07/21	V	989.10				
MAV		982.16				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value