

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2021

Date of creation: 01/09/2021 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/08/21	V	0.00	V	0.00	V	0.60	V	0.00	V	0.03	V	0.29
02/08/21	V	0.02	V	0.00	V	0.63	V	0.00	V	0.42	V	0.31
03/08/21	V	0.11	V	0.00	V	0.64	V	0.00	V	2.12	V	0.30
04/08/21	V	0.06	V	0.00	V	0.62	V	0.00	V	0.25	V	0.32
05/08/21	V	0.05	V	0.00	V	0.65	V	0.00	V	0.20	V	0.33
06/08/21	V	0.06	V	0.00	V	0.62	V	0.00	V	0.31	V	0.32
07/08/21	V	0.07	V	0.00	V	0.64	V	0.00	V	0.07	V	0.28
08/08/21	V	0.09	V	0.00	V	0.73	V	0.00	V	0.01	V	0.27
09/08/21	V	0.01	V	0.00	V	0.66	V	0.00	V	0.25	V	0.28
10/08/21	V	0.01	V	0.00	V	0.66	V	0.00	V	0.07	V	0.23
11/08/21	V	0.00	V	0.00	V	0.64	V	0.00	V	2.36	V	0.33
12/08/21	V	0.01	V	0.00	V	0.61	V	0.00	V	1.32	V	0.34
13/08/21	V	0.00	V	0.00	V	0.54	V	0.01	V	0.27	V	0.31
14/08/21	V	0.00	V	0.00	V	0.51	V	0.01	V	0.17	V	0.35
15/08/21	V	0.01	V	0.00	V	0.53	V	0.00	V	0.08	V	0.35
16/08/21	V	0.00	V	0.01	V	0.52	V	0.00	V	4.40	V	0.34
17/08/21	V	0.01	V	0.00	V	0.56	V	0.00	V	1.28	V	0.36
18/08/21	V	0.04	V	0.00	V	0.55	V	0.00	V	3.06	V	0.35
19/08/21	V	0.01	V	0.00	V	0.54	V	0.00	V	1.92	V	0.34
20/08/21	V	0.08	V	0.00	V	0.51	V	0.00	V	0.77	V	0.33
21/08/21	V	0.19	V	0.00	V	0.53	V	0.00	V	0.37	V	0.26
22/08/21	V	0.00	V	0.00	V	0.52	V	0.00	V	1.63	V	0.32
23/08/21	V	0.01	V	0.00	V	0.54	V	0.00	V	6.95	V	0.31
24/08/21	V	0.00	V	0.00	V	0.52	V	0.00	V	2.98	V	0.32
25/08/21	V	0.01	V	0.00	V	0.55	V	0.00	V	7.61	V	0.37
26/08/21	V	0.00	V	0.00	V	0.55	V	0.00	V	2.82	V	0.39
27/08/21	V	0.00	V	0.00	V	0.52	V	0.00	V	0.79	V	0.32
28/08/21	V	0.00	V	0.00	V	0.53	V	0.00	V	0.96	V	0.28
29/08/21	V	0.00	V	0.00	V	0.53	V	0.00	V	0.35	V	0.33
30/08/21	V	0.00	V	0.00	V	0.54	V	0.00	V	2.32	V	0.26
31/08/21	V	0.00	V	0.00	V	0.55	V	0.00	V	2.23	V	0.37
MAV		0.03		0.00		0.58		0.00		1.56		0.32

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2021

Date of creation: 01/09/2021 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/08/21	V	102.39	V	9.38	V	17.87	V	58.80	V	992.83	V	155318.89
02/08/21	V	85.24	V	9.53	V	17.87	V	58.58	V	990.43	V	156728.28
03/08/21	V	72.46	V	9.80	V	17.34	V	58.37	V	996.79	V	161972.34
04/08/21	V	78.06	V	9.90	V	15.92	V	56.03	V	1001.08	V	161611.48
05/08/21	V	86.18	V	9.93	V	17.54	V	58.56	V	999.24	V	158698.60
06/08/21	V	102.66	V	9.69	V	17.47	V	58.26	V	989.94	V	158144.96
07/08/21	V	80.14	V	9.20	V	18.49	V	59.29	V	988.62	V	145838.65
08/08/21	V	78.78	V	9.31	V	17.93	V	58.81	V	996.99	V	145759.15
09/08/21	V	72.71	V	9.68	V	17.82	V	58.82	V	1003.61	V	148226.44
10/08/21	V	67.41	V	9.58	V	17.80	V	59.07	V	1004.55	V	149549.03
11/08/21	V	66.44	V	9.60	V	17.85	V	58.94	V	1000.99	V	148996.26
12/08/21	V	64.74	V	9.62	V	17.49	V	58.54	V	1003.52	V	149038.44
13/08/21	V	67.65	V	9.45	V	16.47	V	56.96	V	1007.72	V	148453.38
14/08/21	V	81.60	V	9.45	V	12.92	V	50.71	V	1003.28	V	147096.11
15/08/21	V	84.95	V	9.56	V	14.81	V	54.02	V	998.94	V	148529.40
16/08/21	V	77.99	V	9.63	V	14.57	V	53.47	V	995.40	V	148087.24
17/08/21	V	81.15	V	9.57	V	16.89	V	56.91	V	991.68	V	148294.73
18/08/21	V	91.27	V	9.65	V	13.53	V	51.87	V	993.81	V	150760.56
19/08/21	V	94.23	V	9.50	V	12.09	V	48.36	V	993.64	V	148762.66
20/08/21	V	94.20	V	9.39	V	13.98	V	52.64	V	999.66	V	148407.84
21/08/21	V	95.07	V	9.40	V	15.01	V	54.68	V	1002.41	V	148927.73
22/08/21	V	84.33	V	9.67	V	12.90	V	51.24	V	1005.49	V	150145.33
23/08/21	V	74.77	V	9.61	V	13.32	V	52.19	V	1007.65	V	150273.54
24/08/21	V	60.81	V	9.59	V	13.74	V	53.26	V	1009.53	V	149787.87
25/08/21	V	66.97	V	9.70	V	14.12	V	53.69	V	1002.20	V	151293.32
26/08/21	V	82.60	V	9.68	V	14.90	V	54.28	V	992.96	V	149370.79
27/08/21	V	85.80	V	9.44	V	14.53	V	53.45	V	998.36	V	148398.74
28/08/21	V	84.62	V	9.48	V	14.66	V	53.66	V	998.11	V	147728.29
29/08/21	V	75.13	V	9.62	V	14.89	V	53.67	V	997.95	V	147815.50
30/08/21	V	75.95	V	9.64	V	14.83	V	54.01	V	999.49	V	148596.14
31/08/21	V	63.16	V	9.70	V	16.41	V	56.58	V	996.51	V	148876.33
MAV		79.99		9.58		15.68		55.41		998.81		150612.44

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Aug/ 2021

Date of creation: 01/09/2021 04:30

Date	Degimo T					
	Unit:	°C				
	DLV:	850.00				
01/08/21	V	1032.97				
02/08/21	V	988.35				
03/08/21	V	965.48				
04/08/21	V	976.30				
05/08/21	V	985.95				
06/08/21	V	1015.77				
07/08/21	V	1024.18				
08/08/21	V	1036.45				
09/08/21	V	1017.38				
10/08/21	V	1016.26				
11/08/21	V	984.99				
12/08/21	V	964.24				
13/08/21	V	987.36				
14/08/21	V	1009.63				
15/08/21	V	1015.29				
16/08/21	V	978.38				
17/08/21	V	971.30				
18/08/21	V	986.06				
19/08/21	V	1005.11				
20/08/21	V	1012.09				
21/08/21	V	1009.69				
22/08/21	V	997.83				
23/08/21	V	949.19				
24/08/21	V	959.74				
25/08/21	V	964.43				
26/08/21	V	960.61				
27/08/21	V	981.95				
28/08/21	V	991.42				
29/08/21	V	1004.86				
30/08/21	V	971.92				
31/08/21	V	962.36				
MAV		991.26				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value