

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Sep/ 2021

Date of creation: 01/10/2021 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/09/21	V	0.00	V	0.00	V	0.57	V	0.00	V	0.66	V	0.39
02/09/21	V	0.00	V	0.00	V	0.60	V	0.00	V	2.70	V	0.40
03/09/21	V	0.00	V	0.00	V	0.60	V	0.00	V	3.73	V	0.37
04/09/21	V	0.00	V	0.00	V	0.69	V	0.01	V	9.54	V	0.39
05/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
09/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
10/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
11/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
12/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
13/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
14/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
15/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
16/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
17/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
18/09/21	V	0.08	V	0.00	V	0.65	V	0.25	V	57.09	V	0.43
19/09/21	V	0.03	V	0.00	V	0.64	V	0.19	V	15.48	V	0.42
20/09/21	V	0.05	V	0.00	V	0.62	V	0.18	V	0.77	V	0.45
21/09/21	V	0.04	V	0.01	V	0.57	V	0.17	V	1.56	V	0.45
22/09/21	V	0.12	V	0.00	V	0.89	V	0.27	V	2.14	V	0.72
23/09/21	V	0.00	V	0.00	V	0.36	V	0.23	V	0.25	V	0.71
24/09/21	V	0.08	V	0.00	V	0.00	V	0.11	V	0.03	V	0.62
25/09/21	V	0.01	V	0.00	V	0.00	V	0.05	V	0.00	V	0.66
26/09/21	V	0.03	V	0.00	V	0.00	V	0.05	V	0.00	V	0.63
27/09/21	V	0.00	V	0.00	V	0.00	V	0.09	V	0.49	V	0.65
28/09/21	V	0.00	V	0.00	V	0.00	V	0.12	V	0.50	V	0.63
29/09/21	V	0.00	V	0.00	V	0.00	V	0.10	V	0.54	V	0.61
30/09/21	V	0.01	V	0.00	V	0.00	V	0.11	V	0.16	V	0.63
MAV		0.03		0.00		0.34		0.11		2.69		0.55

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Sep/ 2021

Date of creation: 01/10/2021 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/09/21	V	62.33	V	9.72	V	17.47	V	58.58	V	999.77	V	145690.47
02/09/21	V	58.26	V	10.45	V	16.34	V	57.32	V	1004.01	V	137748.10
03/09/21	V	63.58	V	10.55	V	17.19	V	58.25	V	998.84	V	138650.34
04/09/21	V	60.01	V	10.59	V	16.53	V	57.70	V	1002.99	V	134660.50
05/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
06/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
09/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
10/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
11/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
12/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
13/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
14/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
15/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
16/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
17/09/21	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
18/09/21	V	62.98	V	11.01	V	16.40	V	57.51	V	1000.07	V	135030.32
19/09/21	V	81.50	V	10.43	V	16.65	V	58.20	V	999.92	V	148385.59
20/09/21	V	82.20	V	10.24	V	16.72	V	58.39	V	1002.85	V	145688.16
21/09/21	V	94.55	V	10.91	V	14.57	V	54.73	V	1005.53	V	140969.46
22/09/21	V	122.57	V	14.44	V	13.71	V	52.96	V	1005.86	V	143268.33
23/09/21	V	109.94	V	12.22	V	9.09	V	47.67	V	995.48	V	150613.66
24/09/21	V	88.00	V	10.14	V	16.65	V	56.43	V	982.06	V	145070.69
25/09/21	V	84.98	V	10.26	V	17.61	V	57.58	V	992.72	V	143337.90
26/09/21	V	98.15	V	10.38	V	15.64	V	56.07	V	1007.15	V	143785.40
27/09/21	V	101.36	V	10.06	V	8.77	V	47.65	V	1013.12	V	152647.37
28/09/21	V	77.81	V	9.84	V	5.76	V	42.14	V	1014.61	V	163786.61
29/09/21	V	76.00	V	9.69	V	2.50	V	35.66	V	1016.36	V	166480.12
30/09/21	V	84.29	V	9.60	V	2.52	V	36.06	V	1013.49	V	168098.76
MAV		84.67		10.60		12.90		52.09		1003.41		148361.75

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Sep/ 2021

Date of creation: 01/10/2021 04:30

Date	Degimo T					
	Unit:	°C				
	DLV:	850.00				
01/09/21	V	976.26				
02/09/21	V	971.32				
03/09/21	V	964.96				
04/09/21	V	947.32				
05/09/21	N	0.00				
06/09/21	N	0.00				
07/09/21	N	0.00				
08/09/21	N	0.00				
09/09/21	N	0.00				
10/09/21	N	0.00				
11/09/21	N	0.00				
12/09/21	N	0.00				
13/09/21	N	0.00				
14/09/21	N	0.00				
15/09/21	N	0.00				
16/09/21	N	0.00				
17/09/21	N	0.00				
18/09/21	V	960.09				
19/09/21	V	978.40				
20/09/21	V	998.04				
21/09/21	V	1004.55				
22/09/21	V	1004.65				
23/09/21	V	1015.64				
24/09/21	V	1009.17				
25/09/21	V	1007.96				
26/09/21	V	1007.51				
27/09/21	V	1010.73				
28/09/21	V	1001.26				
29/09/21	V	1010.53				
30/09/21	V	1014.52				
MAV		996.33				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value