

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Oct/ 2021

Date of creation: 01/11/2021 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/10/21	V	0.01	V	0.00	V	0.00	V	0.09	V	0.18	V	0.61
02/10/21	V	0.00	V	0.00	V	0.00	V	0.08	V	0.59	V	0.60
03/10/21	V	0.00	V	0.00	V	0.00	V	0.10	V	0.47	V	0.60
04/10/21	V	0.00	V	0.00	V	0.00	V	0.10	V	0.52	V	0.63
05/10/21	V	0.00	V	0.00	V	0.00	V	0.10	V	0.22	V	0.62
06/10/21	V	0.00	V	0.00	V	0.00	V	0.10	V	0.14	V	0.62
07/10/21	V	0.01	V	0.00	V	0.00	V	0.07	V	0.35	V	0.60
08/10/21	V	0.00	V	0.00	V	0.00	V	0.09	V	1.74	V	0.67
09/10/21	V	0.00	V	0.00	V	0.00	V	0.12	V	0.41	V	0.67
10/10/21	V	0.00	V	0.00	V	0.00	V	0.10	V	0.14	V	0.68
11/10/21	V	0.00	V	0.00	V	0.10	V	0.09	V	0.87	V	0.61
12/10/21	V	0.00	V	0.00	V	0.30	V	0.09	V	2.48	V	0.44
13/10/21	V	0.00	V	0.00	V	0.36	V	0.09	V	1.44	V	0.40
14/10/21	V	0.00	V	0.00	V	0.36	V	0.10	V	0.96	V	0.42
15/10/21	V	0.00	V	0.00	V	0.34	V	0.13	V	1.54	V	0.37
16/10/21	V	0.06	V	0.00	V	0.39	V	0.14	V	2.32	V	0.34
17/10/21	V	0.00	V	0.00	V	0.41	V	0.14	V	1.73	V	0.32
18/10/21	V	0.00	V	0.00	V	0.42	V	0.13	V	2.61	V	0.34
19/10/21	V	0.00	V	0.00	V	0.38	V	0.14	V	2.59	V	0.32
20/10/21	V	0.00	V	0.00	V	0.36	V	0.15	V	1.30	V	0.39
21/10/21	V	0.00	V	0.00	V	0.44	V	0.13	V	2.45	V	0.33
22/10/21	V	0.00	V	0.00	V	0.46	V	0.13	V	4.11	V	0.37
23/10/21	V	0.00	V	0.00	V	0.43	V	0.14	V	3.35	V	0.33
24/10/21	V	0.00	V	0.00	V	0.38	V	0.12	V	1.88	V	0.34
25/10/21	V	0.00	V	0.00	V	0.38	V	0.13	V	1.67	V	0.38
26/10/21	V	0.00	V	0.00	V	0.39	V	0.13	V	1.72	V	0.37
27/10/21	V	0.00	V	0.00	V	0.40	V	0.15	V	3.20	V	0.35
28/10/21	V	0.00	V	0.00	V	0.42	V	0.09	V	1.84	V	0.34
29/10/21	V	0.00	V	0.00	V	0.48	V	0.11	V	4.57	V	0.31
30/10/21	V	0.00	V	0.00	V	0.48	V	0.11	V	4.42	V	0.34
31/10/21	V	0.00	V	0.00	V	0.46	V	0.11	V	3.35	V	0.36
MAV		0.00		0.00		0.26		0.11		1.78		0.45

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Oct/ 2021

Date of creation: 01/11/2021 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
01/10/21	V	91.55	V	9.63	V	3.24	V	37.85	V	1014.69	V	168045.13
02/10/21	V	86.82	V	9.55	V	2.78	V	36.89	V	1010.76	V	168163.94
03/10/21	V	91.61	V	9.39	V	3.39	V	38.45	V	1007.88	V	164765.40
04/10/21	V	86.69	V	9.46	V	3.29	V	38.42	V	1008.68	V	166209.78
05/10/21	V	92.44	V	9.44	V	2.90	V	37.47	V	1009.77	V	164179.05
06/10/21	V	78.30	V	9.39	V	3.00	V	38.02	V	1011.26	V	164500.09
07/10/21	V	86.50	V	9.43	V	3.08	V	38.70	V	1019.70	V	165669.87
08/10/21	V	89.51	V	9.61	V	2.44	V	37.00	V	1024.59	V	166356.83
09/10/21	V	98.14	V	9.45	V	2.81	V	38.13	V	1023.99	V	165941.82
10/10/21	V	98.12	V	9.37	V	3.02	V	38.63	V	1019.09	V	165337.81
11/10/21	V	91.59	V	9.44	V	3.53	V	38.07	V	1007.59	V	163452.45
12/10/21	V	99.06	V	9.53	V	5.88	V	38.84	V	996.47	V	158734.06
13/10/21	V	99.74	V	9.58	V	7.10	V	39.63	V	998.86	V	155167.22
14/10/21	V	97.28	V	9.59	V	6.45	V	37.86	V	1003.41	V	156885.72
15/10/21	V	104.43	V	9.58	V	6.35	V	36.96	V	995.29	V	156284.32
16/10/21	V	102.89	V	9.59	V	7.56	V	40.54	V	998.36	V	156485.90
17/10/21	V	102.58	V	9.56	V	7.47	V	40.55	V	1000.72	V	156328.12
18/10/21	V	104.93	V	9.58	V	7.40	V	40.67	V	1004.41	V	156241.72
19/10/21	V	119.71	V	9.72	V	7.13	V	40.36	V	1009.49	V	157678.69
20/10/21	V	98.16	V	9.53	V	7.73	V	40.67	V	993.13	V	154945.86
21/10/21	V	73.41	V	9.51	V	9.43	V	43.81	V	979.64	V	153901.04
22/10/21	V	67.54	V	9.55	V	8.22	V	41.77	V	983.37	V	154721.76
23/10/21	V	67.91	V	9.38	V	7.63	V	40.92	V	994.96	V	155228.93
24/10/21	V	73.66	V	9.64	V	7.29	V	40.84	V	1013.65	V	158379.54
25/10/21	V	84.83	V	9.51	V	6.74	V	39.35	V	1012.44	V	157284.76
26/10/21	V	83.41	V	9.56	V	6.18	V	37.27	V	1004.23	V	157175.49
27/10/21	V	87.83	V	9.51	V	6.77	V	38.32	V	1003.35	V	156220.44
28/10/21	V	89.68	V	9.91	V	7.02	V	38.90	V	1006.25	V	160565.96
29/10/21	V	95.15	V	9.92	V	8.29	V	41.72	V	1007.74	V	162105.25
30/10/21	V	89.20	V	9.94	V	6.41	V	37.49	V	1004.87	V	161893.60
31/10/21	V	89.06	V	9.88	V	6.75	V	38.54	V	1002.22	V	161775.84
MAV		91.03		9.57		5.72		39.12		1005.50		160336.52

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Oct/ 2021

Date of creation: 01/11/2021 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/10/21	V	1028.65				
02/10/21	V	1013.68				
03/10/21	V	1014.34				
04/10/21	V	1018.91				
05/10/21	V	1025.03				
06/10/21	V	1019.63				
07/10/21	V	1019.85				
08/10/21	V	1012.57				
09/10/21	V	1015.26				
10/10/21	V	1019.56				
11/10/21	V	1009.67				
12/10/21	V	1004.65				
13/10/21	V	1005.16				
14/10/21	V	1011.38				
15/10/21	V	1007.76				
16/10/21	V	999.70				
17/10/21	V	1005.62				
18/10/21	V	1003.14				
19/10/21	V	992.46				
20/10/21	V	1009.04				
21/10/21	V	1017.10				
22/10/21	V	994.35				
23/10/21	V	996.20				
24/10/21	V	1012.78				
25/10/21	V	1009.87				
26/10/21	V	997.70				
27/10/21	V	1005.47				
28/10/21	V	1002.92				
29/10/21	V	1000.13				
30/10/21	V	993.19				
31/10/21	V	1010.76				
MAV		1008.92				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value