

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2021

Date of creation: 01/01/2022 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/12/21	V	0.00	V	0.01	V	0.27	V	0.10	V	4.05	V	0.36
02/12/21	V	0.00	V	0.00	V	0.27	V	0.11	V	2.97	V	0.28
03/12/21	V	0.00	V	0.00	V	0.28	V	0.15	V	4.16	V	0.26
04/12/21	V	0.00	V	0.00	V	0.27	V	0.10	V	4.23	V	0.32
05/12/21	V	0.00	V	0.00	V	0.28	V	0.13	V	2.58	V	0.29
06/12/21	V	0.05	V	0.00	V	8.00	V	0.19	V	1.03	V	0.30
07/12/21	V	0.67	V	0.00	V	7.63	V	0.16	V	0.12	V	0.30
08/12/21	V	0.20	V	0.00	V	8.34	V	0.17	V	0.26	V	0.31
09/12/21	V	0.73	V	0.00	V	4.61	V	0.17	V	0.08	V	0.32
10/12/21	V	0.00	V	0.00	V	0.22	V	0.10	V	1.75	V	0.39
11/12/21	V	0.02	V	0.01	V	0.25	V	0.15	V	2.85	V	0.41
12/12/21	V	0.00	V	0.00	V	0.24	V	0.12	V	2.17	V	0.43
13/12/21	V	0.00	V	0.00	V	0.24	V	0.11	V	2.66	V	0.46
14/12/21	V	0.00	V	0.00	V	0.21	V	0.14	V	2.35	V	0.35
15/12/21	V	0.01	V	0.01	V	0.22	V	0.15	V	4.04	V	0.35
16/12/21	V	0.00	V	0.01	V	0.32	V	0.16	V	2.34	V	0.41
17/12/21	V	0.00	V	0.00	V	0.31	V	0.19	V	2.88	V	0.35
18/12/21	V	0.00	V	0.01	V	0.30	V	0.19	V	6.58	V	0.39
19/12/21	V	0.00	V	0.01	V	0.32	V	0.17	V	4.81	V	0.35
20/12/21	V	0.00	V	0.00	V	0.26	V	0.17	V	5.35	V	0.31
21/12/21	V	0.00	V	0.00	V	0.25	V	0.20	V	8.74	V	0.32
22/12/21	V	0.00	V	0.00	V	0.26	V	0.15	V	1.96	V	0.28
23/12/21	V	0.00	V	0.00	V	0.23	V	0.15	V	2.42	V	0.26
24/12/21	V	0.00	V	0.00	V	0.22	V	0.16	V	2.33	V	0.29
25/12/21	V	0.00	V	0.00	V	0.24	V	0.15	V	3.75	V	0.29
26/12/21	V	0.00	V	0.00	V	0.24	V	0.15	V	2.77	V	0.33
27/12/21	V	0.00	V	0.00	V	0.23	V	0.17	V	2.64	V	0.32
28/12/21	V	0.00	V	0.00	V	0.24	V	0.17	V	1.09	V	0.29
29/12/21	V	0.00	V	0.00	V	0.24	V	0.16	V	0.85	V	0.21
30/12/21	V	0.00	V	0.01	V	0.22	V	0.17	V	1.06	V	0.30
31/12/21	V	0.04	V	0.01	V	0.26	V	0.14	V	2.59	V	0.30
MAV		0.06		0.00		1.14		0.15		2.82		0.33

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2021

Date of creation: 01/01/2022 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/12/21	V	84.73	V	9.56	V	6.61	V	38.50	V	981.69	V	147079.99
02/12/21	V	82.45	V	9.73	V	6.44	V	37.62	V	972.05	V	146195.40
03/12/21	V	91.28	V	9.80	V	6.26	V	37.42	V	983.86	V	148200.11
04/12/21	V	84.71	V	9.73	V	6.28	V	37.82	V	990.43	V	149045.50
05/12/21	V	77.28	V	9.73	V	6.25	V	37.83	V	995.90	V	149583.50
06/12/21	V	82.33	V	9.76	V	12.07	V	50.52	V	1000.91	V	161276.45
07/12/21	V	85.83	V	9.88	V	16.28	V	58.38	V	1003.93	V	169069.13
08/12/21	V	81.60	V	9.84	V	16.22	V	58.43	V	1006.40	V	169019.03
09/12/21	V	80.23	V	10.08	V	15.07	V	56.34	V	1003.62	V	167504.80
10/12/21	V	88.49	V	10.03	V	8.63	V	43.63	V	995.87	V	161250.94
11/12/21	V	80.01	V	10.08	V	8.44	V	42.95	V	999.24	V	161064.93
12/12/21	V	84.68	V	9.81	V	8.22	V	43.00	V	1008.69	V	160088.67
13/12/21	V	81.92	V	9.77	V	8.42	V	43.64	V	1012.36	V	159780.21
14/12/21	V	77.15	V	9.71	V	8.29	V	43.71	V	1010.20	V	163711.57
15/12/21	V	79.37	V	9.32	V	6.85	V	38.63	V	1008.33	V	162810.80
16/12/21	V	88.81	V	9.63	V	4.87	V	33.05	V	1004.73	V	159361.86
17/12/21	V	91.51	V	9.58	V	4.73	V	32.97	V	1008.34	V	159670.15
18/12/21	V	91.06	V	9.55	V	5.03	V	33.94	V	1007.05	V	159164.23
19/12/21	V	94.58	V	9.59	V	4.95	V	33.32	V	989.27	V	158864.60
20/12/21	V	91.39	V	10.11	V	5.16	V	35.32	V	996.56	V	166974.82
21/12/21	V	92.09	V	10.35	V	6.92	V	40.29	V	1005.04	V	169399.27
22/12/21	V	87.77	V	10.31	V	7.19	V	41.15	V	1010.87	V	167746.44
23/12/21	V	104.65	V	9.77	V	6.75	V	39.80	V	1000.49	V	161392.62
24/12/21	V	93.40	V	9.43	V	5.99	V	37.17	V	979.72	V	157081.45
25/12/21	V	77.14	V	9.38	V	6.36	V	38.09	V	986.73	V	157324.59
26/12/21	V	92.08	V	9.52	V	6.06	V	37.29	V	994.46	V	158851.09
27/12/21	V	91.47	V	9.60	V	5.95	V	37.54	V	1004.28	V	161032.03
28/12/21	V	91.18	V	9.65	V	6.49	V	39.22	V	1003.58	V	159460.19
29/12/21	V	87.43	V	9.64	V	6.25	V	38.48	V	997.89	V	155285.76
30/12/21	V	96.84	V	9.63	V	5.34	V	35.45	V	997.01	V	154797.57
31/12/21	V	93.39	V	9.62	V	4.79	V	32.63	V	991.42	V	154578.34
MAV		87.32		9.75		7.52		40.45		998.41		159245.93

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Dec/ 2021

Date of creation: 01/01/2022 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/12/21	V	995.49				
02/12/21	V	985.81				
03/12/21	V	969.95				
04/12/21	V	984.70				
05/12/21	V	1000.32				
06/12/21	V	994.12				
07/12/21	V	1002.54				
08/12/21	V	1033.71				
09/12/21	V	1038.14				
10/12/21	V	1005.03				
11/12/21	V	1001.99				
12/12/21	V	1025.26				
13/12/21	V	1013.97				
14/12/21	V	1001.38				
15/12/21	V	1017.24				
16/12/21	V	1047.69				
17/12/21	V	1016.88				
18/12/21	V	1000.99				
19/12/21	V	1004.00				
20/12/21	V	997.32				
21/12/21	V	1005.78				
22/12/21	V	1011.39				
23/12/21	V	1012.07				
24/12/21	V	1009.34				
25/12/21	V	1004.97				
26/12/21	V	1023.04				
27/12/21	V	1026.82				
28/12/21	V	1023.14				
29/12/21	V	1019.03				
30/12/21	V	1030.54				
31/12/21	V	1013.31				
MAV		1010.20				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value