

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2022

Date of creation: 20/01/2022 04:31

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/01/22	V	0.00	V	0.00	V	0.27	V	0.17	V	2.20	V	0.38
02/01/22	V	0.00	V	0.04	V	0.23	V	0.18	V	1.99	V	0.33
03/01/22	V	0.03	V	0.00	V	0.29	V	0.17	V	1.42	V	0.39
04/01/22	V	0.00	V	0.00	V	0.30	V	0.17	V	3.54	V	0.36
05/01/22	V	0.00	V	0.00	V	0.31	V	0.19	V	4.84	V	0.36
06/01/22	V	0.00	V	0.01	V	0.28	V	0.17	V	5.48	V	0.36
07/01/22	V	0.00	V	0.03	V	0.24	V	0.19	V	5.60	V	0.34
08/01/22	V	0.00	V	0.01	V	0.23	V	0.16	V	2.99	V	0.35
09/01/22	V	0.00	V	0.08	V	0.23	V	0.15	V	2.55	V	0.35
10/01/22	V	0.00	V	0.02	V	0.24	V	0.17	V	3.57	V	0.31
11/01/22	V	0.00	V	0.00	V	0.25	V	0.18	V	4.02	V	0.24
12/01/22	V	0.00	V	0.01	V	0.23	V	0.19	V	2.27	V	0.21
13/01/22	V	0.00	V	0.00	V	0.26	V	0.19	V	1.50	V	0.36
14/01/22	V	0.00	V	0.04	V	0.32	V	0.17	V	3.61	V	0.34
15/01/22	V	0.00	V	0.03	V	0.31	V	0.19	V	4.00	V	0.35
16/01/22	V	0.00	V	0.03	V	0.27	V	0.17	V	2.67	V	0.33
17/01/22	V	0.00	V	0.04	V	0.26	V	0.18	V	5.56	V	0.37
18/01/22	V	0.00	V	0.17	V	0.26	V	0.16	V	6.07	V	0.35
19/01/22	V	0.00	V	0.04	V	0.28	V	0.17	V	2.65	V	0.34
MAV		0.00		0.03		0.27		0.18		3.50		0.34

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2022

Date of creation: 20/01/2022 04:31

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
01/01/22	V	98.12	V	9.50	V	4.83	V	32.93	V	998.28	V	157872.79
02/01/22	V	95.27	V	9.54	V	4.69	V	32.97	V	998.24	V	158054.21
03/01/22	V	85.56	V	9.33	V	4.83	V	32.25	V	982.37	V	155929.47
04/01/22	V	73.91	V	9.35	V	4.79	V	32.26	V	981.88	V	157044.57
05/01/22	V	74.68	V	9.28	V	4.65	V	32.15	V	978.59	V	155091.20
06/01/22	V	74.87	V	9.61	V	4.75	V	32.88	V	986.06	V	153316.93
07/01/22	V	73.98	V	9.73	V	5.12	V	34.61	V	999.09	V	155723.16
08/01/22	V	76.97	V	9.66	V	4.88	V	33.96	V	997.80	V	154902.09
09/01/22	V	77.27	V	9.46	V	4.93	V	33.92	V	995.14	V	153998.27
10/01/22	V	83.29	V	9.55	V	4.84	V	34.25	V	1008.03	V	157746.15
11/01/22	V	79.79	V	9.62	V	5.61	V	36.89	V	1020.68	V	160080.21
12/01/22	V	77.99	V	9.69	V	5.95	V	37.81	V	1018.60	V	160490.55
13/01/22	V	74.05	V	9.78	V	4.87	V	33.36	V	1002.61	V	154050.68
14/01/22	V	82.70	V	9.88	V	4.22	V	31.03	V	990.54	V	149188.31
15/01/22	V	83.50	V	9.94	V	4.17	V	31.54	V	1001.73	V	148766.52
16/01/22	V	72.04	V	9.93	V	4.42	V	32.33	V	1000.25	V	148238.40
17/01/22	V	75.40	V	9.88	V	4.65	V	32.41	V	982.96	V	146634.74
18/01/22	V	82.87	V	9.98	V	4.53	V	33.00	V	1008.18	V	151471.82
19/01/22	V	74.25	V	9.88	V	4.64	V	32.81	V	1002.19	V	151013.08
MAV		79.82		9.66		4.81		33.34		997.54		154190.17

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Jan/ 2022

Date of creation: 20/01/2022 04:31

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/01/22	V	1008.69				
02/01/22	V	1027.56				
03/01/22	V	1024.46				
04/01/22	V	994.99				
05/01/22	V	971.80				
06/01/22	V	982.51				
07/01/22	V	974.77				
08/01/22	V	975.08				
09/01/22	V	996.14				
10/01/22	V	997.07				
11/01/22	V	987.55				
12/01/22	V	999.74				
13/01/22	V	1010.11				
14/01/22	V	981.19				
15/01/22	V	973.58				
16/01/22	V	994.42				
17/01/22	V	975.33				
18/01/22	V	971.86				
19/01/22	V	983.36				
MAV		991.06				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value