

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Feb/ 2022

Date of creation: 01/03/2022 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/02/22	V	0.00	V	0.00	V	0.26	V	0.23	V	4.54	V	0.30
02/02/22	V	0.00	V	0.01	V	0.25	V	0.22	V	2.79	V	0.30
03/02/22	V	0.00	V	0.00	V	0.26	V	0.22	V	2.04	V	0.32
04/02/22	V	0.00	V	0.01	V	0.25	V	0.20	V	5.87	V	0.35
05/02/22	V	0.00	V	0.00	V	0.26	V	0.21	V	7.85	V	0.41
06/02/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/02/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/02/22	V	0.00	V	0.00	V	0.31	V	0.24	V	2.97	V	0.41
09/02/22	V	0.00	V	0.00	V	0.32	V	0.22	V	5.34	V	0.41
10/02/22	V	0.00	V	0.01	V	0.34	V	0.18	V	8.83	V	0.40
11/02/22	V	0.00	V	0.00	V	0.32	V	0.21	V	3.47	V	0.44
12/02/22	V	0.00	V	0.03	V	0.30	V	0.20	V	3.89	V	0.39
13/02/22	V	0.00	V	0.05	V	0.29	V	0.18	V	8.05	V	0.37
14/02/22	V	0.00	V	0.03	V	0.30	V	0.18	V	8.91	V	0.38
15/02/22	V	0.00	V	0.19	V	0.29	V	0.19	V	8.40	V	0.33
16/02/22	V	0.00	V	0.10	V	0.31	V	0.18	V	3.59	V	0.37
17/02/22	V	0.00	V	0.00	V	0.34	V	0.19	V	3.78	V	0.33
18/02/22	V	0.00	V	0.00	V	0.34	V	0.21	V	4.55	V	0.35
19/02/22	V	0.01	V	0.00	V	0.33	V	0.20	V	5.99	V	0.34
20/02/22	V	0.00	V	0.00	V	0.31	V	0.19	V	2.19	V	0.33
21/02/22	V	0.00	V	0.00	V	0.33	V	0.17	V	4.00	V	0.33
22/02/22	V	0.00	V	0.02	V	0.31	V	0.20	V	3.34	V	0.35
23/02/22	V	0.00	V	0.03	V	0.30	V	0.20	V	3.04	V	0.32
24/02/22	V	0.00	V	0.06	V	0.28	V	0.19	V	2.29	V	0.31
25/02/22	V	0.05	V	0.05	V	0.31	V	0.16	V	2.81	V	0.37
26/02/22	V	0.00	V	0.01	V	0.32	V	0.15	V	3.53	V	0.37
27/02/22	V	0.00	V	0.14	V	0.26	V	0.14	V	3.73	V	0.32
28/02/22	V	0.00	V	0.06	V	0.28	V	0.17	V	4.40	V	0.41
MAV		0.00		0.03		0.30		0.19		4.56		0.36

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Feb/ 2022

Date of creation: 01/03/2022 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/02/22	V	74.84	V	9.72	V	5.28	V	34.93	V	985.98	V	149543.38
02/02/22	V	75.85	V	9.72	V	5.16	V	34.20	V	984.07	V	146058.11
03/02/22	V	82.39	V	9.99	V	6.15	V	37.44	V	999.84	V	146385.91
04/02/22	V	69.07	V	10.39	V	5.29	V	35.21	V	997.18	V	141167.28
05/02/22	V	60.81	V	10.05	V	10.94	V	48.18	V	988.95	V	140455.54
06/02/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/02/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
08/02/22	V	84.00	V	9.84	V	11.69	V	47.80	V	993.10	V	148726.13
09/02/22	V	90.36	V	9.90	V	5.35	V	34.76	V	998.32	V	155038.87
10/02/22	V	76.83	V	9.65	V	4.92	V	33.58	V	998.59	V	156578.38
11/02/22	V	76.93	V	9.85	V	4.67	V	32.88	V	999.59	V	156659.05
12/02/22	V	72.14	V	9.83	V	4.83	V	34.04	V	1011.54	V	158625.48
13/02/22	V	76.65	V	10.16	V	4.93	V	34.36	V	1007.23	V	163076.58
14/02/22	V	70.39	V	10.05	V	4.85	V	33.78	V	998.99	V	162152.85
15/02/22	V	76.30	V	9.91	V	4.73	V	33.06	V	997.44	V	156997.86
16/02/22	V	87.21	V	9.85	V	4.91	V	33.05	V	988.93	V	155232.93
17/02/22	V	86.12	V	9.78	V	5.08	V	32.84	V	964.62	V	152711.90
18/02/22	V	81.01	V	9.69	V	4.98	V	33.27	V	980.08	V	153626.64
19/02/22	V	85.51	V	9.69	V	4.88	V	32.77	V	975.07	V	152922.10
20/02/22	V	92.11	V	9.62	V	4.81	V	32.97	V	988.44	V	153717.12
21/02/22	V	81.11	V	9.58	V	5.30	V	33.90	V	974.97	V	152243.80
22/02/22	V	92.75	V	9.66	V	4.89	V	33.20	V	982.97	V	153421.04
23/02/22	V	87.77	V	9.73	V	4.89	V	33.58	V	996.14	V	154891.57
24/02/22	V	94.63	V	9.72	V	4.64	V	32.84	V	1003.57	V	154463.07
25/02/22	V	98.38	V	9.77	V	4.78	V	33.05	V	995.87	V	152881.74
26/02/22	V	93.50	V	9.48	V	4.52	V	32.73	V	1012.37	V	151676.95
27/02/22	V	94.99	V	9.58	V	4.52	V	33.39	V	1023.73	V	152887.64
28/02/22	V	86.89	V	9.71	V	4.59	V	33.79	V	1024.33	V	154684.35
MAV		83.27		9.80		5.15		34.16		995.30		153419.05

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Feb/ 2022

Date of creation: 01/03/2022 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/02/22	V	1006.14				
02/02/22	V	1018.58				
03/02/22	V	1014.44				
04/02/22	V	990.23				
05/02/22	V	993.24				
06/02/22	N	0.00				
07/02/22	N	0.00				
08/02/22	V	996.58				
09/02/22	V	1001.52				
10/02/22	V	1010.65				
11/02/22	V	1006.39				
12/02/22	V	1008.79				
13/02/22	V	1017.32				
14/02/22	V	1003.23				
15/02/22	V	997.20				
16/02/22	V	1002.98				
17/02/22	V	1018.36				
18/02/22	V	1009.63				
19/02/22	V	1001.72				
20/02/22	V	1020.24				
21/02/22	V	1017.77				
22/02/22	V	1010.94				
23/02/22	V	1018.64				
24/02/22	V	1028.64				
25/02/22	V	1020.31				
26/02/22	V	1004.65				
27/02/22	V	1020.39				
28/02/22	V	1008.85				
MAV		1010.28				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value