

# Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2022

Date of creation: 01/04/2022 04:31

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/03/22	V	0.00	V	0.06	V	0.30	V	0.16	V	3.29	V	0.32
02/03/22	V	0.00	V	0.01	V	0.31	V	0.18	V	3.34	V	0.35
03/03/22	V	0.00	V	0.05	V	0.30	V	0.17	V	2.27	V	0.38
04/03/22	V	0.00	V	0.07	V	0.30	V	0.15	V	2.64	V	0.37
05/03/22	V	0.00	V	0.00	V	0.31	V	0.15	V	2.70	V	0.32
06/03/22	V	0.01	V	0.00	V	0.29	V	0.20	V	1.57	V	0.39
07/03/22	V	0.00	V	0.03	V	0.29	V	0.18	V	2.87	V	0.36
08/03/22	M	0.00	V	0.06	V	0.30	V	0.16	V	1.63	V	0.38
09/03/22	V	0.54	V	0.03	V	0.31	V	0.17	V	3.76	V	0.32
10/03/22	V	0.34	V	0.02	V	0.31	V	0.22	V	2.44	V	0.32
11/03/22	V	0.34	V	0.01	V	0.32	V	0.21	V	2.33	V	0.37
12/03/22	V	0.34	V	0.03	V	0.35	V	0.18	V	2.29	V	0.39
13/03/22	V	0.33	V	0.02	V	0.33	V	0.20	V	1.38	V	0.37
14/03/22	V	0.33	V	0.08	V	0.34	V	0.18	V	2.65	V	0.37
15/03/22	V	0.35	V	0.03	V	0.38	V	0.16	V	2.02	V	0.38
16/03/22	V	0.34	V	0.11	V	0.42	V	0.17	V	2.69	V	0.44
17/03/22	V	0.34	V	0.00	V	0.42	V	0.15	V	1.75	V	0.29
18/03/22	V	0.34	V	0.03	V	0.41	V	0.17	V	1.99	V	0.30
19/03/22	V	0.34	V	0.00	V	0.40	V	0.19	V	1.18	V	0.35
20/03/22	V	0.34	V	0.00	V	0.40	V	0.19	V	1.11	V	0.34
21/03/22	V	0.35	V	0.02	V	0.42	V	0.18	V	2.14	V	0.43
22/03/22	V	0.35	V	0.06	V	0.42	V	0.16	V	1.41	V	0.39
23/03/22	V	0.00	V	0.05	V	0.48	V	0.16	V	0.84	V	0.36
24/03/22	V	0.00	V	0.07	V	0.41	V	0.16	V	0.89	V	0.40
25/03/22	V	0.00	V	0.11	V	0.44	V	0.16	V	1.29	V	0.42
26/03/22	V	0.00	V	0.10	V	0.49	V	0.13	V	1.94	V	0.33
27/03/22	V	0.00	V	0.07	V	0.37	V	0.16	V	1.10	V	0.30
28/03/22	M	0.33	V	0.21	V	0.42	V	0.17	V	2.05	V	0.58
29/03/22	V	0.67	V	0.00	V	0.43	V	0.17	V	1.96	V	0.49
30/03/22	V	0.66	V	0.00	V	0.37	V	0.19	V	1.91	V	0.28
31/03/22	V	0.65	V	0.00	V	0.38	V	0.19	V	2.77	V	0.28
MAV		0.24		0.04		0.37		0.17		2.07		0.37

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2022

Date of creation: 01/04/2022 04:31

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
01/03/22	V	92.30	V	9.79	V	4.59	V	33.84	V	1020.66	V	155836.07
02/03/22	V	90.96	V	9.83	V	4.60	V	33.41	V	1011.28	V	155204.17
03/03/22	V	84.66	V	10.01	V	4.68	V	33.28	V	1002.81	V	154371.36
04/03/22	V	89.37	V	9.99	V	4.50	V	32.67	V	1006.25	V	151524.51
05/03/22	V	85.60	V	10.00	V	4.52	V	33.23	V	1010.62	V	152232.85
06/03/22	V	89.74	V	9.70	V	4.87	V	34.28	V	1007.44	V	150872.14
07/03/22	V	80.80	V	9.98	V	4.84	V	33.83	V	1003.65	V	152454.05
08/03/22	V	90.69	V	10.32	V	4.73	V	33.64	V	1007.77	V	155718.41
09/03/22	V	93.84	V	10.52	V	4.90	V	34.37	V	1011.72	V	157828.84
10/03/22	V	99.00	V	10.45	V	4.99	V	35.57	V	1024.61	V	157727.34
11/03/22	V	103.29	V	10.39	V	4.99	V	35.54	V	1023.51	V	158427.13
12/03/22	V	95.06	V	10.19	V	4.75	V	34.40	V	1016.51	V	156803.38
13/03/22	V	89.43	V	9.90	V	4.73	V	34.10	V	1016.77	V	157909.86
14/03/22	V	81.90	V	9.84	V	4.91	V	34.53	V	1019.83	V	152609.20
15/03/22	V	82.01	V	10.04	V	8.10	V	41.29	V	1016.10	V	152040.00
16/03/22	V	82.88	V	10.04	V	6.32	V	37.31	V	1016.55	V	152845.50
17/03/22	V	90.50	V	10.25	V	4.36	V	33.02	V	1025.37	V	154458.09
18/03/22	V	91.16	V	10.16	V	5.09	V	35.40	V	1029.61	V	154371.05
19/03/22	V	84.83	V	10.03	V	6.17	V	38.52	V	1031.72	V	152955.31
20/03/22	V	90.67	V	10.16	V	6.14	V	38.14	V	1032.10	V	154170.76
21/03/22	V	78.78	V	10.17	V	7.23	V	40.60	V	1027.92	V	154532.87
22/03/22	V	94.65	V	10.04	V	7.11	V	39.89	V	1024.10	V	155751.53
23/03/22	V	92.61	V	9.90	V	8.02	V	41.00	V	1014.68	V	156419.67
24/03/22	V	93.52	V	9.68	V	5.91	V	36.47	V	1011.16	V	155879.47
25/03/22	V	91.38	V	9.78	V	7.94	V	40.69	V	1008.15	V	155569.72
26/03/22	V	83.23	V	9.95	V	4.94	V	33.66	V	1000.53	V	156126.38
27/03/22	V	84.86	V	9.97	V	4.51	V	33.39	V	1011.74	V	158785.98
28/03/22	V	81.73	V	9.82	V	6.67	V	37.69	V	995.47	V	157013.52
29/03/22	V	78.24	V	9.77	V	6.33	V	37.23	V	990.41	V	161346.73
30/03/22	V	81.60	V	9.79	V	5.65	V	35.99	V	993.33	V	161850.81
31/03/22	V	84.46	V	9.66	V	5.34	V	35.71	V	995.96	V	162911.32
MAV		88.19		10.00		5.56		35.90		1013.17		155690.94

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Mar/ 2022

Date of creation: 01/04/2022 04:31

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/03/22	V	997.28				
02/03/22	V	1011.71				
03/03/22	V	1022.05				
04/03/22	V	1002.94				
05/03/22	V	1005.02				
06/03/22	V	1026.28				
07/03/22	V	1008.32				
08/03/22	V	1003.84				
09/03/22	V	1011.05				
10/03/22	V	1014.94				
11/03/22	V	1011.04				
12/03/22	V	1018.64				
13/03/22	V	1037.73				
14/03/22	V	1010.43				
15/03/22	V	991.61				
16/03/22	V	1003.03				
17/03/22	V	1004.86				
18/03/22	V	997.29				
19/03/22	V	1003.83				
20/03/22	V	1021.75				
21/03/22	V	1011.77				
22/03/22	V	1010.45				
23/03/22	V	1027.82				
24/03/22	V	1049.20				
25/03/22	V	1033.49				
26/03/22	V	1025.91				
27/03/22	V	1049.93				
28/03/22	V	1050.10				
29/03/22	V	1025.75				
30/03/22	V	1016.69				
31/03/22	V	1023.97				
MAV		1017.01				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value