

# Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2022

Date of creation: 01/05/2022 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/04/22	V	0.65	V	0.01	V	0.37	V	0.20	V	1.47	V	0.29
02/04/22	V	0.65	V	0.01	V	0.36	V	0.16	V	1.45	V	0.26
03/04/22	V	0.65	V	0.00	V	0.34	V	0.17	V	0.84	V	0.28
04/04/22	V	0.64	V	0.00	V	0.33	V	0.16	V	2.43	V	0.34
05/04/22	V	0.65	V	0.00	V	0.35	V	0.18	V	1.56	V	0.35
06/04/22	V	0.65	V	0.00	V	0.36	V	0.17	V	1.76	V	0.34
07/04/22	V	0.66	V	0.00	V	0.44	V	0.14	V	3.65	V	0.33
08/04/22	V	0.66	V	0.02	V	0.48	V	0.16	V	3.35	V	0.33
09/04/22	V	0.65	V	0.01	V	0.45	V	0.14	V	1.90	V	0.31
10/04/22	V	0.65	V	0.02	V	0.40	V	0.14	V	1.98	V	0.42
11/04/22	V	0.66	V	0.04	V	0.39	V	0.14	V	2.85	V	0.39
12/04/22	V	0.66	V	0.07	V	0.40	V	0.16	V	2.78	V	0.38
13/04/22	V	0.66	V	0.03	V	0.41	V	0.18	V	2.67	V	0.37
14/04/22	V	0.65	V	0.02	V	0.47	V	0.18	V	2.43	V	0.33
15/04/22	V	0.67	V	0.01	V	0.51	V	0.16	V	3.61	V	0.29
16/04/22	V	0.67	V	0.03	V	0.46	V	0.13	V	4.14	V	0.33
17/04/22	V	0.66	V	0.01	V	0.44	V	0.13	V	3.71	V	0.33
18/04/22	V	0.67	V	0.00	V	0.46	V	0.12	V	5.66	V	0.36
19/04/22	V	0.67	V	0.01	V	0.47	V	0.12	V	2.99	V	0.37
20/04/22	V	0.67	V	0.03	V	0.48	V	0.16	V	4.56	V	0.30
21/04/22	V	0.68	V	0.00	V	0.50	V	0.17	V	3.90	V	0.33
22/04/22	V	0.68	V	0.10	V	0.50	V	0.17	V	3.60	V	0.39
23/04/22	V	0.68	V	0.10	V	0.49	V	0.18	V	2.18	V	0.33
24/04/22	V	0.68	V	0.26	V	0.49	V	0.17	V	1.99	V	0.42
25/04/22	V	0.68	V	0.14	V	0.48	V	0.16	V	3.36	V	0.58
26/04/22	V	0.70	V	0.08	V	0.51	V	0.13	V	3.23	V	0.40
27/04/22	V	0.71	V	0.03	V	0.50	V	0.12	V	4.35	V	0.32
28/04/22	V	0.71	V	0.03	V	0.48	V	0.15	V	6.62	V	0.35
29/04/22	V	0.71	V	0.01	V	0.47	V	0.14	V	4.59	V	0.37
30/04/22	V	0.72	V	0.01	V	0.49	V	0.14	V	3.00	V	0.41
MAV		0.67		0.04		0.44		0.15		3.09		0.35

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2022

Date of creation: 01/05/2022 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
01/04/22	V	88.28	V	9.76	V	5.01	V	34.86	V	995.62	V	164614.32
02/04/22	V	102.36	V	9.76	V	4.80	V	33.99	V	992.83	V	165027.52
03/04/22	V	89.51	V	9.69	V	5.06	V	34.81	V	995.65	V	164391.68
04/04/22	V	92.16	V	9.52	V	5.38	V	35.18	V	989.46	V	163918.98
05/04/22	V	86.98	V	9.61	V	5.50	V	34.88	V	976.82	V	163669.41
06/04/22	V	97.90	V	9.61	V	5.60	V	35.47	V	984.35	V	164840.63
07/04/22	V	97.78	V	9.52	V	7.29	V	38.78	V	977.38	V	163204.64
08/04/22	V	97.03	V	9.58	V	7.02	V	38.20	V	972.70	V	162188.24
09/04/22	V	90.13	V	9.60	V	5.83	V	36.03	V	982.17	V	160533.11
10/04/22	V	98.89	V	9.55	V	5.84	V	36.33	V	993.01	V	160814.88
11/04/22	V	96.60	V	9.71	V	5.71	V	36.42	V	1000.96	V	162597.84
12/04/22	V	76.02	V	9.75	V	5.60	V	36.13	V	1006.96	V	163438.27
13/04/22	V	83.83	V	9.78	V	5.52	V	35.94	V	1010.48	V	163954.37
14/04/22	V	90.72	V	9.58	V	5.69	V	36.29	V	1006.19	V	162951.63
15/04/22	V	84.28	V	9.73	V	6.95	V	38.92	V	1003.28	V	162712.34
16/04/22	V	83.45	V	9.95	V	5.95	V	37.38	V	1012.54	V	164755.40
17/04/22	V	87.59	V	9.83	V	5.66	V	36.72	V	1013.32	V	165178.47
18/04/22	V	83.94	V	9.85	V	5.76	V	37.10	V	1006.04	V	164871.20
19/04/22	V	82.53	V	9.82	V	6.06	V	37.26	V	1001.36	V	163052.22
20/04/22	V	83.12	V	9.82	V	6.46	V	37.96	V	998.52	V	163961.30
21/04/22	V	97.00	V	9.86	V	6.51	V	38.08	V	999.27	V	163296.20
22/04/22	V	87.33	V	9.94	V	6.58	V	38.46	V	1002.82	V	165295.88
23/04/22	V	80.73	V	9.85	V	6.78	V	38.26	V	994.94	V	162582.03
24/04/22	V	83.36	V	9.91	V	6.87	V	38.30	V	990.26	V	162855.31
25/04/22	V	80.84	V	9.88	V	7.04	V	38.94	V	993.10	V	163965.44
26/04/22	V	75.70	V	10.01	V	9.06	V	44.22	V	998.92	V	164693.80
27/04/22	V	85.63	V	10.07	V	9.25	V	44.68	V	1008.39	V	163827.47
28/04/22	V	81.19	V	10.27	V	7.29	V	40.80	V	1013.08	V	165522.56
29/04/22	V	79.41	V	10.20	V	8.49	V	43.68	V	1012.95	V	165345.17
30/04/22	V	76.25	V	10.26	V	9.40	V	45.85	V	1012.39	V	165972.40
MAV		87.38		9.81		6.46		37.98		998.19		163799.23

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Apr/ 2022

Date of creation: 01/05/2022 04:30

Date	Degimo T					
	Unit:	°C				
	DLV:	850.00				
01/04/22	V	1014.89				
02/04/22	V	1032.15				
03/04/22	V	1052.76				
04/04/22	V	1035.16				
05/04/22	V	1030.23				
06/04/22	V	1040.27				
07/04/22	V	1024.67				
08/04/22	V	1007.40				
09/04/22	V	1025.09				
10/04/22	V	1039.93				
11/04/22	V	1010.80				
12/04/22	V	1012.77				
13/04/22	V	1012.44				
14/04/22	V	1015.74				
15/04/22	V	1000.51				
16/04/22	V	988.64				
17/04/22	V	1000.02				
18/04/22	V	996.85				
19/04/22	V	1012.94				
20/04/22	V	1030.94				
21/04/22	V	1026.78				
22/04/22	V	1012.86				
23/04/22	V	1016.38				
24/04/22	V	1043.45				
25/04/22	V	1027.43				
26/04/22	V	1000.99				
27/04/22	V	990.84				
28/04/22	V	994.41				
29/04/22	V	1003.22				
30/04/22	V	1015.35				
MAV		1017.23				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value