

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2022

Date of creation: 01/06/2022 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/05/22	V	0.74	V	0.00	V	0.50	V	0.14	V	1.88	V	0.35
02/05/22	V	0.77	V	0.02	V	0.56	V	0.14	V	9.55	V	0.45
03/05/22	V	0.77	V	0.03	V	0.58	V	0.15	V	0.85	V	0.31
04/05/22	V	0.76	V	0.06	V	0.55	V	0.17	V	2.85	V	0.42
05/05/22	V	0.76	V	0.00	V	0.58	V	0.18	V	1.88	V	0.34
06/05/22	V	0.77	V	0.00	V	0.60	V	0.17	V	9.71	V	0.31
07/05/22	V	0.82	V	0.00	V	0.66	V	0.21	V	6.56	V	0.41
08/05/22	V	0.83	V	0.00	V	0.70	V	0.20	V	0.66	V	0.35
09/05/22	V	0.84	V	0.00	V	0.66	V	0.19	V	0.37	V	0.37
10/05/22	V	0.86	V	0.00	V	0.67	V	0.19	V	0.23	V	0.34
11/05/22	V	0.88	V	0.00	V	0.72	V	0.17	V	0.16	V	0.36
12/05/22	V	0.89	V	0.00	V	0.72	V	0.14	V	0.21	V	0.37
13/05/22	V	0.88	V	0.00	V	0.73	V	0.16	V	0.06	V	0.36
14/05/22	V	0.91	V	0.00	V	0.72	V	0.17	V	0.13	V	0.40
15/05/22	V	0.89	V	0.00	V	0.71	V	0.14	V	0.18	V	0.33
16/05/22	V	0.87	V	0.00	V	0.71	V	0.18	V	8.46	V	0.37
17/05/22	V	0.81	V	0.00	V	0.64	V	0.14	V	6.85	V	0.35
18/05/22	V	0.80	V	0.00	V	0.61	V	0.13	V	0.34	V	0.35
19/05/22	V	0.84	V	0.00	V	0.67	V	0.16	V	1.28	V	0.37
20/05/22	V	0.63	V	0.00	V	0.68	V	0.14	V	1.81	V	0.43
21/05/22	V	0.00	V	0.00	V	0.65	V	0.17	V	0.61	V	0.42
22/05/22	V	0.00	V	0.00	V	0.69	V	0.15	V	0.14	V	0.40
23/05/22	V	0.00	V	0.00	V	0.71	V	0.15	V	0.53	V	0.38
24/05/22	V	0.00	V	0.00	V	0.69	V	0.13	V	0.86	V	0.38
25/05/22	V	0.00	V	0.00	V	0.71	V	0.13	V	0.29	V	0.40
26/05/22	V	0.00	V	0.00	V	0.72	V	0.10	V	0.42	V	0.44
27/05/22	V	0.00	V	0.00	V	0.70	V	0.12	V	1.38	V	0.44
28/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
31/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		0.62		0.00		0.66		0.16		2.17		0.38

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2022

Date of creation: 01/06/2022 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/05/22	V	74.56	V	10.15	V	11.71	V	49.99	V	1008.35	V	165361.60
02/05/22	V	74.14	V	10.49	V	12.80	V	51.48	V	1003.48	V	168252.90
03/05/22	V	76.02	V	10.46	V	12.93	V	51.96	V	998.76	V	163492.73
04/05/22	V	72.84	V	10.54	V	11.16	V	49.11	V	1007.94	V	160036.41
05/05/22	V	68.11	V	10.40	V	12.32	V	51.35	V	1009.03	V	155848.00
06/05/22	V	75.72	V	10.42	V	13.44	V	52.82	V	1008.08	V	153029.55
07/05/22	V	71.65	V	10.76	V	15.17	V	55.65	V	1006.41	V	148837.77
08/05/22	V	63.54	V	11.07	V	14.56	V	54.69	V	1008.41	V	151611.99
09/05/22	V	61.73	V	11.20	V	14.11	V	54.76	V	1016.58	V	154340.17
10/05/22	V	69.69	V	11.34	V	14.40	V	55.02	V	1011.17	V	153497.07
11/05/22	V	69.88	V	11.53	V	15.04	V	55.36	V	999.03	V	150267.15
12/05/22	V	67.05	V	11.63	V	15.33	V	55.10	V	992.66	V	146546.60
13/05/22	V	69.47	V	11.68	V	14.18	V	53.75	V	998.23	V	146826.65
14/05/22	V	67.52	V	11.83	V	15.21	V	55.28	V	996.89	V	144315.51
15/05/22	V	64.71	V	11.69	V	14.69	V	54.61	V	1000.32	V	141786.47
16/05/22	V	77.57	V	11.49	V	14.49	V	54.61	V	1004.34	V	147962.85
17/05/22	V	79.28	V	10.80	V	15.04	V	55.97	V	1006.10	V	150288.34
18/05/22	V	73.24	V	10.68	V	15.13	V	56.22	V	1011.73	V	149531.44
19/05/22	V	81.75	V	11.14	V	14.68	V	55.13	V	1008.33	V	149325.16
20/05/22	V	80.18	V	11.16	V	15.16	V	55.14	V	999.59	V	149341.98
21/05/22	V	76.25	V	11.11	V	15.19	V	54.79	V	990.86	V	147651.20
22/05/22	V	79.06	V	11.12	V	15.30	V	55.25	V	992.67	V	148469.25
23/05/22	V	74.40	V	11.35	V	14.88	V	55.08	V	998.27	V	151925.15
24/05/22	V	79.42	V	11.40	V	14.99	V	55.29	V	998.95	V	159320.19
25/05/22	V	74.45	V	11.71	V	15.19	V	55.24	V	998.09	V	153811.02
26/05/22	V	69.97	V	11.97	V	15.44	V	55.43	V	995.61	V	152369.45
27/05/22	V	75.45	V	12.06	V	14.33	V	53.64	V	993.06	V	150831.02
28/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
31/05/22	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		72.83		11.14		14.33		54.18		1002.50		152434.10

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: May/ 2022

Date of creation: 01/06/2022 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/05/22	V	1029.34				
02/05/22	V	1037.04				
03/05/22	V	1020.09				
04/05/22	V	992.69				
05/05/22	V	987.79				
06/05/22	V	983.08				
07/05/22	V	973.52				
08/05/22	V	992.45				
09/05/22	V	1008.33				
10/05/22	V	1031.88				
11/05/22	V	1027.90				
12/05/22	V	1033.25				
13/05/22	V	1033.60				
14/05/22	V	1033.04				
15/05/22	V	1033.47				
16/05/22	V	1034.60				
17/05/22	V	1043.90				
18/05/22	V	1043.60				
19/05/22	V	989.01				
20/05/22	V	980.12				
21/05/22	V	1008.48				
22/05/22	V	1016.39				
23/05/22	V	1009.18				
24/05/22	V	1012.02				
25/05/22	V	1020.25				
26/05/22	V	1006.89				
27/05/22	V	999.24				
28/05/22	N	0.00				
29/05/22	N	0.00				
30/05/22	N	0.00				
31/05/22	N	0.00				
MAV		1014.43				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value