

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2022

Date of creation: 01/08/2022 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/07/22	V	0.00	V	0.00	V	0.59	V	0.16	V	0.58	V	0.42
02/07/22	V	0.00	V	0.00	V	0.63	V	0.09	V	11.61	V	0.34
03/07/22	V	0.00	V	0.00	V	0.91	V	0.10	V	8.08	V	0.39
04/07/22	V	0.00	V	0.00	V	0.60	V	0.06	V	5.62	V	0.33
05/07/22	V	0.00	V	0.00	V	0.58	V	0.11	V	6.06	V	0.35
06/07/22	V	0.00	V	0.00	V	0.58	V	0.08	V	1.92	V	0.40
07/07/22	V	0.00	V	0.00	V	0.61	V	0.07	V	1.04	V	0.33
08/07/22	V	0.00	V	0.00	V	0.59	V	0.07	V	7.41	V	0.36
09/07/22	V	0.00	V	0.00	V	0.60	V	0.09	V	0.68	V	0.32
10/07/22	V	0.00	V	0.00	V	0.59	V	0.09	V	0.51	V	0.32
11/07/22	V	0.00	V	0.00	V	0.59	V	0.08	V	2.15	V	0.30
12/07/22	V	0.00	V	0.00	V	0.60	V	0.04	V	1.91	V	0.30
13/07/22	V	0.00	V	0.00	V	0.62	V	0.07	V	0.76	V	0.28
14/07/22	V	0.00	V	0.00	V	0.62	V	0.07	V	1.05	V	0.33
15/07/22	V	0.00	V	0.00	V	0.67	V	0.08	V	2.11	V	0.38
16/07/22	V	0.00	V	0.00	V	0.59	V	0.06	V	0.78	V	0.33
17/07/22	V	0.00	V	0.00	V	0.58	V	0.07	V	1.38	V	0.39
18/07/22	V	0.00	V	0.00	V	0.60	V	0.06	V	1.20	V	0.35
19/07/22	V	0.00	V	0.00	V	0.60	V	0.08	V	2.93	V	0.31
20/07/22	V	0.00	V	0.00	V	0.61	V	0.10	V	1.49	V	0.31
21/07/22	V	0.00	V	0.00	V	0.58	V	0.10	V	0.75	V	0.33
22/07/22	V	0.00	V	0.00	V	0.58	V	0.12	V	3.36	V	0.32
23/07/22	V	0.00	V	0.00	V	0.59	V	0.10	V	3.55	V	0.36
24/07/22	V	0.00	V	0.00	V	0.61	V	0.11	V	1.40	V	0.37
25/07/22	V	0.00	V	0.00	V	0.63	V	0.07	V	1.97	V	0.40
26/07/22	V	0.00	V	0.00	V	0.63	V	0.08	V	3.83	V	0.37
27/07/22	V	0.00	V	0.00	V	0.62	V	0.06	V	3.40	V	0.36
28/07/22	V	0.00	V	0.00	V	0.60	V	0.07	V	0.63	V	0.38
29/07/22	V	0.00	V	0.00	V	0.62	V	0.09	V	0.78	V	0.38
30/07/22	V	0.00	V	0.00	V	0.61	V	0.10	V	0.74	V	0.34
31/07/22	V	0.00	V	0.00	V	0.59	V	0.09	V	1.65	V	0.39
MAV		0.00		0.00		0.61		0.08		2.50		0.35

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2022

Date of creation: 01/08/2022 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/07/22	V	85.35	V	10.08	V	17.76	V	58.32	V	1004.29	V	169524.64
02/07/22	V	107.85	V	9.63	V	17.87	V	58.76	V	1006.17	V	163734.81
03/07/22	V	93.55	V	9.92	V	17.72	V	58.77	V	1007.08	V	168786.19
04/07/22	V	97.35	V	9.62	V	18.01	V	59.06	V	1002.77	V	164916.81
05/07/22	V	92.42	V	9.64	V	17.53	V	58.66	V	1003.87	V	165241.28
06/07/22	V	94.83	V	9.38	V	18.48	V	60.07	V	1002.39	V	165434.67
07/07/22	V	89.83	V	9.58	V	17.53	V	58.79	V	1001.75	V	165457.15
08/07/22	V	94.69	V	9.51	V	17.67	V	58.86	V	1003.96	V	164185.21
09/07/22	V	93.51	V	9.46	V	17.73	V	58.94	V	1001.81	V	163787.93
10/07/22	V	94.74	V	9.34	V	17.88	V	59.10	V	997.21	V	163215.20
11/07/22	V	94.78	V	9.24	V	18.07	V	59.45	V	998.75	V	163314.42
12/07/22	V	95.05	V	9.44	V	17.79	V	58.56	V	992.08	V	161449.32
13/07/22	V	106.56	V	9.36	V	18.30	V	59.34	V	994.05	V	162327.21
14/07/22	V	107.29	V	9.33	V	17.96	V	58.98	V	995.45	V	162507.70
15/07/22	V	94.12	V	9.48	V	17.59	V	58.74	V	996.65	V	163382.74
16/07/22	V	93.63	V	9.30	V	17.85	V	59.29	V	999.70	V	163179.06
17/07/22	V	96.83	V	9.33	V	17.71	V	59.12	V	1004.26	V	163781.04
18/07/22	V	99.10	V	9.41	V	17.64	V	59.02	V	1006.84	V	163573.02
19/07/22	V	92.52	V	9.52	V	18.01	V	59.30	V	1005.07	V	164576.44
20/07/22	V	97.10	V	9.42	V	17.72	V	59.19	V	1006.65	V	164543.65
21/07/22	V	92.83	V	9.49	V	18.23	V	59.77	V	1005.07	V	166511.55
22/07/22	V	100.61	V	9.55	V	18.42	V	59.72	V	1002.13	V	166640.70
23/07/22	V	87.40	V	9.66	V	18.03	V	58.93	V	1001.02	V	165109.92
24/07/22	V	95.30	V	9.51	V	17.91	V	58.86	V	1000.30	V	163194.62
25/07/22	V	100.37	V	9.51	V	17.86	V	59.02	V	1001.73	V	163854.36
26/07/22	V	96.25	V	9.66	V	17.85	V	58.83	V	996.42	V	164798.44
27/07/22	V	91.07	V	9.60	V	17.49	V	58.35	V	998.54	V	163074.90
28/07/22	V	93.28	V	9.53	V	17.26	V	58.35	V	1002.97	V	163360.07
29/07/22	V	96.25	V	9.42	V	17.25	V	58.67	V	1008.10	V	163798.90
30/07/22	V	95.34	V	9.52	V	17.31	V	58.76	V	1006.39	V	165199.59
31/07/22	V	95.02	V	9.57	V	17.23	V	58.37	V	1000.73	V	163222.54
MAV		95.63		9.50		17.79		58.98		1001.62		164285.56

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jul/ 2022

Date of creation: 01/08/2022 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/07/22	V	984.62				
02/07/22	V	988.02				
03/07/22	V	962.61				
04/07/22	V	984.56				
05/07/22	V	980.49				
06/07/22	V	985.06				
07/07/22	V	999.82				
08/07/22	V	997.17				
09/07/22	V	1002.89				
10/07/22	V	1016.84				
11/07/22	V	1005.50				
12/07/22	V	995.15				
13/07/22	V	1017.42				
14/07/22	V	999.24				
15/07/22	V	1005.69				
16/07/22	V	1006.24				
17/07/22	V	1006.72				
18/07/22	V	1027.05				
19/07/22	V	1003.47				
20/07/22	V	995.31				
21/07/22	V	997.74				
22/07/22	V	999.69				
23/07/22	V	996.79				
24/07/22	V	1004.74				
25/07/22	V	998.46				
26/07/22	V	992.74				
27/07/22	V	983.90				
28/07/22	V	990.88				
29/07/22	V	986.74				
30/07/22	V	994.98				
31/07/22	V	1000.06				
MAV		997.50				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value