

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2022

Date of creation: 01/09/2022 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/08/22	V	0.00	V	0.00	V	0.63	V	0.11	V	1.32	V	0.31
02/08/22	V	0.00	V	0.00	V	0.58	V	0.09	V	1.15	V	0.30
03/08/22	V	0.00	V	0.00	V	0.59	V	0.09	V	3.04	V	0.27
04/08/22	V	0.00	V	0.00	V	0.56	V	0.09	V	1.84	V	0.27
05/08/22	V	0.00	V	0.00	V	0.55	V	0.09	V	2.48	V	0.28
06/08/22	V	0.00	V	0.00	V	0.59	V	0.12	V	3.69	V	0.30
07/08/22	V	0.00	V	0.00	V	0.58	V	0.09	V	1.21	V	0.28
08/08/22	V	0.00	V	0.00	V	0.56	V	0.10	V	2.27	V	0.28
09/08/22	V	0.00	V	0.02	V	0.57	V	0.10	V	1.05	V	0.28
10/08/22	V	0.00	V	0.00	V	0.58	V	0.11	V	0.76	V	0.32
11/08/22	V	0.00	V	0.00	V	0.58	V	0.11	V	1.19	V	0.31
12/08/22	V	0.00	V	0.00	V	0.63	V	0.11	V	1.08	V	0.30
13/08/22	V	0.00	V	0.00	V	0.57	V	0.11	V	2.72	V	0.31
14/08/22	V	0.00	V	0.00	V	0.56	V	0.09	V	1.47	V	0.33
15/08/22	V	0.00	V	0.00	V	0.57	V	0.09	V	1.24	V	0.29
16/08/22	V	0.00	V	0.00	V	0.59	V	0.11	V	1.81	V	0.29
17/08/22	V	0.00	V	0.00	V	0.59	V	0.11	V	1.96	V	0.28
18/08/22	V	0.00	V	0.00	V	0.59	V	0.11	V	3.82	V	0.32
19/08/22	V	0.00	V	0.00	V	0.58	V	0.12	V	3.90	V	0.32
20/08/22	V	0.00	V	0.00	V	0.61	V	0.12	V	2.72	V	0.29
21/08/22	V	0.00	V	0.00	V	0.63	V	0.13	V	1.38	V	0.33
22/08/22	V	0.00	V	0.00	V	0.61	V	0.10	V	4.60	V	0.31
23/08/22	V	0.00	V	0.00	V	0.61	V	0.10	V	1.63	V	0.36
24/08/22	V	0.00	V	0.00	V	0.61	V	0.10	V	3.93	V	0.32
25/08/22	V	0.00	V	0.00	V	0.62	V	0.12	V	3.01	V	0.33
26/08/22	V	0.00	V	0.00	V	0.62	V	0.11	V	2.99	V	0.36
27/08/22	V	0.00	V	0.04	V	0.23	V	0.04	V	5.39	V	0.62
28/08/22	V	0.00	V	0.06	V	0.00	V	0.01	V	3.87	V	0.72
29/08/22	V	0.00	V	0.00	V	0.00	V	0.02	V	4.46	V	0.78
30/08/22	V	0.00	V	0.01	V	0.20	V	0.06	V	3.74	V	0.51
31/08/22	V	0.00	V	0.00	V	0.53	V	0.09	V	2.33	V	0.40
MAV		0.00		0.00		0.53		0.10		2.52		0.35

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2022

Date of creation: 01/09/2022 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/08/22	V	98.61	V	9.39	V	18.05	V	58.83	V	996.02	V	161009.05
02/08/22	V	101.18	V	9.48	V	17.87	V	59.03	V	1002.53	V	163988.57
03/08/22	V	98.29	V	9.77	V	16.87	V	58.07	V	1005.90	V	166151.77
04/08/22	V	101.48	V	9.74	V	17.44	V	58.72	V	1006.55	V	167818.45
05/08/22	V	93.48	V	9.83	V	17.89	V	58.93	V	1003.85	V	168113.70
06/08/22	V	91.43	V	9.73	V	17.84	V	58.73	V	1003.51	V	164901.57
07/08/22	V	103.13	V	9.55	V	17.37	V	58.78	V	1009.20	V	165089.41
08/08/22	V	101.24	V	9.58	V	17.29	V	58.73	V	1011.09	V	164852.46
09/08/22	V	101.40	V	9.51	V	17.84	V	59.41	V	1012.66	V	165273.02
10/08/22	V	103.26	V	9.67	V	17.03	V	58.39	V	1012.92	V	165453.14
11/08/22	V	99.98	V	9.58	V	17.54	V	59.14	V	1011.99	V	165689.41
12/08/22	V	98.47	V	9.50	V	17.78	V	59.37	V	1010.97	V	165933.60
13/08/22	V	95.05	V	9.72	V	17.56	V	58.78	V	1007.34	V	166818.01
14/08/22	V	96.88	V	9.64	V	18.08	V	59.23	V	1002.81	V	166180.28
15/08/22	V	98.63	V	9.68	V	18.65	V	59.81	V	999.77	V	167400.83
16/08/22	V	102.90	V	9.80	V	18.44	V	59.31	V	998.97	V	166440.43
17/08/22	V	99.05	V	9.83	V	18.08	V	58.95	V	999.67	V	166761.26
18/08/22	V	102.38	V	9.90	V	18.03	V	58.98	V	1001.12	V	167940.03
19/08/22	V	98.90	V	9.81	V	17.93	V	58.96	V	1002.42	V	168183.57
20/08/22	V	94.62	V	9.68	V	18.17	V	59.28	V	1002.21	V	165292.83
21/08/22	V	84.32	V	9.68	V	18.07	V	58.96	V	1000.27	V	163882.95
22/08/22	V	98.18	V	9.78	V	18.32	V	59.36	V	1001.11	V	166360.13
23/08/22	V	91.99	V	10.03	V	17.62	V	58.48	V	1003.45	V	158423.40
24/08/22	V	90.59	V	10.17	V	17.49	V	58.27	V	1005.63	V	155238.66
25/08/22	V	89.20	V	10.20	V	17.44	V	58.13	V	1006.42	V	155110.52
26/08/22	V	90.19	V	10.08	V	17.25	V	57.92	V	1004.60	V	153650.96
27/08/22	V	83.97	V	10.59	V	17.17	V	57.22	V	1001.32	V	155405.11
28/08/22	V	88.03	V	10.34	M	17.84	V	57.98	V	999.10	V	154903.13
29/08/22	V	83.91	V	10.28	M	18.44	V	58.17	V	998.07	V	152313.07
30/08/22	V	100.03	V	10.08	V	18.01	V	58.12	V	1000.03	V	156018.22
31/08/22	V	101.87	V	9.68	V	16.86	V	57.99	V	1005.35	V	164075.16
MAV		96.22		9.82		17.75		58.71		1004.09		163059.30

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Aug/ 2022

Date of creation: 01/09/2022 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/08/22	V	994.23				
02/08/22	V	988.23				
03/08/22	V	984.20				
04/08/22	V	998.48				
05/08/22	V	988.59				
06/08/22	V	993.97				
07/08/22	V	999.11				
08/08/22	V	999.50				
09/08/22	V	982.58				
10/08/22	V	983.70				
11/08/22	V	982.05				
12/08/22	V	972.09				
13/08/22	V	966.25				
14/08/22	V	967.75				
15/08/22	V	978.60				
16/08/22	V	976.58				
17/08/22	V	975.26				
18/08/22	V	968.51				
19/08/22	V	961.83				
20/08/22	V	958.46				
21/08/22	V	966.91				
22/08/22	V	966.07				
23/08/22	V	957.49				
24/08/22	V	975.45				
25/08/22	V	973.42				
26/08/22	V	964.77				
27/08/22	V	974.74				
28/08/22	V	971.74				
29/08/22	V	961.34				
30/08/22	V	964.89				
31/08/22	V	967.51				
MAV		976.27				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value