

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Sep/ 2022

Date of creation: 01/10/2022 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/09/22	V	0.00	V	0.00	V	0.53	V	0.10	V	1.82	V	0.39
02/09/22	V	0.00	V	0.00	V	0.52	V	0.11	V	2.29	V	0.33
03/09/22	V	0.00	V	0.00	V	0.53	V	0.12	V	1.23	V	0.34
04/09/22	V	0.00	V	0.00	V	0.53	V	0.14	V	0.73	V	0.37
05/09/22	V	0.00	V	0.00	V	0.51	V	0.13	V	2.52	V	0.37
06/09/22	V	0.00	V	0.00	V	0.50	V	0.14	V	1.25	V	0.35
07/09/22	V	0.00	V	0.00	V	0.51	V	0.11	V	2.18	V	0.35
08/09/22	V	0.00	V	0.00	V	0.53	V	0.08	V	1.98	V	0.34
09/09/22	V	0.00	V	0.00	V	0.52	V	0.05	V	1.38	V	0.37
10/09/22	V	0.00	V	0.00	V	0.67	V	0.06	V	2.59	V	0.33
11/09/22	V	0.00	V	0.00	V	0.53	V	0.03	V	2.44	V	0.37
12/09/22	V	0.00	V	0.00	V	0.53	V	0.06	V	1.47	V	0.42
13/09/22	V	0.00	V	0.00	V	0.53	V	0.01	V	1.32	V	0.37
14/09/22	V	0.00	V	0.00	V	0.52	V	0.01	V	1.57	V	0.29
15/09/22	V	0.00	V	0.00	V	0.54	V	0.00	V	0.88	V	0.30
16/09/22	V	0.00	V	0.00	V	0.53	V	0.00	V	3.48	V	0.36
17/09/22	V	0.00	V	0.00	V	0.53	V	0.00	V	2.98	V	0.37
18/09/22	V	0.00	V	0.00	V	0.53	V	0.00	V	3.97	V	0.36
19/09/22	V	0.00	V	0.00	V	0.51	V	0.00	V	2.37	V	0.35
20/09/22	V	0.00	V	0.00	V	0.49	V	0.00	V	1.84	V	0.35
21/09/22	V	0.00	V	0.01	V	0.55	V	0.00	V	2.72	V	0.48
22/09/22	V	0.00	V	0.00	V	0.58	V	0.00	V	1.25	V	0.59
23/09/22	V	0.00	V	0.00	V	0.60	V	0.00	V	2.80	V	0.60
24/09/22	V	0.00	V	0.00	V	0.61	V	0.00	V	0.32	V	0.68
25/09/22	V	0.00	V	0.01	V	0.62	V	0.00	V	0.51	V	0.69
26/09/22	V	0.00	V	0.00	V	0.63	V	0.02	V	3.24	V	1.02
27/09/22	M	0.00	V	0.00	V	0.60	V	0.01	V	5.78	V	1.07
28/09/22	V	0.00	V	0.06	V	0.51	V	0.04	V	4.02	V	1.05
29/09/22	V	0.00	V	0.09	V	0.44	V	0.01	V	3.16	V	2.49
30/09/22	V	0.00	V	0.10	V	0.47	V	0.00	V	2.21	V	2.40
MAV		0.00		0.01		0.54		0.04		2.21		0.60

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Sep/ 2022

Date of creation: 01/10/2022 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
01/09/22	V	102.57	V	9.54	V	16.72	V	58.14	V	1005.58	V	164217.66
02/09/22	V	111.41	V	9.46	V	16.99	V	58.63	V	1008.36	V	164494.50
03/09/22	V	120.28	V	9.62	V	16.66	V	58.18	V	1010.01	V	164646.82
04/09/22	V	118.55	V	9.55	V	16.51	V	58.17	V	1012.52	V	164838.97
05/09/22	V	109.64	V	9.60	V	16.65	V	58.41	V	1014.86	V	166880.77
06/09/22	V	91.86	V	9.42	V	16.39	V	57.94	V	1011.95	V	163812.31
07/09/22	V	97.86	V	9.62	V	16.60	V	57.95	V	1006.70	V	165166.65
08/09/22	V	104.71	V	9.53	V	16.63	V	58.15	V	1007.69	V	164224.24
09/09/22	V	117.53	V	9.45	V	16.67	V	58.34	V	1008.16	V	164471.27
10/09/22	V	108.13	V	9.55	V	16.54	V	57.90	V	1004.11	V	164019.62
11/09/22	V	113.08	V	9.46	V	16.64	V	57.74	V	995.24	V	162057.76
12/09/22	V	125.17	V	9.41	V	16.91	V	57.96	V	998.08	V	161729.40
13/09/22	V	117.33	V	9.46	V	17.37	V	58.58	V	996.77	V	162994.44
14/09/22	V	121.57	V	9.24	V	18.23	V	59.44	V	987.63	V	162068.94
15/09/22	V	113.87	V	9.37	V	17.78	V	58.68	V	984.22	V	161893.69
16/09/22	V	118.78	V	9.44	V	17.40	V	58.37	V	983.02	V	161973.76
17/09/22	V	125.76	V	9.33	V	17.79	V	59.09	V	984.52	V	162401.58
18/09/22	V	116.93	V	9.16	V	18.08	V	59.31	V	986.84	V	161371.11
19/09/22	V	123.03	V	9.28	V	17.98	V	59.09	V	987.35	V	161300.76
20/09/22	V	129.20	V	9.17	V	18.02	V	59.48	V	996.09	V	161993.67
21/09/22	V	124.06	V	9.23	V	17.73	V	59.41	V	1003.99	V	162748.09
22/09/22	V	113.10	V	9.34	V	17.27	V	58.90	V	1006.32	V	163350.96
23/09/22	V	120.49	V	9.50	V	17.10	V	58.64	V	1004.14	V	164177.38
24/09/22	V	119.60	V	9.28	V	17.42	V	59.08	V	1001.79	V	163910.52
25/09/22	V	119.76	V	9.39	V	17.14	V	58.48	V	999.27	V	163557.38
26/09/22	V	98.22	V	9.61	V	16.80	V	57.81	V	993.80	V	164095.65
27/09/22	V	119.47	V	9.56	V	16.88	V	57.70	V	990.82	V	162114.39
28/09/22	V	109.73	V	9.52	V	18.92	V	58.59	V	986.70	V	158553.51
29/09/22	V	128.58	V	9.76	V	20.71	V	58.30	V	988.48	V	153966.02
30/09/22	V	116.92	V	9.81	V	20.77	V	58.73	V	998.53	V	155828.72
MAV		115.26		9.45		17.44		58.51		998.77		162623.83

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Sep/ 2022

Date of creation: 01/10/2022 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/09/22	V	968.13				
02/09/22	V	965.84				
03/09/22	V	967.02				
04/09/22	V	967.94				
05/09/22	V	989.78				
06/09/22	V	989.00				
07/09/22	V	971.25				
08/09/22	V	982.74				
09/09/22	V	983.10				
10/09/22	V	964.99				
11/09/22	V	980.05				
12/09/22	V	983.20				
13/09/22	V	972.35				
14/09/22	V	966.54				
15/09/22	V	968.65				
16/09/22	V	968.20				
17/09/22	V	966.26				
18/09/22	V	970.23				
19/09/22	V	966.87				
20/09/22	V	967.18				
21/09/22	V	963.54				
22/09/22	V	960.02				
23/09/22	V	957.47				
24/09/22	V	968.54				
25/09/22	V	967.87				
26/09/22	V	964.09				
27/09/22	V	954.29				
28/09/22	V	963.28				
29/09/22	V	963.53				
30/09/22	V	972.01				
MAV		969.78				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value