

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2022

Date of creation: 01/01/2023 04:31

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/12/22	V	0.00	V	0.00	V	0.38	V	0.23	V	7.72	V	0.04
02/12/22	V	0.00	V	0.00	V	0.36	V	0.14	V	6.21	V	0.03
03/12/22	V	0.00	V	0.00	V	0.36	V	0.17	V	4.44	V	0.07
04/12/22	V	0.00	V	0.00	V	0.32	V	0.21	V	6.58	V	0.00
05/12/22	V	0.00	V	0.00	V	0.33	V	0.18	V	7.32	V	0.01
06/12/22	V	0.00	V	0.00	V	0.32	V	0.18	V	4.42	V	0.01
07/12/22	V	0.01	V	0.00	V	0.46	V	0.19	V	3.61	V	0.03
08/12/22	V	0.01	V	0.00	V	0.34	V	0.19	V	9.09	V	0.03
09/12/22	V	0.01	V	0.01	V	0.33	V	0.16	V	11.01	V	0.04
10/12/22	V	0.00	V	0.00	V	0.35	V	0.15	V	7.23	V	0.08
11/12/22	V	0.00	V	0.00	V	0.33	V	0.12	V	9.07	V	0.06
12/12/22	V	0.01	V	0.01	V	0.32	V	0.18	V	9.85	V	0.06
13/12/22	V	0.02	V	0.02	V	0.35	V	0.24	V	7.94	V	0.16
14/12/22	V	0.00	V	0.01	V	0.35	V	0.15	V	3.42	V	0.05
15/12/22	V	0.02	V	0.00	V	0.34	V	0.13	V	4.17	V	0.04
16/12/22	V	0.00	V	0.00	V	0.33	V	0.17	V	3.64	V	0.02
17/12/22	V	0.00	V	0.00	V	0.32	V	0.18	V	3.03	V	0.00
18/12/22	V	0.00	V	0.01	V	0.32	V	0.22	V	5.25	V	0.00
19/12/22	V	0.00	V	0.00	V	0.31	V	0.10	V	2.48	V	0.00
20/12/22	V	0.02	V	0.00	V	0.29	V	0.19	V	9.35	V	0.06
21/12/22	V	0.01	V	0.00	V	0.30	V	0.24	V	9.32	V	0.16
22/12/22	V	0.00	V	0.01	V	0.31	V	0.30	V	19.17	V	0.27
23/12/22	V	0.00	V	0.10	V	0.32	V	0.37	V	10.02	V	0.29
24/12/22	V	0.00	V	0.01	V	0.35	V	0.29	V	7.64	V	0.18
25/12/22	V	0.00	V	0.01	V	0.34	V	0.21	V	6.44	V	0.15
26/12/22	V	0.00	V	0.03	V	0.31	V	0.19	V	5.70	V	0.08
27/12/22	V	0.01	V	0.01	V	0.35	V	0.42	V	2.25	V	0.38
28/12/22	V	0.00	V	0.03	V	0.34	V	0.27	V	5.72	V	0.29
29/12/22	V	0.00	V	0.04	V	0.33	V	0.32	V	7.10	V	0.31
30/12/22	V	0.00	V	0.00	V	0.37	V	0.41	V	4.66	V	0.44
31/12/22	V	0.01	V	0.02	V	0.37	V	0.29	V	5.65	V	0.41
MAV		0.00		0.01		0.34		0.22		6.76		0.12

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2022

Date of creation: 01/01/2023 04:31

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
	DLV:	200.00										
01/12/22	V	97.19	V	10.28	V	8.53	V	40.30	V	1019.22	V	154933.66
02/12/22	V	90.13	V	10.01	V	8.28	V	39.99	V	1018.11	V	151941.87
03/12/22	V	109.05	V	9.91	V	7.94	V	39.33	V	1017.75	V	158058.22
04/12/22	V	104.28	V	9.78	V	7.90	V	39.05	V	1017.56	V	159687.60
05/12/22	V	111.93	V	10.11	V	7.62	V	38.46	V	1013.83	V	162299.11
06/12/22	V	127.62	V	9.98	V	7.89	V	38.81	V	1002.59	V	158921.69
07/12/22	V	110.61	V	10.12	V	7.98	V	38.34	V	990.66	V	157450.09
08/12/22	V	122.10	V	10.03	V	7.83	V	38.06	V	991.56	V	157317.76
09/12/22	V	112.83	V	9.94	V	7.87	V	38.23	V	995.67	V	157155.59
10/12/22	V	95.97	V	9.78	V	8.23	V	39.54	V	996.57	V	153618.79
11/12/22	V	112.20	V	9.60	V	8.33	V	40.17	V	991.72	V	153044.49
12/12/22	V	99.39	V	9.58	V	9.11	V	40.84	V	980.37	V	151699.64
13/12/22	V	109.67	V	10.03	V	8.95	V	40.51	V	987.01	V	157248.25
14/12/22	V	124.35	V	9.83	V	9.31	V	42.16	V	995.83	V	155935.11
15/12/22	V	121.18	V	9.81	V	9.85	V	43.09	V	994.84	V	154492.63
16/12/22	V	93.58	V	9.88	V	9.57	V	42.99	V	1003.08	V	155258.09
17/12/22	V	108.81	V	9.96	V	9.46	V	43.33	V	1008.43	V	154991.13
18/12/22	V	113.41	V	9.80	V	9.52	V	43.19	V	1018.34	V	154637.18
19/12/22	V	104.63	V	9.71	V	8.83	V	42.46	V	1018.42	V	155482.72
20/12/22	V	102.97	V	9.48	V	9.16	V	41.67	V	1002.58	V	152694.10
21/12/22	V	95.60	V	9.62	V	8.13	V	38.75	V	996.38	V	153866.13
22/12/22	V	100.25	V	9.90	V	9.33	V	40.93	V	992.25	V	155221.95
23/12/22	V	96.89	V	9.87	V	10.31	V	42.28	V	987.69	V	154760.03
24/12/22	V	104.72	V	9.94	V	10.79	V	43.20	V	997.16	V	156054.58
25/12/22	V	100.36	V	9.99	V	9.04	V	41.02	V	1008.38	V	159289.18
26/12/22	V	100.36	V	9.59	V	9.06	V	41.06	V	1001.69	V	154457.14
27/12/22	V	110.54	V	9.70	V	15.52	V	51.69	V	996.52	V	148781.73
28/12/22	V	91.46	V	9.70	V	10.82	V	43.79	V	1000.80	V	152471.69
29/12/22	V	91.11	V	9.59	V	14.32	V	49.74	V	994.02	V	149982.81
30/12/22	V	113.04	V	9.48	V	20.22	V	58.47	V	996.15	V	147431.57
31/12/22	V	120.31	V	9.51	V	18.28	V	55.86	V	996.21	V	147501.93
MAV		106.34		9.82		9.94		42.49		1001.01		154732.01

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Dec/ 2022

Date of creation: 01/01/2023 04:31

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/12/22	V	982.48				
02/12/22	V	982.34				
03/12/22	V	990.30				
04/12/22	V	991.21				
05/12/22	V	984.42				
06/12/22	V	985.04				
07/12/22	V	972.80				
08/12/22	V	970.44				
09/12/22	V	973.47				
10/12/22	V	982.95				
11/12/22	V	992.96				
12/12/22	V	995.08				
13/12/22	V	979.69				
14/12/22	V	984.95				
15/12/22	V	985.45				
16/12/22	V	971.83				
17/12/22	V	968.84				
18/12/22	V	979.74				
19/12/22	V	975.83				
20/12/22	V	977.93				
21/12/22	V	981.56				
22/12/22	V	972.00				
23/12/22	V	970.32				
24/12/22	V	971.95				
25/12/22	V	966.14				
26/12/22	V	970.28				
27/12/22	V	965.84				
28/12/22	V	969.66				
29/12/22	V	974.47				
30/12/22	V	976.87				
31/12/22	V	990.77				
MAV		978.64				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value