

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2023

Date of creation: 01/02/2023 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/01/23	V	0.07	V	0.01	V	0.38	V	0.44	V	3.60	V	0.81
02/01/23	V	0.00	V	0.00	V	0.48	V	0.27	V	2.74	V	0.47
03/01/23	V	0.03	V	0.02	V	0.48	V	0.19	V	3.33	V	0.49
04/01/23	V	0.00	V	0.10	V	0.40	V	0.15	V	4.88	V	0.41
05/01/23	V	0.00	V	0.19	V	0.37	V	0.15	V	4.58	V	0.41
06/01/23	V	0.00	V	0.00	V	0.33	V	0.04	V	3.04	V	0.06
07/01/23	V	0.00	V	0.00	V	0.30	V	0.08	V	2.70	V	0.08
08/01/23	V	0.00	V	0.00	V	0.28	V	0.05	V	4.29	V	0.17
09/01/23	V	0.01	V	0.08	V	0.29	V	0.06	V	5.69	V	0.36
10/01/23	V	0.09	V	0.03	V	0.31	V	0.22	V	8.01	V	0.44
11/01/23	V	0.00	V	0.03	V	0.32	V	0.05	V	5.78	V	0.31
12/01/23	V	0.01	V	0.02	V	0.32	V	0.11	V	4.50	V	0.50
13/01/23	V	0.00	V	0.00	V	0.34	V	0.18	V	7.14	V	0.86
14/01/23	V	0.01	V	0.00	V	0.35	V	0.25	V	5.15	V	2.25
15/01/23	V	0.00	V	0.01	V	0.36	V	0.15	V	3.33	V	1.34
16/01/23	V	0.01	V	0.04	V	0.24	V	0.17	V	12.62	V	2.17
17/01/23	V	0.01	V	0.24	V	0.00	V	0.05	V	11.76	V	0.84
18/01/23	V	0.05	V	0.28	V	0.19	V	0.06	V	8.63	V	0.54
19/01/23	V	0.00	V	0.03	V	0.37	V	0.07	V	5.37	V	0.50
20/01/23	V	0.00	V	0.02	V	0.35	V	0.02	V	5.66	V	0.00
21/01/23	V	0.00	V	0.02	V	0.33	V	0.00	V	3.03	V	0.00
22/01/23	V	0.02	V	0.00	V	0.34	V	0.01	V	4.91	V	0.00
23/01/23	V	0.00	V	0.00	V	0.34	V	0.00	V	4.89	V	0.00
24/01/23	V	0.00	V	0.03	V	0.36	V	0.00	V	6.86	V	0.00
25/01/23	V	0.00	V	0.00	V	0.34	V	0.00	V	4.61	V	0.05
26/01/23	V	0.00	V	0.01	V	0.35	V	0.03	V	4.37	V	0.16
27/01/23	V	0.00	V	0.01	V	0.35	V	0.02	V	4.56	V	0.12
28/01/23	V	0.06	V	0.12	V	0.38	V	0.03	V	8.61	V	0.34
29/01/23	V	0.00	V	0.10	V	0.37	V	0.06	V	9.54	V	1.60
30/01/23	V	0.00	V	0.03	V	0.37	V	0.08	V	6.29	V	3.07
31/01/23	V	0.02	V	0.04	V	0.78	V	0.23	V	10.11	V	5.78
MAV		0.01		0.05		0.34		0.10		5.76		0.70

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2023

Date of creation: 01/02/2023 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/01/23	V	110.24	V	9.23	V	21.88	V	60.03	V	994.76	V	144841.78
02/01/23	V	104.55	V	9.60	V	20.75	V	59.04	V	1002.05	V	147323.94
03/01/23	V	97.20	V	9.41	V	19.95	V	57.98	V	1001.19	V	146837.07
04/01/23	V	103.62	V	9.42	V	10.54	V	43.70	V	1003.80	V	151019.99
05/01/23	V	113.04	V	9.44	V	10.60	V	43.48	V	986.79	V	149823.78
06/01/23	V	101.22	V	9.76	V	10.42	V	45.89	V	1008.65	V	157633.99
07/01/23	V	108.06	V	9.47	V	10.81	V	45.91	V	1008.60	V	153556.63
08/01/23	V	117.03	V	9.47	V	9.59	V	42.89	V	1004.31	V	152096.65
09/01/23	V	104.95	V	9.61	V	9.34	V	41.73	V	995.16	V	152293.44
10/01/23	V	101.50	V	9.78	V	10.48	V	43.39	V	999.72	V	153478.04
11/01/23	V	108.67	V	9.81	V	10.03	V	43.18	V	1004.69	V	154075.75
12/01/23	V	115.85	V	9.55	V	14.75	V	50.55	V	998.27	V	151377.03
13/01/23	V	111.33	V	9.75	V	17.49	V	54.85	V	994.29	V	149540.06
14/01/23	V	123.43	V	9.67	V	19.04	V	57.10	V	997.47	V	149679.78
15/01/23	V	116.07	V	9.52	V	19.38	V	57.57	V	989.11	V	148962.11
16/01/23	V	108.80	V	9.88	V	16.14	V	53.77	V	987.18	V	152772.44
17/01/23	V	89.86	V	9.58	V	11.17	V	50.15	V	979.89	V	156847.70
18/01/23	V	96.79	V	9.76	V	10.63	V	45.94	V	980.45	V	154368.79
19/01/23	V	108.65	V	9.83	V	12.02	V	45.35	V	990.59	V	151698.43
20/01/23	V	109.03	V	9.87	V	9.87	V	42.50	V	1000.68	V	153618.55
21/01/23	V	111.41	V	9.79	V	12.48	V	47.57	V	1010.91	V	154646.77
22/01/23	V	105.27	V	9.95	V	12.51	V	47.42	V	1019.39	V	155297.73
23/01/23	V	105.62	V	9.81	V	10.18	V	44.04	V	1024.97	V	157631.41
24/01/23	V	123.30	V	9.98	V	10.33	V	44.32	V	1024.94	V	159610.66
25/01/23	V	134.92	V	10.06	V	10.05	V	43.60	V	1016.63	V	159896.84
26/01/23	V	113.35	V	9.87	V	10.87	V	44.65	V	1007.59	V	156883.91
27/01/23	V	112.47	V	10.00	V	10.94	V	44.54	V	1008.65	V	155451.57
28/01/23	V	112.87	V	10.57	V	11.48	V	45.78	V	1010.32	V	150668.25
29/01/23	V	100.59	V	10.27	V	13.57	V	49.14	V	1000.58	V	159095.07
30/01/23	V	109.17	V	10.33	V	13.54	V	48.48	V	981.95	V	158737.30
31/01/23	V	98.69	V	10.47	V	15.48	V	51.23	V	984.68	V	156385.95
MAV		109.13		9.78		13.07		48.20		1000.84		153382.08

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jan/ 2023

Date of creation: 01/02/2023 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/01/23	V	984.67				
02/01/23	V	967.09				
03/01/23	V	969.40				
04/01/23	V	976.04				
05/01/23	V	972.47				
06/01/23	V	968.00				
07/01/23	V	970.94				
08/01/23	V	967.46				
09/01/23	V	959.75				
10/01/23	V	961.07				
11/01/23	V	965.07				
12/01/23	V	970.30				
13/01/23	V	965.50				
14/01/23	V	965.14				
15/01/23	V	967.06				
16/01/23	V	960.42				
17/01/23	V	963.54				
18/01/23	V	964.71				
19/01/23	V	964.28				
20/01/23	V	967.44				
21/01/23	V	967.75				
22/01/23	V	964.55				
23/01/23	V	974.56				
24/01/23	V	970.76				
25/01/23	V	963.99				
26/01/23	V	966.91				
27/01/23	V	971.11				
28/01/23	V	954.12				
29/01/23	V	952.23				
30/01/23	V	954.06				
31/01/23	V	951.45				
MAV		966.10				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value