

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Feb/ 2023

Date of creation: 01/03/2023 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/02/23	V	0.00	V	0.08	V	3.92	V	0.06	V	7.73	V	1.78
02/02/23	V	0.00	V	0.17	V	0.39	V	0.05	V	4.96	V	1.68
03/02/23	V	0.00	V	0.17	V	0.36	V	0.03	V	5.44	V	1.58
04/02/23	V	0.01	V	0.14	V	0.33	V	0.02	V	4.87	V	0.02
05/02/23	V	0.01	V	0.06	V	0.31	V	0.03	V	5.26	V	0.00
06/02/23	V	0.02	V	0.13	V	0.33	V	0.06	V	4.01	V	1.38
07/02/23	V	0.01	V	0.11	V	0.37	V	0.03	V	8.12	V	1.34
08/02/23	V	0.00	V	0.04	V	0.34	V	0.02	V	11.16	V	1.62
09/02/23	V	0.00	V	0.04	V	0.34	V	0.01	V	12.39	V	0.33
10/02/23	V	0.04	V	0.06	V	0.37	V	0.06	V	4.29	V	1.99
11/02/23	V	0.01	V	0.08	V	0.36	V	0.16	V	2.76	V	1.58
12/02/23	V	0.01	V	0.09	V	0.35	V	0.09	V	5.93	V	1.68
13/02/23	V	0.01	V	0.01	V	0.31	V	0.18	V	2.46	V	1.32
14/02/23	V	0.00	V	0.00	V	0.34	V	0.09	V	1.83	V	0.48
15/02/23	V	0.00	V	0.00	V	0.35	V	0.05	V	3.18	V	0.41
16/02/23	V	0.03	V	0.00	V	0.35	V	0.02	V	7.16	V	0.47
17/02/23	V	0.02	V	0.00	V	0.36	V	0.02	V	5.33	V	0.47
18/02/23	V	0.03	V	0.00	V	0.35	V	0.15	V	5.11	V	0.46
19/02/23	V	0.00	V	0.00	V	0.35	V	0.03	V	6.64	V	0.40
20/02/23	V	0.00	V	0.00	V	0.35	V	0.05	V	9.13	V	0.46
21/02/23	V	0.00	V	0.00	V	0.36	V	0.08	V	7.85	V	0.46
22/02/23	V	0.00	V	0.00	V	0.38	V	0.01	V	7.82	V	0.41
23/02/23	V	0.00	V	0.00	V	0.34	V	0.05	V	3.23	V	0.45
24/02/23	V	0.08	V	0.00	V	0.33	V	0.09	V	5.47	V	0.45
25/02/23	V	0.01	V	0.00	V	0.34	V	0.02	V	4.45	V	0.53
26/02/23	V	0.00	V	0.00	V	0.34	V	0.01	V	3.96	V	0.33
27/02/23	V	0.00	V	0.02	V	0.14	V	0.01	V	5.89	V	0.50
28/02/23	V	0.00	V	0.01	V	0.03	V	0.00	V	8.59	V	0.61
MAV		0.01		0.04		0.46		0.05		5.86		0.83

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Feb/ 2023

Date of creation: 01/03/2023 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/02/23	V	113.61	V	10.51	V	15.29	V	50.73	V	981.24	V	160450.79
02/02/23	V	109.79	V	10.23	V	13.01	V	47.30	V	988.96	V	159240.83
03/02/23	V	101.03	V	9.91	V	12.03	V	46.31	V	999.31	V	159171.18
04/02/23	V	122.33	V	9.85	V	11.93	V	46.98	V	1009.92	V	160774.35
05/02/23	V	114.96	V	9.95	V	11.80	V	47.13	V	1021.14	V	161140.59
06/02/23	V	121.82	V	9.93	V	12.48	V	47.79	V	1021.40	V	161467.07
07/02/23	V	117.11	V	10.27	V	12.66	V	48.10	V	1024.40	V	164489.25
08/02/23	V	105.25	V	9.99	V	11.88	V	47.28	V	1028.85	V	164381.15
09/02/23	V	89.43	V	10.19	V	11.76	V	46.95	V	1019.70	V	161536.53
10/02/23	V	102.83	V	10.11	V	12.85	V	47.89	V	1008.67	V	158403.73
11/02/23	V	114.30	V	9.83	V	14.88	V	50.50	V	1000.99	V	152154.26
12/02/23	V	107.49	V	9.85	V	13.13	V	48.24	V	1016.24	V	155042.57
13/02/23	V	99.46	V	10.22	V	16.58	V	54.00	V	1011.27	V	156463.63
14/02/23	V	96.97	V	10.25	V	16.68	V	53.75	V	1014.75	V	158176.96
15/02/23	V	95.59	V	10.16	V	11.83	V	45.86	V	1015.99	V	156735.49
16/02/23	V	106.71	V	10.11	V	12.52	V	47.00	V	1006.64	V	157247.89
17/02/23	V	119.20	V	10.36	V	13.64	V	48.17	V	995.68	V	159131.91
18/02/23	V	112.25	V	10.18	V	14.42	V	48.92	V	981.03	V	153663.03
19/02/23	V	111.65	V	9.77	V	12.27	V	46.10	V	989.59	V	151897.42
20/02/23	V	108.11	V	9.85	V	11.03	V	44.23	V	985.98	V	151794.41
21/02/23	V	112.59	V	10.01	V	11.51	V	44.71	V	984.38	V	153755.31
22/02/23	V	108.74	V	9.92	V	9.86	V	43.05	V	1004.36	V	155565.04
23/02/23	V	103.91	V	9.86	V	10.01	V	43.55	V	1005.12	V	154534.54
24/02/23	V	112.56	V	9.69	V	12.24	V	46.34	V	985.44	V	151851.91
25/02/23	V	94.55	V	9.72	V	12.63	V	46.32	V	978.00	V	150494.30
26/02/23	V	95.16	V	9.76	V	9.82	V	42.96	V	994.78	V	153946.55
27/02/23	V	91.48	V	9.49	V	7.71	V	44.28	V	1011.55	V	158925.44
28/02/23	V	81.10	V	9.55	V	7.85	V	46.65	V	1013.63	V	162140.87
MAV		106.06		9.98		12.30		47.18		1003.38		157257.96

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Feb/ 2023

Date of creation: 01/03/2023 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/02/23	V	971.83				
02/02/23	V	986.40				
03/02/23	V	976.02				
04/02/23	V	969.26				
05/02/23	V	968.13				
06/02/23	V	974.28				
07/02/23	V	969.65				
08/02/23	V	971.68				
09/02/23	V	964.17				
10/02/23	V	964.12				
11/02/23	V	974.25				
12/02/23	V	972.23				
13/02/23	V	973.90				
14/02/23	V	976.41				
15/02/23	V	972.00				
16/02/23	V	964.87				
17/02/23	V	960.26				
18/02/23	V	963.50				
19/02/23	V	975.39				
20/02/23	V	969.43				
21/02/23	V	957.17				
22/02/23	V	958.98				
23/02/23	V	975.95				
24/02/23	V	979.26				
25/02/23	V	970.26				
26/02/23	V	966.69				
27/02/23	V	969.22				
28/02/23	V	975.96				
MAV		970.41				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value