

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2023

Date of creation: 01/04/2023 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/03/23	V	0.18	V	0.01	V	0.00	V	0.00	V	5.59	V	0.66
02/03/23	V	0.04	V	0.04	V	0.00	V	0.00	V	10.78	V	0.69
03/03/23	V	0.03	V	0.02	V	0.00	V	0.00	V	8.27	V	0.68
04/03/23	V	0.01	V	0.01	V	0.00	V	0.00	V	8.46	V	0.62
05/03/23	V	0.05	V	0.02	V	0.00	V	0.00	V	7.98	V	0.61
06/03/23	V	0.05	V	0.02	V	0.00	V	0.01	V	5.56	V	0.59
07/03/23	V	0.02	V	0.02	V	0.00	V	0.00	V	7.65	V	0.58
08/03/23	V	0.13	V	0.01	V	0.00	V	0.00	V	6.56	V	0.59
09/03/23	V	0.04	V	0.04	V	0.00	V	0.00	V	9.05	V	0.59
10/03/23	V	0.00	V	0.01	V	0.43	V	0.00	V	6.67	V	0.63
11/03/23	V	0.22	V	0.03	V	0.00	V	0.01	V	7.20	V	0.61
12/03/23	V	0.02	V	0.03	V	0.00	V	0.01	V	8.78	V	0.64
13/03/23	V	0.00	V	0.04	V	0.00	V	0.01	V	7.71	V	0.64
14/03/23	V	0.14	V	0.00	V	0.00	V	0.00	V	5.51	V	0.67
15/03/23	V	0.29	V	0.00	V	0.00	V	0.00	V	5.60	V	0.64
16/03/23	V	0.01	V	0.01	V	0.00	V	0.00	V	4.71	V	0.69
17/03/23	V	0.01	V	0.01	V	0.00	V	0.00	V	3.71	V	0.64
18/03/23	V	0.02	V	0.02	V	0.00	V	0.00	V	5.71	V	0.65
19/03/23	V	0.11	V	0.00	V	0.00	V	0.00	V	4.04	V	0.73
20/03/23	V	0.27	V	0.00	V	0.00	V	0.00	V	4.69	V	0.75
21/03/23	V	0.09	V	0.00	V	0.00	V	0.00	V	7.65	V	0.73
22/03/23	V	0.00	V	0.00	V	0.20	V	0.00	V	4.92	V	0.51
23/03/23	V	0.08	V	0.00	V	0.33	V	0.00	V	2.17	V	0.37
24/03/23	V	0.02	V	0.01	V	0.39	V	0.00	V	4.28	V	0.40
25/03/23	V	0.14	V	0.00	V	0.42	V	0.00	V	5.90	V	0.43
26/03/23	V	0.01	V	0.00	V	0.62	V	0.00	V	4.83	V	0.49
27/03/23	V	0.01	V	0.00	V	0.40	V	0.03	V	2.98	V	0.48
28/03/23	V	0.00	V	0.01	V	0.38	V	0.00	V	10.54	V	0.42
29/03/23	V	0.34	V	0.00	V	0.40	V	0.00	V	7.55	V	0.40
30/03/23	V	0.02	V	0.00	V	0.41	V	0.00	V	5.25	V	0.46
31/03/23	V	0.09	V	0.00	V	0.32	V	0.01	V	5.83	V	0.42
MAV		0.08		0.01		0.14		0.00		6.33		0.58

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2023

Date of creation: 01/04/2023 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
01/03/23	V	86.91	V	9.65	V	11.22	V	50.50	V	1009.80	V	159304.59
02/03/23	V	80.53	V	9.79	V	10.34	V	49.57	V	1006.09	V	159816.48
03/03/23	V	80.17	V	9.76	V	11.58	V	51.61	V	997.02	V	158415.58
04/03/23	V	89.81	V	9.47	V	9.12	V	47.65	V	985.91	V	159013.00
05/03/23	V	82.32	V	9.44	V	6.24	V	44.51	V	987.68	V	162141.29
06/03/23	V	83.92	V	9.43	V	6.22	V	44.75	V	986.52	V	162650.16
07/03/23	V	84.63	V	9.44	V	7.12	V	46.28	V	983.85	V	162152.48
08/03/23	V	85.31	V	9.47	V	7.55	V	46.11	V	978.42	V	160233.67
09/03/23	V	91.34	V	9.73	V	6.56	V	45.31	V	986.36	V	161302.57
10/03/23	V	76.09	V	9.52	V	5.67	V	43.92	V	986.24	V	162128.96
11/03/23	V	78.76	V	9.46	V	6.19	V	43.93	V	976.27	V	160081.29
12/03/23	V	81.53	V	9.46	V	6.19	V	44.47	V	986.97	V	161526.12
13/03/23	V	91.57	V	9.64	V	9.81	V	49.46	V	990.75	V	161465.97
14/03/23	V	92.65	V	10.04	V	15.14	V	54.62	V	980.40	V	154774.08
15/03/23	V	90.22	V	9.59	V	11.66	V	51.31	V	991.49	V	158575.91
16/03/23	V	95.89	V	9.72	V	10.82	V	50.28	V	1004.98	V	161245.56
17/03/23	V	104.50	V	9.72	V	12.63	V	53.50	V	1011.54	V	160957.97
18/03/23	V	97.42	V	9.87	V	16.11	V	57.18	V	1008.56	V	158501.48
19/03/23	V	102.26	V	10.10	V	19.00	V	59.22	V	1004.10	V	156054.76
20/03/23	V	95.14	V	9.90	V	18.24	V	58.11	V	999.31	V	154628.96
21/03/23	V	87.17	V	9.90	V	15.26	V	55.39	V	998.80	V	157013.06
22/03/23	V	97.23	V	10.05	V	15.53	V	54.22	V	998.27	V	156101.33
23/03/23	V	111.53	V	9.92	V	18.63	V	56.01	V	990.87	V	149789.18
24/03/23	V	102.84	V	10.14	V	16.90	V	53.43	V	989.00	V	151511.27
25/03/23	V	99.62	V	10.64	V	17.78	V	54.32	V	986.62	V	156895.26
26/03/23	V	98.77	V	10.48	V	17.83	V	54.37	V	984.50	V	156272.08
27/03/23	V	103.25	V	10.24	V	16.38	V	52.77	V	988.23	V	154849.22
28/03/23	V	109.72	V	10.26	V	13.14	V	48.24	V	996.14	V	158598.95
29/03/23	V	113.29	V	9.98	V	14.08	V	50.24	V	1001.53	V	154514.53
30/03/23	V	106.77	V	9.94	V	15.48	V	52.56	V	997.50	V	152009.13
31/03/23	V	101.51	V	9.85	V	17.69	V	54.34	V	986.18	V	147831.04
MAV		93.63		9.82		12.45		50.90		992.90		157756.56

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant:

Report time: Mar/ 2023

Date of creation: 01/04/2023 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/03/23	V	976.18				
02/03/23	V	965.39				
03/03/23	V	967.56				
04/03/23	V	971.57				
05/03/23	V	970.24				
06/03/23	V	974.31				
07/03/23	V	974.03				
08/03/23	V	974.35				
09/03/23	V	966.49				
10/03/23	V	968.91				
11/03/23	V	971.61				
12/03/23	V	974.75				
13/03/23	V	978.16				
14/03/23	V	971.55				
15/03/23	V	985.91				
16/03/23	V	969.39				
17/03/23	V	981.69				
18/03/23	V	983.74				
19/03/23	V	972.64				
20/03/23	V	971.18				
21/03/23	V	972.52				
22/03/23	V	965.80				
23/03/23	V	972.35				
24/03/23	V	970.59				
25/03/23	V	966.12				
26/03/23	V	970.97				
27/03/23	V	982.39				
28/03/23	V	996.42				
29/03/23	V	995.23				
30/03/23	V	982.60				
31/03/23	V	978.39				
MAV		974.95				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value