

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jun/ 2023

Date of creation: 01/07/2023 04:34

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/06/23	V	0.00	V	0.00	V	0.30	V	0.00	V	7.14	V	0.36
02/06/23	V	0.01	V	0.00	V	0.43	V	0.00	V	11.81	V	0.38
03/06/23	V	0.00	V	0.00	V	0.41	V	0.00	V	14.14	V	0.36
04/06/23	V	0.01	V	0.00	V	0.38	V	0.00	V	3.36	V	0.26
05/06/23	V	0.00	V	0.00	V	0.32	V	0.01	V	10.17	V	0.32
06/06/23	V	0.00	V	0.00	V	0.33	V	0.01	V	6.91	V	0.33
07/06/23	V	0.06	V	0.00	V	0.32	V	0.03	V	14.70	V	0.39
08/06/23	V	0.00	V	0.00	V	0.30	V	0.06	V	10.51	V	0.32
09/06/23	V	0.01	V	0.00	V	0.30	V	0.08	V	8.69	V	0.37
10/06/23	V	0.00	V	0.00	V	0.38	V	0.02	V	11.75	V	0.35
11/06/23	V	0.00	V	0.00	V	0.36	V	0.03	V	5.45	V	0.37
12/06/23	V	0.00	V	0.00	V	0.31	V	0.06	V	7.24	V	0.37
13/06/23	V	0.00	V	0.00	V	0.29	V	0.04	V	5.28	V	0.35
14/06/23	V	0.00	V	0.00	V	0.29	V	0.03	V	2.61	V	0.39
15/06/23	V	0.01	V	0.00	V	0.29	V	0.05	V	2.16	V	0.45
16/06/23	V	0.07	V	0.00	V	0.27	V	0.01	V	1.27	V	0.36
17/06/23	V	0.00	V	0.00	V	0.30	V	0.03	V	0.10	V	0.34
18/06/23	V	0.02	V	0.00	V	0.34	V	0.07	V	1.73	V	0.36
19/06/23	V	0.01	V	0.00	V	0.34	V	0.05	V	1.08	V	0.38
20/06/23	V	0.08	V	0.00	V	0.33	V	0.05	V	3.42	V	0.37
21/06/23	V	0.04	V	0.00	V	0.30	V	0.06	V	2.76	V	0.42
22/06/23	V	0.05	V	0.00	V	0.31	V	0.11	V	7.96	V	0.42
23/06/23	V	0.09	V	0.00	V	0.34	V	0.05	V	6.09	V	0.38
24/06/23	V	0.06	V	0.00	V	0.33	V	0.05	V	8.02	V	0.38
25/06/23	V	0.00	V	0.00	V	0.33	V	0.04	V	9.99	V	0.36
26/06/23	V	0.01	V	0.00	V	0.32	V	0.03	V	4.85	V	0.33
27/06/23	V	0.00	V	0.00	V	0.33	V	0.03	V	8.43	V	0.39
28/06/23	V	0.00	V	0.00	V	0.32	V	0.02	V	1.74	V	0.35
29/06/23	V	0.03	V	0.00	V	0.31	V	0.02	V	1.50	V	0.34
30/06/23	V	0.01	V	0.00	V	0.32	V	0.03	V	0.89	V	0.39
MAV		0.02		0.00		0.33		0.04		6.04		0.37

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jun/ 2023

Date of creation: 01/07/2023 04:34

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/06/23	V	97.33	V	9.85	V	16.18	V	52.27	V	998.99	V	154998.40
02/06/23	V	107.05	V	10.18	V	14.25	V	49.95	V	1001.54	V	158229.25
03/06/23	V	100.22	V	10.14	V	15.21	V	51.46	V	1008.49	V	156570.05
04/06/23	V	99.37	V	9.69	V	14.68	V	50.78	V	1008.60	V	153475.16
05/06/23	V	86.30	V	9.85	V	15.32	V	51.61	V	1009.21	V	154210.04
06/06/23	V	105.13	V	10.23	V	15.45	V	51.67	V	1008.15	V	158107.23
07/06/23	V	112.24	V	10.52	V	15.80	V	51.99	V	1005.62	V	158842.75
08/06/23	V	92.83	V	10.26	V	15.51	V	51.53	V	1003.74	V	156516.01
09/06/23	V	93.08	V	10.10	V	15.99	V	52.28	V	1004.15	V	155394.77
10/06/23	V	108.37	V	10.17	V	15.32	V	51.83	V	1009.25	V	156417.93
11/06/23	V	123.76	V	9.42	V	14.41	V	50.48	V	1012.71	V	149849.13
12/06/23	V	108.57	V	9.53	V	11.58	V	45.55	V	1011.16	V	150066.63
13/06/23	V	119.78	V	9.60	V	14.47	V	50.10	V	1006.80	V	149370.42
14/06/23	V	115.36	V	9.77	V	11.76	V	45.39	V	1005.07	V	146028.38
15/06/23	V	136.21	V	9.60	V	13.03	V	47.07	V	1003.27	V	148688.36
16/06/23	V	143.12	V	9.56	V	13.09	V	46.90	V	1000.69	V	147776.17
17/06/23	V	160.30	V	9.45	V	15.92	V	51.02	V	998.03	V	144687.95
18/06/23	V	120.31	V	9.11	V	15.42	V	50.15	V	1000.05	V	141315.14
19/06/23	V	126.47	V	8.99	V	15.96	V	51.17	V	1001.30	V	140433.12
20/06/23	V	130.33	V	9.69	V	16.74	V	52.43	V	1002.65	V	149532.75
21/06/23	V	128.78	V	9.61	V	17.64	V	53.71	V	1003.03	V	151473.65
22/06/23	V	130.28	V	9.61	V	18.13	V	54.19	V	1001.81	V	151342.54
23/06/23	V	117.32	V	9.34	V	17.74	V	53.88	V	1001.50	V	148603.81
24/06/23	V	112.84	V	9.47	V	18.35	V	54.93	V	1003.10	V	148803.15
25/06/23	V	114.05	V	9.72	V	17.09	V	53.44	V	1003.63	V	152798.41
26/06/23	V	129.35	V	9.48	V	15.80	V	50.98	V	999.48	V	148262.04
27/06/23	V	129.77	V	9.49	V	16.98	V	52.66	V	994.24	V	147166.59
28/06/23	V	137.50	V	9.79	V	17.38	V	53.20	V	993.51	V	151961.40
29/06/23	V	136.79	V	9.65	V	17.36	V	53.17	V	994.39	V	152335.32
30/06/23	V	104.64	V	9.93	V	16.98	V	52.55	V	993.52	V	153098.04
MAV		117.65		9.73		15.65		51.27		1002.91		151189.94

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jun/ 2023

Date of creation: 01/07/2023 04:34

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/06/23	V	969.88				
02/06/23	V	973.89				
03/06/23	V	969.45				
04/06/23	V	982.17				
05/06/23	V	967.59				
06/06/23	V	967.94				
07/06/23	V	948.29				
08/06/23	V	954.78				
09/06/23	V	953.98				
10/06/23	V	964.17				
11/06/23	V	983.37				
12/06/23	V	974.41				
13/06/23	V	975.96				
14/06/23	V	970.82				
15/06/23	V	980.53				
16/06/23	V	982.47				
17/06/23	V	985.29				
18/06/23	V	979.27				
19/06/23	V	981.60				
20/06/23	V	972.92				
21/06/23	V	972.87				
22/06/23	V	978.75				
23/06/23	V	972.34				
24/06/23	V	975.04				
25/06/23	V	980.25				
26/06/23	V	986.92				
27/06/23	V	983.06				
28/06/23	V	975.29				
29/06/23	V	981.96				
30/06/23	V	977.19				
MAV		974.11				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value