

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2023

Date of creation: 01/08/2023 04:33

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/07/23	V	0.02	V	0.00	V	0.33	V	0.09	V	0.12	V	0.38
02/07/23	V	0.01	V	0.00	V	0.33	V	0.03	V	0.70	V	0.40
03/07/23	V	0.00	V	0.00	V	0.34	V	0.02	V	3.07	V	0.39
04/07/23	V	0.01	V	0.00	V	0.33	V	0.06	V	3.54	V	0.40
05/07/23	V	0.00	V	0.00	V	0.33	V	0.03	V	3.21	V	0.39
06/07/23	V	0.02	V	0.00	V	0.33	V	0.08	V	0.41	V	0.35
07/07/23	V	0.00	V	0.00	V	0.33	V	0.04	V	1.29	V	0.36
08/07/23	V	0.00	V	0.00	V	0.32	V	0.05	V	0.46	V	0.38
09/07/23	V	0.00	V	0.00	V	0.32	V	0.03	V	0.94	V	0.41
10/07/23	V	0.00	V	0.00	V	0.35	V	0.01	V	1.72	V	0.36
11/07/23	V	0.00	V	0.00	V	0.35	V	0.02	V	4.42	V	0.31
12/07/23	V	0.01	V	0.00	V	0.33	V	0.04	V	1.83	V	0.36
13/07/23	V	0.01	V	0.00	V	0.30	V	0.09	V	0.54	V	0.37
14/07/23	V	0.01	V	0.00	V	0.28	V	0.04	V	0.62	V	0.32
15/07/23	V	0.02	V	0.00	V	0.28	V	0.05	V	0.31	V	0.38
16/07/23	V	0.00	V	0.00	V	0.26	V	0.14	V	0.03	V	0.38
17/07/23	V	0.04	V	0.00	V	0.28	V	0.10	V	0.64	V	0.34
18/07/23	V	0.00	V	0.00	V	0.29	V	0.01	V	1.14	V	0.35
19/07/23	V	0.00	V	0.00	V	0.28	V	0.00	V	1.71	V	0.31
20/07/23	V	0.01	V	0.00	V	0.31	V	0.06	V	0.81	V	0.36
21/07/23	V	0.00	V	0.00	V	0.30	V	0.03	V	0.60	V	0.36
22/07/23	V	0.00	V	0.00	V	0.31	V	0.01	V	4.62	V	0.43
23/07/23	V	0.01	V	0.00	V	0.31	V	0.04	V	1.92	V	0.41
24/07/23	V	0.01	V	0.00	V	0.30	V	0.07	V	1.35	V	0.39
25/07/23	V	0.06	V	0.00	V	0.30	V	0.08	V	1.16	V	0.34
26/07/23	V	0.02	V	0.00	V	0.29	V	0.09	V	1.95	V	0.36
27/07/23	V	0.00	V	0.00	V	0.28	V	0.02	V	1.14	V	0.39
28/07/23	V	0.00	V	0.00	V	0.30	V	0.01	V	0.71	V	0.37
29/07/23	V	0.05	V	0.00	V	0.31	V	0.06	V	0.80	V	0.37
30/07/23	V	0.05	V	0.00	V	0.30	V	0.05	V	1.78	V	0.37
31/07/23	V	0.01	V	0.00	V	0.32	V	0.08	V	2.04	V	0.38
MAV		0.01		0.00		0.31		0.05		1.47		0.37

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2023

Date of creation: 01/08/2023 04:33

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/07/23	V	139.22	V	9.59	V	17.80	V	53.86	V	990.54	V	151203.98
02/07/23	V	143.68	V	9.70	V	17.73	V	53.61	V	987.31	V	151879.96
03/07/23	V	124.07	V	9.75	V	16.98	V	53.16	V	992.78	V	153058.74
04/07/23	V	131.38	V	9.84	V	17.57	V	53.95	V	997.19	V	153991.80
05/07/23	V	127.11	V	9.84	V	17.84	V	54.51	V	1001.85	V	154923.23
06/07/23	V	138.76	V	9.68	V	18.57	V	55.26	V	1001.71	V	152959.01
07/07/23	V	138.64	V	9.69	V	17.61	V	54.42	V	1007.12	V	153534.05
08/07/23	V	141.21	V	9.55	V	17.75	V	54.63	V	1006.58	V	153097.82
09/07/23	V	133.16	V	9.58	V	18.02	V	54.70	V	1005.99	V	152712.57
10/07/23	V	139.07	V	9.70	V	17.98	V	54.60	V	1004.79	V	152385.59
11/07/23	V	146.09	V	9.60	V	16.61	V	52.98	V	1002.95	V	152454.03
12/07/23	V	140.86	V	9.69	V	17.22	V	53.67	V	998.98	V	152359.78
13/07/23	V	134.39	V	9.74	V	18.33	V	54.69	V	996.92	V	152224.82
14/07/23	V	139.90	V	9.77	V	17.81	V	54.31	V	1001.05	V	153208.39
15/07/23	V	123.90	V	9.85	V	17.15	V	53.63	V	1003.36	V	153706.55
16/07/23	V	137.31	V	9.59	V	19.88	V	56.94	V	1000.49	V	152584.53
17/07/23	V	123.68	V	9.80	V	19.21	V	55.81	V	1000.67	V	152642.40
18/07/23	V	125.12	V	9.83	V	17.56	V	53.89	V	998.99	V	153521.91
19/07/23	V	120.09	V	9.85	V	20.54	V	57.92	V	996.47	V	153403.48
20/07/23	V	129.57	V	9.71	V	18.62	V	55.33	V	993.80	V	152195.11
21/07/23	V	128.65	V	9.61	V	18.63	V	55.43	V	996.07	V	152364.62
22/07/23	V	125.13	V	9.75	V	18.52	V	55.09	V	996.50	V	152828.98
23/07/23	V	125.44	V	9.72	V	17.44	V	53.78	V	997.36	V	153056.32
24/07/23	V	132.90	V	9.71	V	17.98	V	54.01	V	991.60	V	151509.26
25/07/23	V	144.51	V	9.72	V	17.96	V	53.68	V	985.35	V	151369.84
26/07/23	V	121.41	V	9.83	V	18.13	V	54.31	V	989.33	V	152461.78
27/07/23	V	138.09	V	9.64	V	17.42	V	53.67	V	993.88	V	152093.52
28/07/23	V	133.06	V	9.65	V	17.78	V	54.19	V	992.03	V	152446.96
29/07/23	V	133.99	V	9.67	V	18.97	V	55.65	V	993.25	V	152172.53
30/07/23	V	106.61	V	9.58	V	18.67	V	55.11	V	993.21	V	151310.92
31/07/23	V	100.76	V	9.50	V	18.74	V	55.23	V	993.92	V	151091.67
MAV		131.21		9.70		18.10		54.58		997.16		152605.12

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jul/ 2023

Date of creation: 01/08/2023 04:33

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/07/23	V	990.77				
02/07/23	V	990.52				
03/07/23	V	981.43				
04/07/23	V	979.70				
05/07/23	V	979.19				
06/07/23	V	982.94				
07/07/23	V	978.58				
08/07/23	V	990.28				
09/07/23	V	991.71				
10/07/23	V	981.94				
11/07/23	V	980.02				
12/07/23	V	974.13				
13/07/23	V	986.37				
14/07/23	V	991.44				
15/07/23	V	985.23				
16/07/23	V	997.30				
17/07/23	V	985.72				
18/07/23	V	978.51				
19/07/23	V	973.45				
20/07/23	V	983.12				
21/07/23	V	987.88				
22/07/23	V	985.04				
23/07/23	V	987.20				
24/07/23	V	982.42				
25/07/23	V	981.43				
26/07/23	V	976.71				
27/07/23	V	983.71				
28/07/23	V	970.33				
29/07/23	V	963.23				
30/07/23	V	961.88				
31/07/23	V	960.80				
MAV		981.38				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value