

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2023

Date of creation: 01/09/2023 04:32

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/08/23	V	0.01	V	0.00	V	0.31	V	0.02	V	1.69	V	0.42
02/08/23	V	0.08	V	0.00	V	0.33	V	0.08	V	2.73	V	0.39
03/08/23	V	0.04	V	0.00	V	0.34	V	0.06	V	2.00	V	0.34
04/08/23	V	0.37	V	0.00	V	0.35	V	0.05	V	4.12	V	0.42
05/08/23	V	0.26	V	0.00	V	0.33	V	0.04	V	1.67	V	0.43
06/08/23	V	0.01	V	0.00	V	0.33	V	0.06	V	1.72	V	0.47
07/08/23	V	0.01	V	0.00	V	0.37	V	0.04	V	1.39	V	0.39
08/08/23	V	0.02	V	0.01	V	0.30	V	0.01	V	2.87	V	0.36
09/08/23	V	0.14	V	0.00	V	0.27	V	0.00	V	2.93	V	0.40
10/08/23	V	0.01	V	0.00	V	0.40	V	0.00	V	0.49	V	0.36
11/08/23	V	0.00	V	0.00	V	0.43	V	0.00	V	0.54	V	0.37
12/08/23	V	0.00	V	0.00	V	0.48	V	0.01	V	0.81	V	0.37
13/08/23	V	0.00	V	0.00	V	0.41	V	0.00	V	0.52	V	0.32
14/08/23	V	0.02	V	0.00	V	0.44	V	0.00	V	1.17	V	0.34
15/08/23	V	0.02	V	0.00	V	0.42	V	0.01	V	2.29	V	0.31
16/08/23	V	0.00	V	0.00	V	0.51	V	0.04	V	0.66	V	0.27
17/08/23	V	0.10	V	0.00	V	0.40	V	0.05	V	4.32	V	0.31
18/08/23	V	0.00	V	0.00	V	0.41	V	0.03	V	1.21	V	0.28
19/08/23	V	0.00	V	0.00	V	0.42	V	0.02	V	0.39	V	0.40
20/08/23	V	0.35	V	0.00	V	0.41	V	0.05	V	2.96	V	0.34
21/08/23	V	0.00	V	0.00	V	0.45	V	0.01	V	3.04	V	0.41
22/08/23	V	0.00	V	0.00	V	0.48	V	0.00	V	5.85	V	0.42
23/08/23	V	0.00	V	0.00	V	0.43	V	0.01	V	3.45	V	0.32
24/08/23	V	0.00	V	0.00	V	0.42	V	0.00	V	2.55	V	0.33
25/08/23	V	0.00	V	0.00	V	0.43	V	0.01	V	3.77	V	0.33
26/08/23	V	0.00	V	0.00	V	0.43	V	0.03	V	1.43	V	0.38
27/08/23	V	0.01	V	0.00	V	0.47	V	0.04	V	7.53	V	0.36
28/08/23	V	0.00	V	0.00	V	0.48	V	0.03	V	3.19	V	0.35
29/08/23	V	0.00	V	0.00	V	0.47	V	0.00	V	6.03	V	0.36
30/08/23	V	0.00	V	0.00	V	0.46	V	0.02	V	2.09	V	0.37
31/08/23	V	0.00	V	0.00	V	0.50	V	0.01	V	6.71	V	0.38
MAV		0.05		0.00		0.41		0.02		2.65		0.36

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Aug/ 2023

Date of creation: 01/09/2023 04:32

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/08/23	V	100.29	V	9.54	V	20.65	V	57.78	V	990.19	V	151138.08
02/08/23	V	103.65	V	9.59	V	19.67	V	56.27	V	988.24	V	150775.47
03/08/23	V	106.98	V	9.53	V	21.79	V	59.14	V	988.04	V	151156.52
04/08/23	V	111.65	V	9.78	V	21.32	V	58.70	V	994.20	V	152344.80
05/08/23	V	135.88	V	9.71	V	21.90	V	59.43	V	999.61	V	152158.93
06/08/23	V	123.64	V	9.67	V	22.65	V	59.62	V	989.95	V	149927.09
07/08/23	V	110.63	V	9.64	V	22.43	V	59.20	V	984.06	V	149612.44
08/08/23	V	104.15	V	9.53	V	20.58	V	58.93	V	992.15	V	153819.96
09/08/23	V	107.13	V	9.59	V	20.24	V	59.38	V	1000.01	V	156190.80
10/08/23	V	120.63	V	9.51	V	21.70	V	59.83	V	1005.82	V	154717.64
11/08/23	V	112.19	V	9.60	V	21.33	V	59.47	V	1007.87	V	148586.87
12/08/23	V	102.28	V	9.56	V	21.40	V	59.43	V	1007.30	V	153515.10
13/08/23	V	105.87	V	9.37	V	22.01	V	59.86	V	1003.15	V	151710.61
14/08/23	V	105.62	V	9.65	V	22.08	V	59.90	V	1006.48	V	152795.05
15/08/23	V	103.91	V	9.81	V	21.94	V	59.44	V	1006.87	V	152202.49
16/08/23	V	120.93	V	9.66	V	22.03	V	59.72	V	1005.95	V	151231.45
17/08/23	V	128.10	V	9.86	V	22.29	V	59.77	V	1006.72	V	152332.50
18/08/23	V	140.16	V	9.66	V	22.77	V	60.49	V	1007.74	V	152697.17
19/08/23	V	112.04	V	9.49	V	23.01	V	60.82	V	1007.15	V	152145.37
20/08/23	V	106.42	V	9.72	V	22.11	V	59.61	V	1004.72	V	152077.23
21/08/23	V	111.03	V	9.79	V	22.10	V	59.60	V	1003.95	V	152505.30
22/08/23	V	115.40	V	9.83	V	21.47	V	59.00	V	1003.45	V	152938.41
23/08/23	V	133.83	V	9.76	V	21.84	V	59.67	V	1002.35	V	154369.56
24/08/23	V	136.91	V	9.70	V	22.25	V	60.04	V	1002.11	V	153802.74
25/08/23	V	110.42	V	9.78	V	22.30	V	59.97	V	999.53	V	155118.36
26/08/23	V	109.39	V	9.70	V	22.59	V	59.96	V	995.86	V	152147.16
27/08/23	V	98.60	V	9.80	V	22.18	V	59.23	V	996.59	V	151071.87
28/08/23	V	108.66	V	9.66	V	22.82	V	60.14	V	993.36	V	151525.47
29/08/23	V	113.22	V	9.94	V	22.96	V	60.61	V	995.90	V	155409.73
30/08/23	V	128.58	V	9.44	V	23.89	V	61.24	V	989.78	V	151118.12
31/08/23	V	129.90	V	9.64	V	22.74	V	59.94	V	991.83	V	150495.36
MAV		114.75		9.66		21.97		59.55		999.07		152311.96

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Aug/ 2023

Date of creation: 01/09/2023 04:32

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/08/23	V	956.42				
02/08/23	V	950.54				
03/08/23	V	954.06				
04/08/23	V	948.76				
05/08/23	V	957.31				
06/08/23	V	958.80				
07/08/23	V	963.59				
08/08/23	V	969.37				
09/08/23	V	956.02				
10/08/23	V	964.42				
11/08/23	V	961.85				
12/08/23	V	958.91				
13/08/23	V	968.68				
14/08/23	V	963.18				
15/08/23	V	962.27				
16/08/23	V	967.72				
17/08/23	V	950.80				
18/08/23	V	960.94				
19/08/23	V	960.91				
20/08/23	V	948.39				
21/08/23	V	953.86				
22/08/23	V	951.59				
23/08/23	V	956.84				
24/08/23	V	953.91				
25/08/23	V	945.82				
26/08/23	V	959.63				
27/08/23	V	956.57				
28/08/23	V	957.13				
29/08/23	V	952.85				
30/08/23	V	977.83				
31/08/23	V	960.16				
MAV		958.35				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value