

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Sep/ 2023

Date of creation: 01/10/2023 04:33

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/09/23	V	0.00	V	0.00	V	0.44	V	0.01	V	7.63	V	0.32
02/09/23	V	0.00	V	0.00	V	0.41	V	0.00	V	2.58	V	0.44
03/09/23	V	0.00	V	0.00	V	0.41	V	0.00	V	1.39	V	0.41
04/09/23	V	0.06	V	0.00	V	0.42	V	0.01	V	1.20	V	0.38
05/09/23	V	0.00	V	0.00	V	0.42	V	0.02	V	4.96	V	0.39
06/09/23	V	0.02	V	0.00	V	0.43	V	0.00	V	1.57	V	0.45
07/09/23	V	0.00	V	0.00	V	0.42	V	0.01	V	2.44	V	0.38
08/09/23	V	0.01	V	0.00	V	0.40	V	0.01	V	1.43	V	0.40
09/09/23	V	0.00	V	0.00	V	0.41	V	0.00	V	0.89	V	0.37
10/09/23	V	0.00	V	0.00	V	0.41	V	0.01	V	0.79	V	0.41
11/09/23	V	0.01	V	0.00	V	0.40	V	0.02	V	0.69	V	0.38
12/09/23	V	0.01	V	0.00	V	0.42	V	0.00	V	6.78	V	0.38
13/09/23	V	0.00	V	0.00	V	0.44	V	0.00	V	3.67	V	0.39
14/09/23	V	0.00	V	0.00	V	0.44	V	0.00	V	4.79	V	0.32
15/09/23	V	0.00	V	0.00	V	0.44	V	0.00	V	7.97	V	0.35
16/09/23	V	0.00	V	0.00	V	0.51	V	0.00	V	8.36	V	0.27
17/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
18/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
19/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
23/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
24/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
25/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
26/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		0.01		0.00		0.42		0.01		3.33		0.38

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Sep/ 2023

Date of creation: 01/10/2023 04:33

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/09/23	V	109.71	V	9.74	V	20.04	V	57.28	V	998.39	V	154177.06
02/09/23	V	125.01	V	9.70	V	18.87	V	55.79	V	1002.25	V	154448.45
03/09/23	V	129.03	V	9.62	V	18.41	V	55.31	V	1007.68	V	153204.78
04/09/23	V	130.08	V	9.73	V	18.49	V	55.40	V	1011.81	V	147327.95
05/09/23	V	135.10	V	9.51	V	22.59	V	60.96	V	1010.21	V	153563.54
06/09/23	V	129.13	V	9.65	V	20.21	V	57.56	V	1009.55	V	153310.62
07/09/23	V	111.77	V	9.74	V	17.20	V	54.04	V	1014.93	V	154776.73
08/09/23	V	112.93	V	9.66	V	18.62	V	55.84	V	1010.16	V	154714.71
09/09/23	V	114.20	V	9.66	V	18.93	V	56.10	V	1008.25	V	154897.06
10/09/23	V	120.08	V	9.70	V	18.72	V	55.77	V	1006.61	V	155413.13
11/09/23	V	124.32	V	9.64	V	18.98	V	55.75	V	1001.74	V	152982.57
12/09/23	V	126.76	V	9.79	V	18.86	V	55.40	V	1000.08	V	154126.28
13/09/23	V	126.29	V	9.82	V	18.60	V	54.89	V	998.58	V	153318.45
14/09/23	V	117.33	V	9.55	V	18.46	V	54.86	V	1000.72	V	150913.75
15/09/23	V	109.62	V	9.80	V	18.79	V	56.27	V	1010.74	V	147847.72
16/09/23	V	124.68	V	10.89	V	20.47	V	58.56	V	1014.10	V	124515.74
17/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
18/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
19/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
20/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
21/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
22/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
23/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
24/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
25/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
26/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/09/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		121.56		9.72		19.09		56.14		1006.33		152319.77

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Sep/ 2023

Date of creation: 01/10/2023 04:33

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/09/23	V	967.28				
02/09/23	V	984.10				
03/09/23	V	975.54				
04/09/23	V	971.32				
05/09/23	V	969.02				
06/09/23	V	973.87				
07/09/23	V	973.98				
08/09/23	V	975.83				
09/09/23	V	976.63				
10/09/23	V	978.00				
11/09/23	V	972.16				
12/09/23	V	964.33				
13/09/23	V	960.26				
14/09/23	V	962.85				
15/09/23	V	958.38				
16/09/23	V	917.11				
17/09/23	N	0.00				
18/09/23	N	0.00				
19/09/23	N	0.00				
20/09/23	N	0.00				
21/09/23	N	0.00				
22/09/23	N	0.00				
23/09/23	N	0.00				
24/09/23	N	0.00				
25/09/23	N	0.00				
26/09/23	N	0.00				
27/09/23	N	0.00				
28/09/23	N	0.00				
29/09/23	N	0.00				
30/09/23	N	0.00				
MAV		969.65				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value