

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Oct/ 2023

Date of creation: 01/11/2023 04:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
02/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
03/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/10/23	T	0.00	T	0.00	T	0.00	T	0.00	T	0.00	T	0.00
06/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/10/23	V	0.00	V	0.00	V	11.40	V	0.01	V	17.74	V	0.40
08/10/23	V	0.00	V	0.00	V	0.67	V	0.00	V	17.07	V	0.53
09/10/23	V	0.01	V	0.00	V	0.67	V	0.00	V	6.49	V	0.36
10/10/23	V	0.00	V	0.00	V	0.62	V	0.00	V	5.50	V	0.38
11/10/23	V	0.00	V	0.00	V	0.59	V	0.01	V	1.91	V	0.36
12/10/23	V	0.09	V	0.00	V	0.49	V	0.01	V	13.63	V	0.27
13/10/23	V	0.00	V	0.00	V	0.53	V	0.00	V	3.46	V	0.31
14/10/23	V	0.03	V	0.00	V	0.51	V	0.01	V	1.70	V	0.22
15/10/23	V	0.00	V	0.00	V	0.54	V	0.00	V	2.99	V	0.39
16/10/23	V	0.00	V	0.00	V	0.57	V	0.00	V	1.12	V	0.31
17/10/23	V	0.00	V	0.00	V	0.69	V	0.00	V	2.16	V	0.35
18/10/23	V	0.00	V	0.00	V	0.50	V	0.00	V	2.14	V	0.33
19/10/23	V	0.00	V	0.00	V	0.42	V	0.00	V	3.81	V	0.38
20/10/23	V	0.00	V	0.03	V	0.40	V	0.00	V	1.18	V	0.44
21/10/23	V	0.00	V	0.00	V	0.54	V	0.00	V	4.03	V	0.39
22/10/23	V	0.07	V	0.00	V	2.10	V	0.00	V	2.26	V	0.36
23/10/23	V	0.02	V	0.00	V	0.58	V	0.00	V	0.68	V	0.31
24/10/23	V	0.00	V	0.02	V	0.37	V	0.00	V	1.69	V	0.31
25/10/23	V	0.00	V	0.01	V	0.45	V	0.00	V	2.04	V	0.42
26/10/23	V	0.00	V	0.00	V	0.34	V	0.00	V	2.56	V	0.42
27/10/23	V	0.00	V	0.31	V	0.60	V	0.08	V	5.16	V	0.20
28/10/23	V	0.01	V	0.59	V	1.00	V	0.16	V	9.79	V	0.00
29/10/23	V	0.00	V	0.53	V	1.13	V	0.13	V	8.58	V	0.00
30/10/23	V	0.02	V	0.43	V	1.11	V	0.13	V	8.84	V	0.00
31/10/23	V	0.00	V	0.44	V	1.05	V	0.14	V	9.79	V	0.00
MAV		0.01		0.10		0.87		0.03		5.08		0.29

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Oct/ 2023

Date of creation: 01/11/2023 04:30

Date	NOx		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm <sup>3</sup> /h
	DLV:	200.00										
01/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
02/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
03/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/10/23	T	0.00	T	0.00	T	0.00	T	0.00	T	0.00	T	0.00
06/10/23	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
07/10/23	V	131.01	V	10.47	V	19.77	V	57.12	V	988.85	V	137362.80
08/10/23	V	131.62	V	10.42	V	19.49	V	57.37	V	996.10	V	148074.04
09/10/23	V	104.64	V	9.95	V	19.64	V	57.56	V	1002.23	V	155467.24
10/10/23	V	112.95	V	9.80	V	18.09	V	55.58	V	1004.63	V	156051.31
11/10/23	V	117.89	V	9.65	V	17.19	V	54.07	V	997.15	V	154460.67
12/10/23	V	109.08	V	9.70	V	17.71	V	53.98	V	990.24	V	153725.80
13/10/23	V	132.34	V	9.93	V	17.75	V	54.67	V	998.36	V	157736.94
14/10/23	V	125.48	V	9.67	V	20.51	V	57.52	V	986.86	V	151668.06
15/10/23	V	126.36	V	9.50	V	19.68	V	57.26	V	990.20	V	153132.55
16/10/23	V	127.51	V	9.57	V	16.90	V	53.62	V	995.16	V	153981.13
17/10/23	V	124.37	V	9.77	V	16.77	V	53.83	V	1001.22	V	156123.07
18/10/23	V	125.07	V	9.60	V	17.50	V	54.59	V	996.18	V	154106.61
19/10/23	V	119.56	V	9.68	V	16.96	V	54.15	V	997.31	V	155274.67
20/10/23	V	121.24	V	9.63	V	14.63	V	50.58	V	993.14	V	155851.58
21/10/23	V	121.74	V	9.70	V	16.96	V	54.00	V	994.04	V	155437.87
22/10/23	V	125.73	V	9.58	V	18.11	V	55.17	V	994.55	V	154098.30
23/10/23	V	122.67	V	9.66	V	14.36	V	48.99	V	995.73	V	155233.18
24/10/23	V	128.61	V	9.86	V	11.41	V	44.26	V	999.84	V	157540.96
25/10/23	V	115.81	V	9.74	V	13.58	V	48.11	V	993.24	V	156356.91
26/10/23	V	120.01	V	9.74	V	10.98	V	43.56	V	986.24	V	156379.84
27/10/23	V	117.77	V	9.53	V	10.07	V	42.40	V	982.15	V	133951.56
28/10/23	V	116.05	V	9.18	V	9.54	V	42.13	V	985.94	V	105698.41
29/10/23	V	104.64	V	9.54	V	13.43	V	49.26	V	994.82	V	107567.49
30/10/23	V	117.24	V	9.40	V	17.61	V	55.31	V	990.13	V	104918.84
31/10/23	V	115.42	V	9.44	V	17.70	V	55.14	V	986.43	V	104854.77
MAV		120.26		9.68		16.11		52.21		993.70		145349.31

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: Oct/ 2023

Date of creation: 01/11/2023 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/10/23	N	0.00				
02/10/23	N	0.00				
03/10/23	N	0.00				
04/10/23	N	0.00				
05/10/23	T	495.85				
06/10/23	N	0.00				
07/10/23	V	919.18				
08/10/23	V	943.73				
09/10/23	V	964.92				
10/10/23	V	962.75				
11/10/23	V	971.89				
12/10/23	V	958.48				
13/10/23	V	957.33				
14/10/23	V	959.51				
15/10/23	V	957.46				
16/10/23	V	955.29				
17/10/23	V	949.76				
18/10/23	V	955.11				
19/10/23	V	955.48				
20/10/23	V	956.80				
21/10/23	V	969.53				
22/10/23	V	966.25				
23/10/23	V	972.32				
24/10/23	V	970.48				
25/10/23	V	969.34				
26/10/23	V	963.77				
27/10/23	V	969.16				
28/10/23	V	968.97				
29/10/23	V	965.46				
30/10/23	V	969.70				
31/10/23	V	979.19				
MAV		962.09				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value