

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Nov/ 2023

Date of creation: 01/12/2023 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/11/23	V	0.00	V	0.45	V	1.05	V	0.08	V	9.46	V	0.00
02/11/23	V	0.00	V	0.53	V	1.07	V	0.08	V	10.79	V	0.00
03/11/23	V	0.00	V	0.34	V	0.67	V	0.05	V	8.30	V	0.17
04/11/23	V	0.04	V	0.00	V	0.34	V	0.00	V	6.14	V	0.36
05/11/23	V	0.08	V	0.00	V	0.34	V	0.00	V	6.07	V	0.32
06/11/23	V	0.02	V	0.00	V	0.32	V	0.00	V	6.21	V	0.32
07/11/23	V	0.00	V	0.00	V	0.34	V	0.00	V	7.20	V	0.37
08/11/23	V	0.03	V	0.00	V	0.35	V	0.00	V	7.42	V	0.44
09/11/23	V	0.00	V	0.00	V	0.36	V	0.00	V	9.24	V	0.47
10/11/23	V	0.00	V	0.00	V	0.38	V	0.00	V	10.10	V	0.40
11/11/23	V	0.02	V	0.00	V	0.36	V	0.00	V	3.92	V	0.40
12/11/23	V	0.00	V	0.00	V	0.37	V	0.00	V	3.52	V	0.43
13/11/23	V	0.00	V	0.00	V	0.36	V	0.00	V	12.12	V	0.44
14/11/23	V	0.00	V	0.01	V	0.38	V	0.00	V	11.31	V	0.38
15/11/23	V	0.00	V	0.01	V	0.40	V	0.00	V	8.91	V	0.40
16/11/23	V	0.04	V	0.00	V	0.36	V	0.00	V	6.03	V	0.70
17/11/23	V	0.00	V	0.00	V	0.34	V	0.00	V	6.47	V	0.66
18/11/23	V	0.03	V	0.00	V	0.32	V	0.00	V	4.33	V	0.53
19/11/23	V	0.03	V	0.01	V	0.31	V	0.00	V	4.83	V	0.77
20/11/23	V	0.00	V	0.00	V	0.31	V	0.00	V	6.84	V	0.70
21/11/23	V	0.00	V	0.00	V	0.30	V	0.00	V	9.54	V	0.51
22/11/23	V	0.00	V	0.01	V	0.28	V	0.03	V	8.91	V	0.53
23/11/23	V	0.05	V	0.01	V	0.28	V	0.01	V	7.31	V	0.45
24/11/23	V	0.00	V	0.36	V	0.75	V	0.08	V	10.40	V	0.31
25/11/23	V	0.00	V	0.53	V	0.94	V	0.10	V	13.02	V	0.37
26/11/23	V	0.00	V	0.54	V	0.90	V	0.10	V	10.78	V	0.34
27/11/23	V	0.00	V	0.67	V	0.83	V	0.04	V	13.84	V	0.24
28/11/23	V	0.00	V	0.58	V	0.86	V	0.05	V	11.14	V	0.40
29/11/23	V	0.00	V	0.63	V	0.84	V	0.07	V	8.18	V	0.29
30/11/23	V	0.00	V	0.60	V	0.90	V	0.09	V	7.47	V	0.36
MAV		0.01		0.17		0.52		0.03		8.32		0.40

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Nov/ 2023

Date of creation: 01/12/2023 04:30

Date	NOx		NH ₃		O ₂		H ₂ O		Kamino T		Slėgis	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	200.00	DLV:	10.00								
01/11/23	V	110.47			V	9.41	V	16.35	V	53.39	V	990.03
02/11/23	V	107.90			V	9.59	V	14.14	V	50.07	V	992.61
03/11/23	V	135.66			V	9.49	V	12.95	V	47.57	V	984.28
04/11/23	V	135.44			V	9.81	V	15.11	V	50.39	V	979.88
05/11/23	V	137.03			V	9.74	V	14.51	V	49.47	V	976.84
06/11/23	V	132.53			V	9.79	V	13.36	V	47.10	V	978.98
07/11/23	V	120.63			V	9.78	V	13.88	V	48.71	V	993.52
08/11/23	V	123.90			V	9.85	V	13.76	V	48.58	V	995.51
09/11/23	V	139.52			V	10.17	V	13.63	V	47.76	V	996.81
10/11/23	V	140.85			V	9.99	V	15.20	V	50.93	V	992.54
11/11/23	V	147.35			V	9.74	V	17.56	V	54.45	V	989.76
12/11/23	V	143.89			V	9.51	V	17.89	V	54.77	V	986.72
13/11/23	V	130.32			V	9.33	V	15.81	V	51.87	V	989.87
14/11/23	V	125.24			V	9.57	V	14.62	V	49.75	V	986.43
15/11/23	V	132.61	V	0.08	V	9.65	V	13.61	V	48.64	V	988.88
16/11/23	V	120.94	V	0.10	V	9.86	V	11.73	V	45.40	V	1000.71
17/11/23	V	128.99	V	0.42	V	9.96	V	10.51	V	43.47	V	1004.05
18/11/23	V	130.19	V	0.09	V	9.99	V	10.15	V	42.99	V	1009.50
19/11/23	V	122.66	V	0.37	V	9.61	V	11.39	V	45.08	V	1003.79
20/11/23	V	122.64	V	0.01	V	9.60	V	9.43	V	41.96	V	999.12
21/11/23	V	125.24	V	0.01	V	9.66	V	9.70	V	42.72	V	1004.75
22/11/23	V	128.80	V	0.02	V	9.84	V	9.49	V	42.66	V	1010.69
23/11/23	V	135.02	V	0.29	V	9.59	V	10.45	V	43.18	V	980.52
24/11/23	V	125.96	V	0.13	V	9.24	V	9.00	V	40.92	V	968.47
25/11/23	V	122.22	V	0.12	V	9.24	V	8.84	V	41.63	V	978.49
26/11/23	V	120.38	V	0.10	V	9.17	V	8.92	V	42.41	V	988.15
27/11/23	V	112.86	V	0.12	V	9.14	V	9.02	V	42.98	V	989.66
28/11/23	V	117.23	V	0.15	V	9.30	V	9.40	V	43.73	V	985.40
29/11/23	V	125.79	V	0.32	V	9.29	V	9.51	V	43.96	V	990.09
30/11/23	V	114.51	V	0.33	V	9.77	V	7.80	V	41.69	V	989.25
MAV		127.21		0.17		9.62		12.26		46.60		990.85

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Nov/ 2023

Date of creation: 01/12/2023 04:30

Date	Srautas		Degimo T					
	Unit:	Nm³/h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/11/23	V	105346.25	V	974.55				
02/11/23	V	107164.89	V	954.54				
03/11/23	V	124862.93	V	983.53				
04/11/23	V	152344.24	V	992.91				
05/11/23	V	152260.69	V	996.69				
06/11/23	V	154218.72	V	992.63				
07/11/23	V	154963.94	V	991.09				
08/11/23	V	156060.61	V	986.53				
09/11/23	V	152421.19	V	978.06				
10/11/23	V	156606.71	V	969.00				
11/11/23	V	153138.06	V	987.47				
12/11/23	V	149965.19	V	981.19				
13/11/23	V	148833.19	V	975.75				
14/11/23	V	152612.72	V	970.10				
15/11/23	V	153647.67	V	972.26				
16/11/23	V	156898.73	V	962.92				
17/11/23	V	160468.48	V	963.78				
18/11/23	V	161639.54	V	974.49				
19/11/23	V	157169.20	V	981.09				
20/11/23	V	157790.46	V	981.98				
21/11/23	V	158085.59	V	976.89				
22/11/23	V	159815.29	V	970.29				
23/11/23	V	155371.88	V	970.34				
24/11/23	V	133706.03	V	971.31				
25/11/23	V	123456.28	V	977.65				
26/11/23	V	123994.90	V	982.19				
27/11/23	V	124141.53	V	970.71				
28/11/23	V	124746.12	V	964.59				
29/11/23	V	124613.20	V	969.05				
30/11/23	V	126324.61	V	969.57				
MAV		144105.27		976.48				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value