

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2023

Date of creation: 01/01/2024 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/12/23	V	0.04	V	0.60	V	1.38	V	0.07	V	7.96	V	0.30
02/12/23	V	0.02	V	0.65	V	1.39	V	0.08	V	4.52	V	0.22
03/12/23	V	0.00	V	0.57	V	1.41	V	0.11	V	5.85	V	0.31
04/12/23	M	0.15	M	0.67	M	1.36	M	0.06	M	4.28	M	0.34
05/12/23	M	0.00	M	0.64	M	1.44	M	0.06	M	5.17	M	0.21
06/12/23	V	0.00	V	0.57	V	1.49	V	0.04	V	8.37	V	0.27
07/12/23	V	0.00	V	0.61	V	1.48	V	0.15	V	8.45	V	0.37
08/12/23	V	0.00	V	0.53	V	1.50	V	0.08	V	7.40	V	0.40
09/12/23	V	0.00	V	0.54	V	1.46	V	0.13	V	6.48	V	0.58
10/12/23	V	0.04	V	0.60	V	1.40	V	0.14	V	7.32	V	0.25
11/12/23	V	0.04	V	0.55	V	1.34	V	0.12	V	6.90	V	0.22
12/12/23	V	0.02	V	0.57	V	1.39	V	0.23	V	5.68	V	0.18
13/12/23	V	0.00	V	0.59	V	1.40	V	0.26	V	3.57	V	0.18
14/12/23	V	0.00	V	0.60	V	1.38	V	0.04	V	7.48	V	0.20
15/12/23	V	0.00	V	0.56	V	1.42	V	0.04	V	6.05	V	0.25
16/12/23	V	0.01	V	0.54	V	1.38	V	0.13	V	2.57	V	0.58
17/12/23	V	0.01	V	0.54	V	1.38	V	0.15	V	5.41	V	0.33
18/12/23	V	0.00	V	0.57	V	1.40	V	0.10	V	5.24	V	0.18
19/12/23	V	0.01	V	0.60	V	1.39	V	0.05	V	6.76	V	0.21
20/12/23	V	0.00	V	0.56	V	1.34	V	0.01	V	7.09	V	0.23
21/12/23	V	0.00	V	0.47	V	1.60	V	0.03	V	7.05	V	0.27
22/12/23	V	0.00	V	0.47	V	1.25	V	0.01	V	5.36	V	0.32
23/12/23	V	0.00	V	0.51	V	1.26	V	0.02	V	2.46	V	0.50
24/12/23	V	0.00	V	0.53	V	1.29	V	0.01	V	4.56	V	0.40
25/12/23	V	0.01	V	0.53	V	1.32	V	0.05	V	5.76	V	0.38
26/12/23	V	0.00	V	0.48	V	1.34	V	0.02	V	6.32	V	0.32
27/12/23	V	0.02	V	0.45	V	1.39	V	0.03	V	10.28	V	0.22
28/12/23	V	0.00	V	0.53	V	1.35	V	0.02	V	6.91	V	0.29
29/12/23	V	0.00	V	0.47	V	1.37	V	0.01	V	7.60	V	0.40
30/12/23	V	0.03	V	0.49	V	1.38	V	0.03	V	6.26	V	0.43
31/12/23	V	0.00	V	0.47	V	1.34	V	0.02	V	10.06	V	0.30
MAV		0.01		0.55		1.39		0.08		6.34		0.31

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Dec/ 2023

Date of creation: 01/01/2024 04:30

Date	NOx		NH ₃		O ₂		H ₂ O		Kamino T		Slėgis	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	200.00	DLV:	10.00								
01/12/23	V	121.80	V	0.39	V	11.07	V	4.01	V	41.25	V	987.42
02/12/23	V	122.56	V	0.92	V	11.08	V	4.22	V	41.20	V	993.44
03/12/23	V	124.53	V	0.51	V	11.07	V	4.07	V	41.40	V	997.92
04/12/23	M	124.72	M	0.46	M	10.85	M	4.45	V	41.94	V	1001.04
05/12/23	M	115.74	M	0.02	M	11.28	M	3.96	V	41.11	V	1006.47
06/12/23	V	108.22	V	0.06	V	11.15	V	4.24	V	42.07	V	1009.66
07/12/23	V	105.75	V	0.13	V	11.17	V	4.27	V	42.41	V	1012.22
08/12/23	V	107.49	V	0.76	V	11.25	V	5.24	V	44.65	V	1010.66
09/12/23	V	107.80	V	0.57	V	11.19	V	4.97	V	44.04	V	1005.46
10/12/23	V	106.23	V	6.08	V	11.09	V	4.39	V	42.47	V	998.97
11/12/23	V	98.01	V	0.65	V	10.92	V	4.24	V	41.78	V	990.06
12/12/23	V	94.21	V	0.15	V	11.27	V	4.43	V	41.41	V	988.65
13/12/23	V	89.49	V	0.93	V	11.27	V	4.73	V	42.05	V	993.74
14/12/23	V	95.01	V	1.08	V	11.02	V	4.38	V	42.07	V	998.61
15/12/23	V	96.86	V	0.75	V	11.13	V	4.55	V	42.41	V	1008.36
16/12/23	V	97.46	V	0.71	V	11.02	V	5.76	V	44.17	V	1010.13
17/12/23	V	97.94	V	0.59	V	11.06	V	6.62	V	45.57	V	1004.17
18/12/23	V	100.24	V	0.89	V	11.03	V	8.02	V	47.77	V	1002.38
19/12/23	V	103.66	V	1.27	V	10.99	V	9.97	V	50.41	V	994.01
20/12/23	V	101.65	V	1.56	V	10.88	V	7.60	V	46.75	V	985.76
21/12/23	V	104.38	V	0.87	V	10.84	V	6.48	V	44.94	V	973.17
22/12/23	V	113.38	V	0.38	V	10.74	V	6.29	V	44.47	V	957.16
23/12/23	V	106.18	V	1.04	V	10.55	V	6.72	V	44.52	V	963.38
24/12/23	V	101.35	V	0.56	V	10.77	V	5.10	V	42.85	V	979.96
25/12/23	V	99.64	V	2.63	V	10.92	V	8.85	V	48.16	V	971.15
26/12/23	V	112.43	V	1.93	V	10.90	V	8.63	V	47.65	V	981.97
27/12/23	V	117.25	V	1.38	V	11.25	V	7.44	V	46.10	V	994.46
28/12/23	V	112.95	V	0.94	V	11.11	V	5.54	V	44.32	V	998.05
29/12/23	V	119.39	V	2.24	V	11.02	V	9.85	V	49.96	V	989.19
30/12/23	V	114.09	V	1.75	V	11.08	V	9.60	V	49.63	V	988.40
31/12/23	V	108.93	V	1.16	V	10.90	V	6.52	V	45.04	V	998.06
MAV		106.96		1.10		11.03		6.03		44.35		993.39

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Dec/ 2023

Date of creation: 01/01/2024 04:30

Date	Srautas		Degimo T					
	Unit:	Nm³/h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/12/23	V	130427.72	V	967.88				
02/12/23	V	129944.96	V	975.62				
03/12/23	V	130632.63	V	979.01				
04/12/23	V	134255.36	M	988.42				
05/12/23	V	134991.26	M	968.54				
06/12/23	V	131872.68	V	970.78				
07/12/23	V	132182.47	V	973.93				
08/12/23	V	133161.20	V	966.70				
09/12/23	V	133652.44	V	975.00				
10/12/23	V	131478.56	V	970.29				
11/12/23	V	130499.75	V	983.48				
12/12/23	V	131786.94	V	995.07				
13/12/23	V	131138.29	V	990.42				
14/12/23	V	130742.81	V	975.84				
15/12/23	V	130774.65	V	975.36				
16/12/23	V	129597.07	V	978.11				
17/12/23	V	128507.07	V	974.27				
18/12/23	V	127263.68	V	973.62				
19/12/23	V	127268.70	V	976.46				
20/12/23	V	127381.82	V	976.22				
21/12/23	V	127394.09	V	967.46				
22/12/23	V	127119.23	V	969.56				
23/12/23	V	125968.10	V	969.35				
24/12/23	V	129172.97	V	963.72				
25/12/23	V	127267.52	V	964.59				
26/12/23	V	127526.71	V	960.90				
27/12/23	V	130158.14	V	964.29				
28/12/23	V	131267.83	V	964.09				
29/12/23	V	127676.75	V	962.31				
30/12/23	V	127899.20	V	965.52				
31/12/23	V	128484.09	V	973.43				
MAV		129919.63		972.68				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value