

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2024

Date of creation: 01/02/2024 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/01/24	V	0.00	V	0.61	V	1.37	V	0.02	V	7.19	V	0.32
02/01/24	V	0.00	V	0.53	V	1.42	V	0.04	V	9.29	V	0.19
03/01/24	V	0.00	V	0.52	V	1.42	V	0.07	V	8.26	V	0.25
04/01/24	V	0.00	V	0.48	V	1.43	V	0.02	V	6.09	V	0.26
05/01/24	V	0.01	V	0.43	V	1.48	V	0.05	V	5.17	V	0.24
06/01/24	V	0.02	V	0.46	V	1.54	V	0.09	V	7.63	V	0.17
07/01/24	V	0.00	V	0.51	V	1.48	V	0.02	V	4.83	V	0.35
08/01/24	V	0.00	V	0.49	V	1.49	V	0.04	V	4.40	V	0.26
09/01/24	V	0.00	V	0.53	V	1.50	V	0.12	V	2.93	V	0.32
10/01/24	V	0.00	V	0.54	V	1.37	V	0.15	V	1.76	V	0.54
11/01/24	V	0.00	V	0.51	V	1.40	V	0.11	V	5.71	V	0.39
12/01/24	V	0.00	V	0.54	V	1.39	V	0.05	V	4.59	V	0.15
13/01/24	V	0.00	V	0.53	V	1.36	V	0.03	V	6.78	V	0.16
14/01/24	V	0.02	V	0.52	V	1.30	V	0.07	V	3.69	V	0.36
15/01/24	V	0.00	V	0.48	V	1.26	V	0.06	V	5.17	V	0.42
16/01/24	V	0.00	V	0.52	V	1.37	V	0.02	V	10.55	V	0.21
17/01/24	V	0.00	V	0.47	V	1.45	V	0.05	V	11.62	V	0.13
18/01/24	V	0.00	V	0.51	V	1.35	V	0.09	V	5.24	V	0.23
19/01/24	V	0.00	V	0.53	V	1.37	V	0.10	V	5.51	V	0.44
20/01/24	V	0.00	V	0.53	V	1.39	V	0.13	V	4.49	V	0.40
21/01/24	V	0.00	V	0.49	V	1.41	V	0.05	V	5.72	V	0.39
22/01/24	V	0.00	V	0.46	V	1.36	V	0.08	V	4.82	V	0.38
23/01/24	V	0.00	V	0.54	V	0.85	V	0.17	V	7.80	V	0.40
24/01/24	V	0.00	V	0.57	V	0.63	V	0.22	V	7.60	V	0.30
25/01/24	V	0.00	V	0.56	V	0.69	V	0.17	V	5.26	V	0.27
26/01/24	V	0.00	V	0.51	V	0.69	V	0.14	V	6.06	V	0.35
27/01/24	V	0.00	V	0.53	V	0.70	V	0.12	V	7.10	V	0.29
28/01/24	V	0.00	V	0.60	V	0.64	V	0.14	V	6.23	V	0.34
29/01/24	V	0.00	V	0.47	V	0.65	V	0.13	V	5.20	V	0.36
30/01/24	V	0.00	V	0.56	V	0.64	V	0.19	V	7.16	V	0.35
31/01/24	V	0.00	V	0.55	V	0.64	V	0.20	V	6.66	V	0.35
MAV		0.00		0.52		1.19		0.09		6.13		0.31

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jan/ 2024

Date of creation: 01/02/2024 04:30

Date	NOx		NH ₃		O ₂		H ₂ O		Kamino T		Slėgis	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	200.00	DLV:	10.00								
01/01/24	V	110.66	V	0.75	V	10.84	V	6.13	V	45.19	V	996.80
02/01/24	V	115.95	V	0.68	V	10.88	V	6.46	V	46.12	V	995.71
03/01/24	V	113.24	V	0.86	V	10.93	V	6.99	V	47.00	V	988.14
04/01/24	V	110.38	V	0.87	V	10.84	V	8.26	V	48.72	V	982.26
05/01/24	V	118.60	V	1.01	V	11.05	V	10.16	V	51.15	V	989.99
06/01/24	V	124.53	V	1.42	V	11.30	V	9.82	V	51.31	V	1001.41
07/01/24	V	121.85	V	0.76	V	11.05	V	7.89	V	50.86	V	1012.47
08/01/24	V	119.48	V	0.20	V	10.97	V	7.08	V	49.75	V	1020.23
09/01/24	V	111.30	V	0.63	V	11.30	V	7.45	V	48.10	V	1016.94
10/01/24	V	119.75	V	0.24	V	11.10	V	5.68	V	44.51	V	1010.40
11/01/24	V	127.31	V	0.12	V	11.19	V	5.31	V	44.07	V	1001.85
12/01/24	V	124.37	V	0.39	V	11.01	V	6.39	V	46.17	V	1001.21
13/01/24	V	136.67	V	0.11	V	10.68	V	6.16	V	46.13	V	995.31
14/01/24	V	136.90	V	0.08	V	10.79	V	6.40	V	45.18	V	977.06
15/01/24	V	127.56	V	0.06	V	10.75	V	5.82	V	44.15	V	969.68
16/01/24	V	146.90	V	0.14	V	10.97	V	7.00	V	46.55	V	980.50
17/01/24	V	116.15	V	1.06	V	11.18	V	7.82	V	48.73	V	991.65
18/01/24	V	123.82	V	0.59	V	11.01	V	6.52	V	45.78	V	977.88
19/01/24	V	124.15	V	0.50	V	11.08	V	5.68	V	44.51	V	990.54
20/01/24	V	118.63	V	0.88	V	11.20	V	5.41	V	44.32	V	998.80
21/01/24	V	122.30	V	0.59	V	11.10	V	5.75	V	45.29	V	1014.53
22/01/24	V	120.22	V	0.17	V	11.05	V	5.60	V	44.87	V	1000.61
23/01/24	V	100.34	V	0.09	V	9.59	V	8.42	V	44.13	V	996.19
24/01/24	V	100.11	V	0.17	V	8.71	V	9.54	V	43.07	V	988.80
25/01/24	V	109.74	V	0.38	V	8.64	V	10.79	V	45.01	V	986.60
26/01/24	V	108.91	V	0.07	V	8.88	V	9.59	V	44.16	V	1002.71
27/01/24	V	102.36	V	0.06	V	8.75	V	9.41	V	43.67	V	1004.05
28/01/24	V	104.85	V	0.09	V	8.75	V	8.95	V	42.87	V	1018.37
29/01/24	V	106.91	V	0.23	V	8.58	V	9.87	V	44.65	V	1020.22
30/01/24	V	114.32	V	0.01	V	8.85	V	8.78	V	42.25	V	1015.19
31/01/24	V	115.39	V	0.13	V	8.67	V	9.59	V	43.79	V	1008.75
MAV		117.88		0.43		10.37		7.57		45.85		998.64

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jan/ 2024

Date of creation: 01/02/2024 04:30

Date	Srautas		Degimo T					
	Unit:	Nm³/h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/01/24	V	129206.98	V	972.86				
02/01/24	V	128646.24	V	968.49				
03/01/24	V	127694.55	V	962.34				
04/01/24	V	128075.15	V	963.28				
05/01/24	V	129874.26	V	973.09				
06/01/24	V	133059.77	V	965.28				
07/01/24	V	135073.07	V	968.38				
08/01/24	V	135588.51	V	970.49				
09/01/24	V	131395.67	V	964.38				
10/01/24	V	129861.96	V	966.01				
11/01/24	V	130585.18	V	954.50				
12/01/24	V	129674.45	V	960.12				
13/01/24	V	127980.60	V	966.87				
14/01/24	V	126584.85	V	963.60				
15/01/24	V	126732.09	V	965.94				
16/01/24	V	129403.61	V	959.97				
17/01/24	V	132541.71	V	960.02				
18/01/24	V	129118.48	V	962.70				
19/01/24	V	129146.28	V	963.21				
20/01/24	V	131763.44	V	980.45				
21/01/24	V	131726.46	V	979.71				
22/01/24	V	132269.95	V	972.97				
23/01/24	V	129125.88	V	961.51				
24/01/24	V	124172.16	V	968.27				
25/01/24	V	123378.14	V	965.10				
26/01/24	V	127382.19	V	963.76				
27/01/24	V	126190.81	V	964.49				
28/01/24	V	126676.21	V	969.93				
29/01/24	V	125773.65	V	978.42				
30/01/24	V	123232.34	V	957.57				
31/01/24	V	124960.77	V	967.18				
MAV		128914.96		966.50				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value