

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2024

Date of creation: 01/04/2024 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/03/24	V	0.00	V	0.37	V	0.84	V	0.13	V	11.13	V	0.21
02/03/24	V	0.00	V	0.46	V	0.88	V	0.12	V	7.66	V	0.15
03/03/24	V	0.00	V	0.44	V	0.90	V	0.11	V	11.87	V	0.20
04/03/24	V	0.00	V	0.54	V	0.88	V	0.26	V	13.40	V	0.21
05/03/24	V	0.00	V	0.50	V	0.87	V	0.24	V	9.72	V	0.24
06/03/24	V	0.00	V	0.47	V	0.85	V	0.26	V	7.26	V	0.39
07/03/24	V	0.01	V	0.47	V	0.86	V	0.23	V	4.82	V	0.27
08/03/24	V	0.00	V	0.50	V	0.83	V	0.26	V	6.04	V	0.29
09/03/24	V	0.00	V	0.52	V	0.82	V	0.20	V	5.80	V	0.22
10/03/24	V	0.00	V	0.46	V	0.86	V	0.20	V	6.50	V	0.38
11/03/24	V	0.00	V	0.45	V	0.89	V	0.22	V	5.14	V	0.21
12/03/24	V	0.00	V	0.34	V	0.85	V	0.25	V	5.86	V	0.39
13/03/24	V	0.00	V	0.35	V	0.83	V	0.19	V	6.35	V	0.58
14/03/24	V	0.00	V	0.39	V	0.85	V	0.17	V	5.17	V	0.77
15/03/24	V	0.00	V	0.42	V	0.87	V	0.16	V	5.23	V	0.32
16/03/24	V	0.00	V	0.42	V	0.88	V	0.22	V	4.97	V	0.20
17/03/24	V	0.01	V	0.50	V	0.87	V	0.16	V	5.26	V	0.17
18/03/24	V	0.00	V	0.41	V	0.87	V	0.22	V	5.71	V	0.25
19/03/24	V	0.00	V	0.43	V	0.87	V	0.12	V	8.23	V	0.19
20/03/24	V	0.00	V	0.54	V	0.90	V	0.19	V	5.96	V	0.26
21/03/24	V	0.00	V	0.40	V	0.90	V	0.24	V	6.43	V	0.15
22/03/24	V	0.00	V	0.39	V	0.88	V	0.19	V	5.59	V	0.23
23/03/24	V	0.00	V	0.49	V	0.90	V	0.16	V	5.51	V	0.28
24/03/24	V	0.00	V	0.51	V	0.88	V	0.10	V	6.50	V	0.19
25/03/24	V	0.00	V	0.44	V	0.86	V	0.12	V	6.30	V	0.22
26/03/24	V	0.00	V	0.45	V	0.88	V	0.13	V	7.71	V	0.19
27/03/24	V	0.00	V	0.44	V	0.92	V	0.08	V	7.66	V	0.29
28/03/24	V	0.00	V	0.46	V	0.90	V	0.14	V	6.40	V	0.30
29/03/24	V	0.02	V	0.43	V	0.88	V	0.06	V	6.29	V	0.53
30/03/24	V	0.01	V	0.48	V	0.91	V	0.06	V	4.73	V	0.46
31/03/24	V	0.00	V	0.39	V	0.89	V	0.05	V	4.47	V	0.15
MAV		0.00		0.45		0.87		0.17		6.75		0.29

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Mar/ 2024

Date of creation: 01/04/2024 04:30

Date	NOx		NH ₃		O ₂		H ₂ O		Kamino T		Slėgis	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	200.00	DLV:	10.00								
01/03/24	V	114.15	V	0.87	V	8.44	V	15.70	V	54.29	V	1005.93
02/03/24	V	122.25	V	0.42	V	8.53	V	16.56	V	55.72	V	1004.61
03/03/24	V	115.18	V	0.90	V	8.65	V	16.34	V	55.48	V	1004.48
04/03/24	V	113.70	V	0.25	V	8.94	V	12.41	V	48.97	V	1004.08
05/03/24	V	107.64	V	0.28	V	8.79	V	14.81	V	53.37	V	1006.82
06/03/24	V	115.44	V	0.09	V	8.77	V	12.34	V	49.18	V	1013.68
07/03/24	V	112.96	V	0.12	V	8.61	V	11.89	V	48.31	V	1013.73
08/03/24	V	112.31	V	0.04	V	8.74	V	9.80	V	44.47	V	1008.63
09/03/24	V	118.26	V	0.04	V	8.73	V	10.13	V	44.85	V	1006.38
10/03/24	V	113.49	V	0.10	V	8.55	V	12.35	V	49.16	V	1007.57
11/03/24	V	112.92	V	0.50	V	8.59	V	12.99	V	50.54	V	1007.91
12/03/24	V	116.49	V	0.52	V	8.46	V	12.85	V	49.79	V	1003.97
13/03/24	V	118.76	V	0.39	V	8.46	V	13.93	V	51.55	V	1004.40
14/03/24	V	113.60	V	0.27	V	8.65	V	14.20	V	51.92	V	1003.99
15/03/24	V	112.48	V	0.57	V	8.74	V	15.30	V	54.00	V	1001.62
16/03/24	V	110.99	V	0.66	V	8.60	V	15.99	V	54.62	V	997.41
17/03/24	V	114.90	V	0.77	V	8.49	V	15.13	V	53.10	V	998.35
18/03/24	V	113.18	V	0.39	V	8.77	V	15.04	V	53.69	V	1003.71
19/03/24	V	121.04	V	0.36	V	9.08	V	13.90	V	51.99	V	1008.73
20/03/24	V	133.46	V	0.31	V	9.17	V	14.03	V	52.03	V	1009.45
21/03/24	V	124.68	V	0.21	V	9.14	V	14.43	V	52.81	V	1006.46
22/03/24	V	117.44	V	0.12	V	8.91	V	14.68	V	52.73	V	997.95
23/03/24	V	115.13	V	0.31	V	8.95	V	15.07	V	52.96	V	987.79
24/03/24	V	116.21	V	0.30	V	8.86	V	14.42	V	51.94	V	986.27
25/03/24	V	124.69	V	0.21	V	8.82	V	14.53	V	52.33	V	989.57
26/03/24	V	116.90	V	0.39	V	8.87	V	15.04	V	53.39	V	994.71
27/03/24	V	114.27	V	0.52	V	9.08	V	14.65	V	52.66	V	990.97
28/03/24	V	123.25	V	0.22	V	9.07	V	14.80	V	52.51	V	983.70
29/03/24	V	110.05	V	1.61	V	8.96	V	15.42	V	53.25	V	987.32
30/03/24	V	114.71	V	1.36	V	8.91	V	16.35	V	54.99	V	992.80
31/03/24	V	118.42	V	1.13	V	8.77	V	17.71	V	56.61	V	989.92
MAV		116.42		0.46		8.78		14.28		52.03		1000.73

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant:

Report time: Mar/ 2024

Date of creation: 01/04/2024 04:30

Date	Srautas		Degimo T					
	Unit:	Nm³/h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/03/24	V	121813.18	V	980.66				
02/03/24	V	121426.06	V	985.09				
03/03/24	V	123231.53	V	983.62				
04/03/24	V	124522.94	V	985.66				
05/03/24	V	123773.72	V	998.16				
06/03/24	V	123316.01	V	1003.90				
07/03/24	V	122322.80	V	992.61				
08/03/24	V	123659.66	V	981.53				
09/03/24	V	123227.11	V	983.84				
10/03/24	V	121107.83	V	991.86				
11/03/24	V	122179.20	V	987.08				
12/03/24	V	120546.69	V	985.30				
13/03/24	V	119697.24	V	977.95				
14/03/24	V	120174.29	V	982.08				
15/03/24	V	120893.02	V	989.98				
16/03/24	V	119801.91	V	984.79				
17/03/24	V	119654.14	V	982.25				
18/03/24	V	124735.18	V	977.41				
19/03/24	V	126924.67	V	970.48				
20/03/24	V	127873.25	V	962.89				
21/03/24	V	127297.64	V	963.29				
22/03/24	V	124504.35	V	970.89				
23/03/24	V	124161.99	V	974.26				
24/03/24	V	124163.12	V	980.17				
25/03/24	V	124774.76	V	976.16				
26/03/24	V	124692.64	V	974.75				
27/03/24	V	124762.44	V	969.35				
28/03/24	V	124164.48	V	968.55				
29/03/24	V	123932.57	V	968.05				
30/03/24	V	124285.96	V	975.08				
31/03/24	V	123618.46	V	981.36				
MAV		123264.07		980.29				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value