

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2024

Date of creation: 01/05/2024 05:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	5.00	DLV:	6.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/04/24	V	0.01	V	0.39	V	0.93	V	0.10	V	5.88	V	0.14
02/04/24	V	0.00	V	0.36	V	0.93	V	0.09	V	6.55	V	0.13
03/04/24	V	0.00	V	0.48	V	0.94	V	0.06	V	8.52	V	0.38
04/04/24	V	0.00	V	0.49	V	0.95	V	0.08	V	8.60	V	0.65
05/04/24	V	0.01	V	0.39	V	0.89	V	0.18	V	9.98	V	0.32
06/04/24	V	0.00	V	0.38	V	0.89	V	0.25	V	6.56	V	0.27
07/04/24	V	0.00	V	0.48	V	0.88	V	0.14	V	6.92	V	0.26
08/04/24	V	0.03	V	0.38	V	0.90	V	0.12	V	5.78	V	0.06
09/04/24	V	0.01	V	0.35	V	0.91	V	0.17	V	5.65	V	0.08
10/04/24	V	0.01	V	0.43	V	0.95	V	0.12	V	6.66	V	0.09
11/04/24	V	0.00	V	0.35	V	0.94	V	0.12	V	6.73	V	0.23
12/04/24	V	0.03	V	0.33	V	0.93	V	0.15	V	4.41	V	0.08
13/04/24	V	0.00	V	0.35	V	0.91	V	0.13	V	3.26	V	0.16
14/04/24	V	0.00	V	0.35	V	0.92	V	0.09	V	3.66	V	0.26
15/04/24	V	0.01	V	0.40	V	0.95	V	0.09	V	6.45	V	0.26
16/04/24	V	0.00	V	0.47	V	0.96	V	0.03	V	5.45	V	0.30
17/04/24	V	0.00	V	0.44	V	0.95	V	0.05	V	4.83	V	0.31
18/04/24	V	0.00	V	0.47	V	0.92	V	0.08	V	7.51	V	0.44
19/04/24	V	0.00	V	0.44	V	0.94	V	0.10	V	8.66	V	0.24
20/04/24	V	0.00	V	0.54	V	0.92	V	0.12	V	8.02	V	0.72
21/04/24	V	0.00	V	0.54	V	0.94	V	0.07	V	6.88	V	0.65
22/04/24	V	0.00	V	0.58	V	0.93	V	0.14	V	7.43	V	0.83
23/04/24	V	0.00	V	0.57	V	0.95	V	0.20	V	8.19	V	1.23
24/04/24	V	0.00	V	0.50	V	0.93	V	0.24	V	9.27	V	0.74
25/04/24	V	0.01	V	0.42	V	0.91	V	0.11	V	8.84	V	0.39
26/04/24	V	0.00	V	0.48	V	0.92	V	0.13	V	8.84	V	0.47
27/04/24	V	0.00	V	0.40	V	0.93	V	0.18	V	4.54	V	0.40
28/04/24	V	0.00	V	0.36	V	0.93	V	0.15	V	4.59	V	0.19
29/04/24	V	0.00	V	0.36	V	0.92	V	0.12	V	4.67	V	0.19
30/04/24	V	0.00	V	0.42	V	0.93	V	0.08	V	4.37	V	0.15
MAV		0.00		0.43		0.93		0.12		6.59		0.35

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2024

Date of creation: 01/05/2024 05:30

Date	NOx		NH <sub>3</sub>		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	150.00	DLV:	10.00								
01/04/24	V	105.50	V	2.01	V	8.96	V	19.07	V	58.58	V	985.90
02/04/24	V	104.28	V	1.86	V	9.24	V	18.35	V	57.10	V	980.63
03/04/24	V	107.30	V	0.31	V	8.88	V	15.25	V	53.11	V	981.72
04/04/24	V	115.27	V	0.26	V	9.16	V	14.54	V	52.73	V	998.83
05/04/24	V	109.71	V	0.19	V	8.86	V	15.10	V	53.20	V	997.16
06/04/24	V	114.33	V	0.25	V	9.03	V	15.49	V	53.57	V	997.17
07/04/24	V	116.33	V	0.23	V	8.77	V	15.81	V	54.48	V	1004.62
08/04/24	V	122.18	V	0.43	V	9.00	V	17.93	V	57.08	V	1001.90
09/04/24	V	115.08	V	0.57	V	9.08	V	19.34	V	58.90	V	997.89
10/04/24	V	108.74	V	0.71	V	9.68	V	16.15	V	54.43	V	1003.33
11/04/24	V	111.73	V	0.29	V	9.28	V	16.30	V	55.65	V	1013.76
12/04/24	V	113.65	V	0.30	V	9.37	V	18.08	V	57.85	V	1010.29
13/04/24	V	108.48	V	0.37	V	9.17	V	17.90	V	57.31	V	1003.74
14/04/24	V	109.48	V	0.24	V	8.96	V	17.80	V	57.03	V	995.16
15/04/24	V	112.77	V	0.18	V	9.18	V	15.68	V	54.05	V	991.23
16/04/24	V	116.48	V	0.14	V	9.13	V	15.85	V	54.05	V	983.65
17/04/24	V	108.67	V	0.40	V	9.18	V	15.69	V	53.84	V	987.81
18/04/24	V	103.04	V	0.33	V	9.11	V	14.38	V	52.02	V	993.18
19/04/24	V	105.91	V	0.15	V	9.21	V	14.44	V	52.00	V	990.33
20/04/24	V	108.77	V	0.10	V	9.18	V	12.07	V	48.45	V	995.47
21/04/24	V	108.71	V	0.11	V	9.12	V	13.81	V	51.75	V	1004.35
22/04/24	V	104.63	V	0.10	V	9.18	V	12.48	V	49.11	V	998.45
23/04/24	V	94.43	V	0.34	V	9.24	V	12.83	V	50.06	V	1004.88
24/04/24	V	89.92	V	0.83	V	9.21	V	13.56	V	50.77	V	996.37
25/04/24	V	85.58	V	3.03	V	9.11	V	15.36	V	53.19	V	989.68
26/04/24	V	101.28	V	0.92	V	9.14	V	15.14	V	53.35	V	997.81
27/04/24	V	116.02	V	0.26	V	9.25	V	15.31	V	53.87	V	1003.94
28/04/24	V	130.34	V	0.19	V	9.21	V	16.03	V	55.01	V	1009.10
29/04/24	V	121.12	V	0.19	V	9.07	V	17.84	V	57.74	V	1012.66
30/04/24	V	120.41	V	0.15	V	9.20	V	17.62	V	57.53	V	1013.96
MAV		109.67		0.51		9.14		15.83		54.25		998.18

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant:

Report time: Apr/ 2024

Date of creation: 01/05/2024 05:30

Date	Srautas		Degimo T					
	Unit:	Nm <sup>3</sup> /h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/04/24	V	123844.77	V	976.91				
02/04/24	V	118533.57	V	972.80				
03/04/24	V	122901.54	V	969.16				
04/04/24	V	126440.72	V	971.46				
05/04/24	V	123707.92	V	983.33				
06/04/24	V	124010.37	V	984.54				
07/04/24	V	123783.84	V	983.07				
08/04/24	V	124052.91	V	975.34				
09/04/24	V	124946.68	V	970.61				
10/04/24	V	117910.53	V	958.61				
11/04/24	V	129136.08	V	958.68				
12/04/24	V	128928.89	V	971.71				
13/04/24	V	126636.59	V	978.28				
14/04/24	V	125780.02	V	974.72				
15/04/24	V	126498.40	V	968.72				
16/04/24	V	126001.06	V	978.39				
17/04/24	V	126385.74	V	974.76				
18/04/24	V	126031.55	V	976.69				
19/04/24	V	126059.49	V	979.40				
20/04/24	V	126647.51	V	977.47				
21/04/24	V	127252.75	V	980.26				
22/04/24	V	129426.25	V	980.83				
23/04/24	V	128763.42	V	973.19				
24/04/24	V	126924.37	V	967.98				
25/04/24	V	125875.12	V	963.52				
26/04/24	V	127091.33	V	964.43				
27/04/24	V	127440.34	V	966.92				
28/04/24	V	128009.19	V	964.27				
29/04/24	V	128680.38	V	965.30				
30/04/24	V	129255.79	V	956.84				
MAV		125916.74		972.29				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value