

# Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2024

Date of creation: 01/06/2024 05:30

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	5.00	DLV:	6.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/05/24	V	0.00	V	0.33	V	0.94	V	0.06	V	4.79	V	0.14
02/05/24	V	0.00	V	0.35	V	0.95	V	0.12	V	4.49	V	0.10
03/05/24	V	0.01	V	0.38	V	0.94	V	0.07	V	8.22	V	0.09
04/05/24	V	0.01	V	0.35	V	0.93	V	0.12	V	7.78	V	0.11
05/05/24	V	0.01	V	0.28	V	0.92	V	0.07	V	7.72	V	0.13
06/05/24	V	0.01	V	0.31	V	0.91	V	0.08	V	8.12	V	0.10
07/05/24	V	0.00	V	0.48	V	0.97	V	0.03	V	5.58	V	0.44
08/05/24	V	0.01	V	0.47	V	0.98	V	0.03	V	6.63	V	0.45
09/05/24	V	0.01	V	0.37	V	0.97	V	0.04	V	5.62	V	0.35
10/05/24	V	0.00	V	0.30	V	0.93	V	0.13	V	4.41	V	0.16
11/05/24	V	0.00	V	0.39	V	0.98	V	0.05	V	5.92	V	0.45
12/05/24	V	0.04	V	0.41	V	0.96	V	0.08	V	4.98	V	0.35
13/05/24	V	0.01	V	0.38	V	0.93	V	0.12	V	4.67	V	0.17
14/05/24	V	0.01	V	0.32	V	0.93	V	0.10	V	5.06	V	0.14
15/05/24	V	0.00	V	0.39	V	0.93	V	0.09	V	4.90	V	0.14
16/05/24	V	0.11	V	0.41	V	0.91	V	0.08	V	4.04	V	0.16
17/05/24	V	0.26	V	0.39	V	1.50	V	0.15	V	8.26	V	0.15
18/05/24	V	0.06	V	0.35	V	0.92	V	0.18	V	6.90	V	0.11
19/05/24	V	0.02	V	0.30	V	0.93	V	0.17	V	6.21	V	0.15
20/05/24	V	0.00	V	0.33	V	0.94	V	0.14	V	9.82	V	0.06
21/05/24	V	0.04	V	0.41	V	0.93	V	0.07	V	7.09	V	0.08
22/05/24	V	0.01	V	0.32	V	0.93	V	0.18	V	7.29	V	0.09
23/05/24	V	0.07	V	0.40	V	0.94	V	0.11	V	7.25	V	0.03
24/05/24	V	0.08	V	0.34	V	0.93	V	0.22	V	5.60	V	0.07
25/05/24	V	0.09	V	0.41	V	0.93	V	0.16	V	4.25	V	0.05
26/05/24	V	0.00	V	0.35	V	0.93	V	0.15	V	5.70	V	0.09
27/05/24	V	0.00	V	0.36	V	0.93	V	0.22	V	6.63	V	0.05
28/05/24	V	0.13	V	0.36	V	0.93	V	0.26	V	5.58	V	0.08
29/05/24	V	0.01	V	0.32	V	0.93	V	0.28	V	6.98	V	0.01
30/05/24	V	0.00	V	0.36	V	0.93	V	0.16	V	5.81	V	0.07
31/05/24	V	0.00	V	0.39	V	0.94	V	0.12	V	5.43	V	0.09
MAV		0.03		0.37		0.96		0.12		6.17		0.15

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

**Mėnesinė ataskaita**



Plant: Kauno kogeneracinė jėgainė

Report time: May/ 2024

Date of creation: 01/06/2024 05:30

Date	NOx		NH <sub>3</sub>		O <sub>2</sub>		H <sub>2</sub> O		Kamino T		Slėgis	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	150.00	DLV:	10.00								
01/05/24	V	107.19	V	0.27	V	9.16	V	18.65	V	58.82	V	1008.76
02/05/24	V	92.24	V	0.46	V	9.16	V	18.85	V	58.77	V	1003.32
03/05/24	V	97.38	V	0.26	V	9.15	V	17.36	V	56.91	V	1002.10
04/05/24	V	95.72	V	0.35	V	9.14	V	17.50	V	56.89	V	1000.56
05/05/24	V	95.72	V	0.75	V	8.91	V	18.39	V	57.81	V	996.44
06/05/24	V	85.29	V	0.72	V	9.04	V	18.15	V	57.02	V	991.84
07/05/24	V	96.46	V	0.38	V	9.01	V	17.20	V	56.77	V	1000.61
08/05/24	V	86.90	V	0.54	V	9.10	V	17.21	V	57.35	V	1010.96
09/05/24	V	97.99	V	0.35	V	9.10	V	17.51	V	57.68	V	1011.50
10/05/24	V	97.86	V	0.40	V	9.14	V	17.54	V	56.89	V	1003.71
11/05/24	V	98.88	V	0.44	V	9.22	V	16.96	V	56.86	V	1007.83
12/05/24	V	114.42	V	0.21	V	9.05	V	16.78	V	56.59	V	1009.94
13/05/24	V	107.26	V	0.18	V	8.95	V	16.59	V	55.96	V	1007.31
14/05/24	V	111.37	V	0.25	V	9.07	V	18.11	V	57.90	V	1006.09
15/05/24	V	106.42	V	0.33	V	9.23	V	17.05	V	56.59	V	1009.85
16/05/24	V	107.85	V	0.11	V	9.15	V	15.19	V	53.93	V	1011.60
17/05/24	V	97.66	V	0.19	V	9.57	V	15.06	V	53.28	V	1008.62
18/05/24	V	102.29	V	0.26	V	9.16	V	18.34	V	57.77	V	1003.32
19/05/24	V	108.13	V	0.35	V	8.99	V	18.86	V	58.42	V	1000.29
20/05/24	V	95.13	V	0.45	V	9.17	V	18.71	V	58.19	V	1000.41
21/05/24	V	114.61	V	0.41	V	9.02	V	19.26	V	58.87	V	1002.80
22/05/24	V	127.88	V	0.27	V	9.24	V	18.58	V	57.97	V	1002.81
23/05/24	V	117.70	V	0.22	V	9.38	V	18.30	V	57.59	V	1004.89
24/05/24	V	109.34	V	0.27	V	9.19	V	18.20	V	57.59	V	1008.93
25/05/24	V	103.70	V	0.35	V	9.20	V	18.53	V	58.04	V	1009.59
26/05/24	V	103.50	V	0.32	V	9.08	V	18.50	V	58.18	V	1010.49
27/05/24	V	105.71	V	0.21	V	9.14	V	17.84	V	57.35	V	1009.47
28/05/24	V	136.17	V	0.40	V	9.08	V	19.04	V	58.85	V	1006.06
29/05/24	V	124.22	V	0.32	V	9.08	V	19.34	V	59.08	V	999.25
30/05/24	V	99.47	V	0.86	V	9.19	V	19.33	V	58.65	V	996.54
31/05/24	V	109.79	V	0.72	V	9.32	V	18.74	V	57.64	V	996.75
MAV		104.34		0.38		9.14		17.89		57.38		1004.71

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: May/ 2024

Date of creation: 01/06/2024 05:30

Date	Srautas		Degimo T					
	Unit:	Nm³/h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/05/24	V	130732.88	V	964.43				
02/05/24	V	128228.17	V	958.78				
03/05/24	V	127547.45	V	954.34				
04/05/24	V	127410.26	V	965.46				
05/05/24	V	126781.36	V	961.71				
06/05/24	V	125741.88	V	968.96				
07/05/24	V	127331.78	V	964.77				
08/05/24	V	129042.23	V	963.24				
09/05/24	V	128724.44	V	958.85				
10/05/24	V	126306.01	V	965.88				
11/05/24	V	128187.52	V	960.88				
12/05/24	V	127597.29	V	966.26				
13/05/24	V	127559.28	V	971.12				
14/05/24	V	128347.02	V	972.01				
15/05/24	V	128282.63	V	971.23				
16/05/24	V	127784.30	V	974.02				
17/05/24	V	129038.78	V	956.24				
18/05/24	V	126759.64	V	971.75				
19/05/24	V	127194.97	V	976.88				
20/05/24	V	127511.93	V	979.73				
21/05/24	V	126452.90	V	983.74				
22/05/24	V	126716.43	V	993.91				
23/05/24	V	127537.05	V	992.07				
24/05/24	V	126050.72	V	982.12				
25/05/24	V	125763.90	V	975.19				
26/05/24	V	125960.49	V	971.05				
27/05/24	V	126936.14	V	966.15				
28/05/24	V	126347.61	V	984.09				
29/05/24	V	125219.10	V	972.60				
30/05/24	V	126689.90	V	977.02				
31/05/24	V	124655.71	V	977.93				
MAV		127289.03		970.90				

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value