

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2024

Date of creation: 01/08/2024 05:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	5.00	DLV:	6.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/07/24	V	0.03	V	0.35	V	0.94	V	0.27	V	4.80	V	0.01
02/07/24	V	0.03	V	0.34	V	0.94	V	0.13	V	6.96	V	0.07
03/07/24	V	0.06	V	0.35	V	0.92	V	0.19	V	6.61	V	0.06
04/07/24	V	0.06	V	0.39	V	0.93	V	0.22	V	7.98	V	0.04
05/07/24	V	0.05	V	0.47	V	0.92	V	0.18	V	11.28	V	0.07
06/07/24	V	0.01	V	0.38	V	0.90	V	0.29	V	9.37	V	0.08
07/07/24	V	0.12	V	0.48	V	0.91	V	0.24	V	6.07	V	0.04
08/07/24	V	0.09	V	0.42	V	0.92	V	0.23	V	7.89	V	0.08
09/07/24	V	0.00	V	0.37	V	0.91	V	0.29	V	5.83	V	0.08
10/07/24	V	0.00	V	0.38	V	0.93	V	0.24	V	5.38	V	0.05
11/07/24	V	0.01	V	0.39	V	0.89	V	0.21	V	6.34	V	0.04
12/07/24	V	0.00	V	0.30	V	0.92	V	0.19	V	6.70	V	0.05
13/07/24	V	0.01	V	0.34	V	0.93	V	0.16	V	6.21	V	0.05
14/07/24	V	0.04	V	0.40	V	0.92	V	0.12	V	5.20	V	0.05
15/07/24	V	0.01	V	0.36	V	0.91	V	0.16	V	6.38	V	0.05
16/07/24	V	0.02	V	0.31	V	0.92	V	0.18	V	5.64	V	0.08
17/07/24	V	0.01	V	0.31	V	0.95	V	0.14	V	6.92	V	0.09
18/07/24	V	0.00	V	0.32	V	0.95	V	0.14	V	6.56	V	0.02
19/07/24	V	0.00	V	0.30	V	0.94	V	0.17	V	6.09	V	0.06
20/07/24	V	0.00	V	0.40	V	0.95	V	0.23	V	6.46	V	0.11
21/07/24	V	0.01	V	0.33	V	0.93	V	0.27	V	6.57	V	0.08
22/07/24	V	0.04	V	0.31	V	0.93	V	0.25	V	6.84	V	0.11
23/07/24	V	0.02	V	0.31	V	0.92	V	0.25	V	5.74	V	0.11
24/07/24	V	0.01	V	0.36	V	0.96	V	0.19	V	7.75	V	0.09
25/07/24	V	0.00	V	0.47	V	0.96	V	0.21	V	6.55	V	0.08
26/07/24	V	0.00	V	0.39	V	0.96	V	0.22	V	5.89	V	0.10
27/07/24	V	0.00	V	0.36	V	0.96	V	0.33	V	5.35	V	0.12
28/07/24	V	0.05	V	0.41	V	0.94	V	0.22	V	5.72	V	0.12
29/07/24	V	0.04	V	0.50	V	0.94	V	0.26	V	5.69	V	0.18
30/07/24	V	0.06	V	0.47	V	0.97	V	0.26	V	8.13	V	0.06
31/07/24	V	0.16	V	0.55	V	0.95	V	0.28	V	12.20	V	0.08
MAV		0.03		0.38		0.93		0.22		6.81		0.07

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2024

Date of creation: 01/08/2024 05:30

Date	NOx		NH ₃		O ₂		H ₂ O		Kamino T		Slėgis	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa
	DLV:	150.00	DLV:	10.00								
01/07/24	V	123.24	V	0.58	V	9.10	V	19.74	V	58.70	V	991.92
02/07/24	V	116.46	V	0.45	V	9.12	V	18.85	V	57.84	V	991.71
03/07/24	V	116.94	V	0.27	V	9.07	V	18.05	V	56.69	V	991.44
04/07/24	V	109.78	V	0.37	V	9.12	V	18.29	V	57.04	V	993.13
05/07/24	V	115.33	V	0.28	V	9.01	V	17.22	V	55.65	V	994.41
06/07/24	V	125.13	V	0.22	V	8.80	V	17.96	V	57.17	V	997.44
07/07/24	V	124.25	V	0.29	V	9.00	V	18.97	V	58.00	V	998.15
08/07/24	V	117.76	V	0.23	V	9.08	V	18.05	V	57.43	V	1005.47
09/07/24	V	109.75	V	0.36	V	9.10	V	18.49	V	58.00	V	1009.14
10/07/24	V	111.23	V	0.45	V	9.17	V	19.05	V	58.76	V	1009.01
11/07/24	V	115.56	V	0.38	V	9.00	V	19.30	V	58.65	V	1003.29
12/07/24	V	105.91	V	0.85	V	9.11	V	19.32	V	58.36	V	1001.35
13/07/24	V	110.82	V	1.03	V	9.07	V	20.31	V	59.55	V	996.11
14/07/24	V	105.21	V	0.67	V	8.98	V	19.63	V	59.14	V	1001.04
15/07/24	V	101.86	V	0.37	V	9.21	V	17.14	V	55.63	V	1002.64
16/07/24	V	119.36	V	0.88	V	9.18	V	20.25	V	59.92	V	1001.45
17/07/24	V	102.96	V	1.15	V	9.39	V	20.10	V	59.57	V	1001.40
18/07/24	V	103.79	V	3.47	V	9.27	V	19.77	V	59.50	V	1005.56
19/07/24	V	99.59	V	1.98	V	9.39	V	18.74	V	58.06	V	1005.11
20/07/24	V	104.16	V	0.90	V	9.43	V	19.21	V	58.48	V	1000.49
21/07/24	V	108.57	V	0.47	V	9.14	V	19.89	V	59.34	V	997.16
22/07/24	V	101.45	V	0.45	V	9.32	V	19.03	V	58.07	V	997.95
23/07/24	V	94.30	V	0.71	V	9.16	V	20.08	V	59.46	V	999.38
24/07/24	V	113.65	V	0.70	V	9.32	V	19.40	V	58.46	V	998.92
25/07/24	V	105.91	V	0.60	V	9.42	V	18.37	V	56.97	V	996.67
26/07/24	V	109.72	V	0.35	V	9.30	V	17.86	V	56.31	V	998.73
27/07/24	V	106.36	V	0.43	V	9.30	V	19.59	V	59.06	V	1001.53
28/07/24	V	113.99	V	0.36	V	9.17	V	19.66	V	58.75	V	995.33
29/07/24	V	99.61	V	0.24	V	9.33	V	17.22	V	55.30	V	991.52
30/07/24	V	93.14	V	1.61	V	9.70	V	16.81	V	54.83	V	999.06
31/07/24	V	98.25	V	0.35	V	9.97	V	13.73	V	50.22	V	997.92
MAV		109.14		0.69		9.22		18.71		57.71		999.19

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant:

Report time: Jul/ 2024

Date of creation: 01/08/2024 05:30

Date	Srautas		Degimo T					
	Unit:	Nm³/h	Unit:	°C				
	DLV:	240000.00	DLV:	850.00				
01/07/24	V	125630.28	V	960.37				
02/07/24	V	125522.29	V	952.06				
03/07/24	V	125444.45	V	952.19				
04/07/24	V	124225.74	V	956.60				
05/07/24	V	123800.48	V	965.09				
06/07/24	V	123612.38	V	972.73				
07/07/24	V	124184.14	V	971.45				
08/07/24	V	125360.78	V	972.68				
09/07/24	V	125741.35	V	963.85				
10/07/24	V	126016.45	V	966.82				
11/07/24	V	124198.20	V	962.81				
12/07/24	V	124128.02	V	953.97				
13/07/24	V	124494.93	V	958.24				
14/07/24	V	124983.20	V	957.45				
15/07/24	V	125633.08	V	951.79				
16/07/24	V	128332.17	V	955.41				
17/07/24	V	128009.37	V	946.63				
18/07/24	V	128498.75	V	944.63				
19/07/24	V	126974.16	V	942.75				
20/07/24	V	125785.47	V	943.69				
21/07/24	V	125345.31	V	954.03				
22/07/24	V	124123.43	V	945.90				
23/07/24	V	123719.30	V	942.49				
24/07/24	V	124169.92	V	943.96				
25/07/24	V	124151.49	V	939.59				
26/07/24	V	124092.88	V	942.30				
27/07/24	V	125794.09	V	947.21				
28/07/24	V	124049.05	V	951.22				
29/07/24	V	121953.60	V	949.05				
30/07/24	V	117489.85	V	937.70				
31/07/24	V	113726.94	V	932.16				
MAV		124488.69		952.79				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value