

Mėnesinė ataskaita



Plant: Kauno kogeneraci

Report time: saus.- 2025

Date of creation: 01-02-2025 05:01

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	5.00	DLV:	6.00	DLV:	30,00	DLV:	1,00	DLV:	50,00	DLV:	10,00
01-01-25	M	0,00	V	0,73	V	0,97	V	0,21	V	10,40	V	0,24
02-01-25	M	0,00	V	0,72	V	1,00	V	0,19	V	9,81	V	0,23
03-01-25	M	0,00	V	0,71	V	0,95	V	0,19	V	7,68	V	0,43
04-01-25	M	0,00	V	0,71	V	0,87	V	0,20	V	7,82	V	0,24
05-01-25	M	0,00	V	0,72	V	0,71	V	0,20	V	8,02	V	0,32
06-01-25	M	0,00	V	0,71	V	0,66	V	0,18	V	13,55	V	0,46
07-01-25	M	0,00	V	0,71	V	0,75	V	0,22	V	9,41	V	0,33
08-01-25	M	0,00	V	0,73	V	0,86	V	0,20	V	8,86	V	0,22
09-01-25	M	0,00	V	0,71	V	0,81	V	0,20	V	11,33	V	0,38
10-01-25	M	0,00	V	0,73	V	0,86	V	0,20	V	10,83	V	0,31
11-01-25	M	0,00	V	0,71	V	0,87	V	0,21	V	12,77	V	0,24
12-01-25	M	0,00	V	0,72	V	0,85	V	0,19	V	8,90	V	0,38
13-01-25	M	0,00	V	0,70	V	0,73	V	0,17	V	6,29	V	0,32
14-01-25	M	0,00	V	0,71	V	0,67	V	0,18	V	9,10	V	0,38
15-01-25	M	0,00	V	0,73	V	0,68	V	0,23	V	12,04	V	0,34
16-01-25	M	0,00	V	0,73	V	0,79	V	0,24	V	9,05	V	0,46
17-01-25	M	0,00	V	0,74	V	0,91	V	0,23	V	7,48	V	0,25
18-01-25	M	0,00	V	0,77	V	0,97	V	0,24	V	6,61	V	0,24
19-01-25	M	0,00	V	0,74	V	0,95	V	0,21	V	9,87	V	0,26
20-01-25	M	0,00	V	0,72	V	0,81	V	0,19	V	9,87	V	0,22
21-01-25	M	0,00	V	0,71	V	0,77	V	0,21	V	9,34	V	0,20
22-01-25	M	0,00	V	0,72	V	1,43	V	0,20	V	7,77	V	0,15
23-01-25	M	0,00	V	0,71	V	0,69	V	0,20	V	7,33	V	0,17
24-01-25	M	0,00	V	0,73	V	0,85	V	0,20	V	7,48	V	0,23
25-01-25	M	0,00	V	0,74	V	0,74	V	0,20	V	6,83	V	0,21
26-01-25	M	0,00	V	0,75	V	0,95	V	0,19	V	6,07	V	0,52
27-01-25	M	0,00	V	0,76	V	0,95	V	0,20	V	5,71	V	0,28
28-01-25	M	0,00	V	0,76	V	0,98	V	0,21	V	6,66	V	0,17
29-01-25	M	0,00	V	0,75	V	1,02	V	0,23	V	5,94	V	0,21
30-01-25	M	0,00	V	0,74	V	0,98	V	0,22	V	6,78	V	0,20
31-01-25	M	0,00	V	0,73	V	0,98	V	0,20	V	6,93	V	0,19
MAV		0,00		0,73		0,87		0,21		8,59		0,28

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneraci

Report time: saus.- 2025

Date of creation: 01-02-2025 05:01

Date	NOx		NH ₃		Hg		O ₂		H ₂ O		Kamino T	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C
DLV:	150.00	DLV:	10.00	DLV:	0.02							
01-01-25	V	101,86	V	1,03	V	0,0027	V	8,75	M	14,27	V	51,66
02-01-25	V	104,31	V	1,11	V	0,0027	V	8,72	V	14,34	V	51,13
03-01-25	V	111,97	V	0,88	V	0,0027	V	8,77	V	12,53	V	49,03
04-01-25	V	116,56	V	0,90	V	0,0027	V	8,85	V	12,83	V	49,66
05-01-25	V	107,20	V	0,96	V	0,0027	V	8,79	V	13,00	V	50,28
06-01-25	V	94,90	V	0,94	V	0,0027	V	8,72	V	12,42	V	48,92
07-01-25	V	100,06	V	0,92	V	0,0027	V	8,84	V	12,44	V	48,56
08-01-25	V	96,75	V	0,96	V	0,0027	V	8,87	V	14,00	V	51,13
09-01-25	V	98,32	V	0,94	V	0,0027	V	8,82	V	12,71	V	49,32
10-01-25	V	109,71	V	0,98	V	0,0028	V	8,88	V	14,27	V	51,38
11-01-25	V	106,04	V	1,01	V	0,0027	V	8,78	V	12,46	V	48,97
12-01-25	V	102,70	V	0,94	V	0,0027	V	8,81	V	12,82	V	49,80
13-01-25	V	98,25	V	1,11	V	0,0027	V	8,95	V	12,01	V	50,18
14-01-25	V	95,20	V	1,15	V	0,0028	V	9,21	V	11,61	V	50,34
15-01-25	V	94,37	V	0,99	V	0,0028	V	9,13	V	13,06	V	49,83
16-01-25	V	103,07	V	1,02	V	0,0028	V	9,05	V	13,40	V	50,49
17-01-25	V	107,59	V	0,99	V	0,0028	V	9,10	V	14,26	V	51,80
18-01-25	V	104,27	V	1,02	V	0,0029	V	9,12	V	16,94	V	56,05
19-01-25	V	94,77	V	1,00	V	0,0028	V	8,99	V	15,25	V	53,34
20-01-25	V	100,08	V	0,91	V	0,0027	V	8,85	V	13,15	V	50,09
21-01-25	V	106,18	V	0,98	V	0,0027	V	8,88	V	12,20	V	48,73
22-01-25	V	116,77	V	0,97	V	0,0027	V	8,95	V	12,88	V	49,54
23-01-25	V	107,46	V	0,98	V	0,0027	V	8,91	V	12,23	V	48,53
24-01-25	V	97,12	V	0,93	V	0,0028	V	8,92	V	13,80	V	50,77
25-01-25	V	87,15	V	1,04	V	0,0028	V	9,11	V	14,00	V	51,42
26-01-25	V	99,94	V	0,98	V	0,0028	V	8,88	V	16,36	V	54,91
27-01-25	V	117,53	V	0,99	V	0,0028	V	9,07	V	16,19	V	54,54
28-01-25	V	107,89	V	1,00	V	0,0028	V	9,11	V	15,90	V	53,96
29-01-25	V	105,47	V	1,00	V	0,0028	V	9,01	V	16,35	V	54,68
30-01-25	V	91,52	V	0,99	V	0,0028	V	8,91	V	15,70	V	54,11
31-01-25	V	97,37	V	0,98	V	0,0028	V	8,99	V	14,07	V	51,26
MAV		102,66		0,99		0,0027		8,93		13,79		51,11

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant:

Report time: saus.- 2025

Date of creation: 01-02-2025 05:01

Date	Slėgis		Srautas		Degimo T	
	Unit:	hPa	Unit:	Nm³/h	Unit:	°C
			DLV:	240000,00	DLV:	850,00
01-01-25	V	991,50	V	126140,19	V	976,04
02-01-25	V	982,98	V	125161,09	V	972,03
03-01-25	V	987,97	V	128303,32	V	965,94
04-01-25	V	992,43	V	129113,87	V	971,94
05-01-25	V	997,30	V	129613,18	V	973,25
06-01-25	V	989,68	V	127951,46	V	965,17
07-01-25	V	987,65	V	126677,88	V	956,67
08-01-25	V	988,18	V	126747,69	V	965,77
09-01-25	V	992,10	V	129246,98	V	976,12
10-01-25	V	985,47	V	128376,59	V	969,75
11-01-25	V	990,50	V	128660,05	V	964,38
12-01-25	V	1004,05	V	129910,43	V	974,62
13-01-25	V	1020,90	V	131731,26	V	970,50
14-01-25	V	1008,52	V	132730,76	V	971,01
15-01-25	V	1009,60	V	127517,55	V	965,29
16-01-25	V	1015,79	V	129699,18	V	980,43
17-01-25	V	1015,54	V	127794,03	V	971,34
18-01-25	V	1013,04	V	128085,57	V	972,14
19-01-25	V	1012,79	V	126566,48	V	979,95
20-01-25	V	1012,12	V	128072,85	V	991,91
21-01-25	V	1006,79	V	128746,30	V	976,45
22-01-25	V	1003,75	V	128256,35	V	998,72
23-01-25	V	998,44	V	126909,64	V	995,07
24-01-25	V	999,86	V	125424,29	V	987,13
25-01-25	V	998,40	V	125904,47	V	985,92
26-01-25	V	996,86	V	125268,93	V	986,47
27-01-25	V	993,94	V	124712,11	V	992,07
28-01-25	V	992,02	V	124592,74	V	991,49
29-01-25	V	990,60	V	124312,98	V	993,91
30-01-25	V	1001,69	V	124101,36	V	985,82
31-01-25	V	1004,13	V	125035,67	V	986,21
MAV		999,52		127465,05		977,88

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value