

# Mėnesinė ataskaita

Plant: Kauno kogeneraci

Report time: geg.- 2025

Date of creation: 12-05-2025 05:01

Date	Dulkės		HCl		SO <sub>2</sub>		HF		CO		BOA	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>
	DLV:	5,00	DLV:	6,00	DLV:	30,00	DLV:	1,00	DLV:	50,00	DLV:	10,00
01-05-25	V	0,02	V	0,75	V	1,15	V	0,34	V	7,03	V	0,40
02-05-25	V	0,03	V	0,74	V	1,16	V	0,32	V	6,08	V	0,43
03-05-25	V	0,04	V	0,75	V	1,10	V	0,25	V	7,88	V	0,19
04-05-25	V	0,05	V	0,76	V	1,17	V	0,29	V	8,95	V	0,12
05-05-25	V	0,05	V	0,76	V	1,19	V	0,26	V	7,41	V	0,28
06-05-25	V	0,14	V	0,76	V	1,21	V	0,33	V	7,70	V	0,20
07-05-25	V	0,22	V	0,75	V	1,20	V	0,31	V	8,70	V	0,66
08-05-25	V	0,38	V	0,75	V	1,33	V	0,28	V	6,72	V	0,81
09-05-25	N	0,00	N	0,00	N	0,00	N	0,00	N	0,00	N	0,00
10-05-25	V	0,00	V	0,79	V	1,20	V	0,40	V	23,77	V	0,73
11-05-25	V	0,03	V	0,77	V	1,18	V	0,38	V	9,62	V	0,38
MAV		0,10		0,75		1,19		0,31		8,22		0,39

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

# Mēnesinē ataskaita

Plant: Kauno kogeneraci

Report time: geg.- 2025

Date of creation: 12-05-2025 05:01

Date	NOx		NH <sub>3</sub>		Hg		O <sub>2</sub>		H <sub>2</sub> O		Kamino T	
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	Vol%	Unit:	Vol%	Unit:	°C
	DLV:	150.00	DLV:	10.00	DLV:	0.02						
01-05-25	V	93,92	V	1,06	V	0,0029	V	9,06	V	15,50	V	53,96
02-05-25	V	89,35	V	1,08	V	0,0028	V	8,87	V	16,18	V	54,93
03-05-25	V	85,65	V	1,12	V	0,0028	V	8,79	V	17,33	V	55,81
04-05-25	V	81,76	V	1,14	V	0,0029	V	8,95	V	16,95	V	55,14
05-05-25	V	91,33	V	1,16	V	0,0029	V	9,02	V	16,79	V	55,67
06-05-25	V	94,46	V	1,08	V	0,0029	V	9,03	V	16,53	V	55,40
07-05-25	V	88,09	V	1,11	V	0,0029	V	9,06	V	16,18	V	55,14
08-05-25	V	93,76	V	1,11	V	0,0029	V	9,02	V	16,23	V	55,23
09-05-25	N	0,00	N	0,00	N	0,0000	N	0,00	N	0,00	N	0,00
10-05-25	V	106,43	T	1,09	T	0,0031	V	9,88	V	13,81	V	51,16
11-05-25	V	120,33	V	1,12	V	0,0029	V	9,38	V	15,51	V	53,99
MAV		93,50		1,11		0,0029		9,04		16,29		54,92

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value

Plant:

Report time: geg.- 2025

Date of creation: 12-05-2025 05:01

Date	Slėgis		Srautas		Degimo T	
	Unit:	hPa	Unit:	Nm³/h	Unit:	°C
			DLV:	240000,00	DLV:	850,00
01-05-25	V	1008,85	V	130450,57	V	967,84
02-05-25	V	1004,08	V	128977,59	V	968,32
03-05-25	V	993,51	V	126632,67	V	967,83
04-05-25	V	989,44	V	126181,04	V	966,99
05-05-25	V	999,85	V	128671,06	V	974,51
06-05-25	V	1002,96	V	129748,36	V	968,01
07-05-25	V	1005,81	V	130165,28	V	962,43
08-05-25	V	1006,66	V	130201,93	V	968,58
09-05-25	N	0,00	N	0,00	N	0,00
10-05-25	V	1006,95	V	121866,81	V	971,72
11-05-25	V	1007,36	V	127368,89	V	984,71
MAV		1002,07		128493,83		969,98

The status refer to the plant:

V: Valid    T: <2/3    M: Maintenance    N: undefined    MAV: Month average value